

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q873

Asset: I.S. 73 MINISCHOOL - QUEENS, 70-02 54TH AVENUE, New York, 11378

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q873	Electrical	2023-12-19 7:56 AM	2024-02-29 2:30 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Fire Alarm System
	Years: Under construction
	Systems: IPDVS/CCTV System, Intrusion Alarm System (Infrared Sensor)
	Years: 2023
	Systems: Security Lights
	Years: 2022
	Systems: Exit Lights (Battery Pack)
	Years: 2020
	Systems: Public Address System
	Years: 2015
	Systems: Retrofitted Fluorescent Lighting
	Years: 2003
	Systems: All Other Electrical Systems and Components
	Years: 1992

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	Yes
Are dedicated intercoms available in all of these spaces for use during a fire?	Yes
Are all dedicated intercoms operational?	Yes

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Electrical	
AUDITORIUM	Does not Exist
CAFETERIA	Does not Exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q873

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
COMPUTER LAB	Does not Exist
GYMNASIUM	Does not Exist
KITCHEN	Does not Exist
LIBRARY	Does not Exist
LOCKER ROOM	Does not Exist
MULTIPURPOSE ROOM	Does not Exist
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SWIMMING POOL	Does not Exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Replacement Quantity	22,000
Replacement Uom	S.F.
Condition	3 - Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q873

Question	Response
EMERGENCY DC STANDBY BATTERY POWER	Inspected
Deficiency	No deficiencies recorded
EMERGENCY GENERATOR SET	Does not Exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not Exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not Exist
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not Exist
FIRE ALARM SYSTEM	Under Construction
GROUNDING SYSTEM	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Inspected
Elevator	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Holding Area	Does not Exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Does not Exist
LIGHTNING PROTECTION	Does not Exist
MOTOR CONTROLLER	Inspected
Motor Control Center	Does not Exist
Motor Starter/Contactor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Variable Frequency Drive	Does not Exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Does not Exist
Fused Knife Switch Type	Does not Exist
Fused Toggle Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Inspected
Replacement Quantity	22,000
Replacement Uom	S.F.
Instance	Connected to Main Asset Q073

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q873

Question	Response
PUBLIC ADDRESS SYSTEM	
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	2015
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
SECURITY	
	Inspected
IPDVS/CCTV System	
	Inspected
Replacement Quantity	22,000
Replacement Uom	S.F.
Installation Year	2023
Source of Installation	Custodial Staff
Condition	1 - Good
Deficiency	No deficiencies recorded
Intrusion Alarm System	
	Inspected
Replacement Quantity	22,000
Replacement Uom	S.F.
Central Control Panel	
	Does not Exist
Infrared Sensor	
	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Panic Switch	
	Does not Exist
Remote Annunciator	
	Does not Exist
Siren/Strobe	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting - Security	
	Inspected
Replacement Uom	EACH
Condition	1 - Good
Deficiency	No deficiencies recorded
SERVICE SWITCH	
	Does not Exist
SWITCHBOARD	
	Inspected
Number of Spares	3
Fused Disconnect Switch Type	
	Does not Exist
Fused Knife Switch Type	
	Does not Exist
Molded Case Circuit Breaker Type	
	Inspected
Instance	Electrical Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Siemens
Equipment	MDP
Capacity/Size Quantity	1,200
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q873

Question	Response
SWITCHBOARD	Inspected
Molded Case Circuit Breaker Type	
Installation Year	1992
Source of Installation	Documented
Deficiency	No deficiencies recorded
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	3 - Fair
Deficiency	TELEPHONE NOT OPERATIONAL
Deficiency Location/Instance	Mechanical Room S201
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE TELEPHONE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Standard	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not Exist