

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q875

Asset: P.S. 233 MINISCHOOL2 (OLD P752)-Q, 114-43 142ND STREET, New York, 11436

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q875	Mechanical	2024-01-16 11:16 AM	2024-01-26 12:46 PM

Asset Data

Question	Answer
Are there fuel tanks?	No
Total # of water main service entries to the asset	1
MERs/Fan Rooms Locations	Attic MER
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Gas Fired Domestic Water Heater
	Years: 2019
	Systems: Gas Fired Furnaces (2 of 3); Gas Distribution Piping (50%)
	Years: 2016
	Systems: Kitchen - Hood Fire Suppression System
	Years: 2015

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Does not Exist
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Inspected
Instance	Attic MER
Instance Condition	3 - Fair
Instance Quantity	3
Instance Quantity Uom	EACH
Source of Heating	N/A
Refrigerant Type	R-22
Instance Manufacturer	Carrier
Equipment	AC-1, AC-2, AC-3
Capacity/Size Quantity	20
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1992
Source of Installation	Documented
Deficiency	No deficiencies recorded
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q875

Question	Response
AIR CONDITIONING	
Refrigerant Leak Detection System	
Refrigerant Piping	Does not Exist
Return Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CENTRAL ACID WASTE NEUTRALIZING TANK	
	Does not Exist
CLIMATE CONTROL SYSTEM	
	Does not Exist
COMPACTOR	
	Does not Exist
CONVEYING	
	Does not Exist
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	Room 108 - Custodian Closet
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Room 108 - Custodian Closet
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	A.O. Smith
Equipment	N/A
Capacity/Size Quantity	275
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	100
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2019
Source of Installation	Documented
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	
	Inspected
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q875

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Does not Exist
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Student's Toilet Room 118, Girls Toilet Room 106
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Student's Toilet Room 118, Boys Toilet Room 136
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q875

Question	Response
FIXTURES	Inspected
Student	
Urinal	Does not Exist
GAS FIRED FURNACE	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not Exist
Gas Meter Room Vent	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Does not Exist
HEATING	Inspected
Heating Coil In Ductwork	Does not Exist
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Does not Exist
Steam Heating	Does not Exist
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Attic MER (1 of 1)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
HEATING PLANT	Does not Exist
Enclosed IDF Room	Does not Exist
KITCHEN	Inspected
Instance on 1st Floor	Inspected
CO Detector	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas System	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Grease Trap	Does not Exist
Instance on 1st Floor	Does not Exist
Hood	Inspected
Instance on 1st Floor	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q875

Question	Response
KITCHEN	
Hood	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hot Water Temperature Booster	Does not Exist
Instance on 1st Floor	Does not Exist
Kitchen Sink	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	Does not Exist
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	No
Condition	3 - Fair
Deficiency	DEFECTIVE REGISTER/DIFFUSER
Deficiency Location/Instance	Rooms 101, 108, Girls Toilet Room 106, Boys Toilet Room 107
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE DUCTWORK

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q875

Question	Response
VENTILATION	
Metal Ductwork	
Deficiency Location/Instance	Attic MER / AC-1
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Attic MER
Deficiency Quantity	60
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist