

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q907

Asset: P.S. 43 ANNEX - QUEENS, 12 MARVIN STREET, New York, 11691

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q907	Mechanical	2024-04-09 7:18 AM	2024-04-24 4:45 PM

Asset Data

Question	Answer
Are there fuel tanks?	No
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	None
Are there any spaces with Missing or Defective CO Detectors?	Yes
Location(s)	Water Main Room
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Packaged / Rooftop Unit (1 of 5)
	Years: 2022
	Systems: Exhaust Fans (3 of 6)
	Years: 2020
	Systems: MDF Room - Dedicated A/C Equipment:(DX Split System)
	Years: 2018

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Does not Exist
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Inspected
Instance	Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating Refrigerant Type	Gas R-410A
Instance Manufacturer	Trane
Equipment	3
Capacity/Size Quantity	4
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2022
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Roof

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q907

Question	Response
AIR CONDITIONING	
Packaged / Rooftop Unit	
Instance Condition	4 - Between Fair and Poor
Instance Quantity	4
Instance Quantity Uom	EACH
Source of Heating	Gas
Refrigerant Type	R-22
Instance Manufacturer	York
Equipment	1, 2, 4, 5
Capacity/Size Quantity	10
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2004
Source of Installation	Documented
Deficiency	UP TO 20 TONS: DEFECTIVE COIL - CONDENSER
Deficiency Location/Instance	Roof/defective condenser fins
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Does not Exist
Return Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Inspected
Dumbwaiter	Does not Exist
Elevator	Inspected
Are all the existing elevators operable?	Yes
Condition	3 - Fair
Deficiency	No deficiencies recorded
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Does not Exist
Non-auditorium Handicap Lift - Stair	Does not Exist
Ash Hoist	Does not Exist
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	Water Main Room - Domestic

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q907

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Water Main Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Water Main Room - Sprinkler
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Water Main Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Instance Manufacturer	Bradford White
Equipment	N/A
Capacity/Size Quantity	40
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	50
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2012
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q907

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	
Sewage/Waste/Vent Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Does not Exist
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Corridor adjacent to Room 102
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Does not Exist
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not Exist
Gas Meter Room Vent	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q907

Question	Response
GAS SERVICE	Inspected
Gas Meter Room Vent	Does not Exist
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Does not Exist
HEATING	Does not Exist
HEATING PLANT	Does not Exist
Enclosed IDF Room	Inspected
Instance on Room 200	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 200	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room 200
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
KITCHEN	Does not Exist
MDF Room	Inspected
Instance on Room 100	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 100	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sprinkler Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not Exist
Water Gong	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q907

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Water Gong	
Deficiency	No deficiencies recorded
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	No
Are there chain operated dampers?	No
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE DUCTWORK
Deficiency Location/Instance	Roof/RTU-3
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist