

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R051

Asset: I.S. 51 - STATEN ISLAND, 20 HOUSTON STREET, STATEN ISLAND, NY, 10302

Inspection Id	Inspection Type	Time In	Last Edited
4777	ELECTRICAL	2024-04-16 11:37AM	2024-06-14 10:13AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: LAN Years: 2024 Systems: Security Lighting Years: 2022, 2007 Systems: Auditorium (LED Lighting, Local Sound System, Theater Lighting System, Projection System) Years: 2022 Systems: IPDVS/CCTV System Years: 2020 Systems: Fused Disconnect Switch Type Panel Board Years: 2018, 2009 Systems: Gymnasium (LED Lighting), Partial Emergency Lighting (Battery Pack) Years: 2018 Systems: Public Address System, Local Sound System, Fire Alarm System, Gymnasium (Scoreboard) Years: 2014 Systems: Partial Molded Case Circuit Breaker Panel Board Years: 2013, 2009, 2002 Systems: Intercom System (Elevator) Years: 2013 Systems: Exit Lights (Battery Pack) Years: 2012 Systems: Interior Fluorescent Lighting, Retrofitted Recessed Fluorescent Lighting (Main Entrance Lobby) Years: 2010 Systems: Emergency Light/Exit Light Panel Years: 2002 Systems: Intrusion Alarm System Years: 2001
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image	
No		No condition recorded						

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance on 1st Floor	Inspected
House Lighting	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R051

Question	Response
AUDITORIUM	
House Lighting	
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Installation Year	2022
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
CAFETERIA	
Instance on Basement	Inspected
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R051

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Lighting Fixture - LED	
Instance on Basement	Does not exist
Local Sound System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Installation Year	2014
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on Basement	Does not exist
Theater Lighting System	
Instance on Basement	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
COMPUTER LAB	Inspected
Instance on Room B2	Inspected
Power Panel?	Yes
Lighting	
Instance on Room B2	Inspected
Lighting Fixture - Fluorescent	
Instance on Room B2	Inspected
Pendant Mounted	
Instance on Room B2	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R051

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room B2	Does not exist
Recessed Mounted	
Instance on Room B2	Does not exist
Lighting Fixture - HID	
Instance on Room B2	Does not exist
Lighting Fixture - Incandescent	
Instance on Room B2	Does not exist
Lighting Fixture - LED	
Instance on Room B2	Does not exist
Raceway With Receptacles	
Instance on Room B2	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2014
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not exist
Scoreboard	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 1st Floor	Does not exist
KITCHEN	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R051

Question	Response
KITCHEN	
Instance on Basement	Inspected
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Lighting Fixture - LED	
Instance on Basement	Does not exist
LIBRARY	Inspected
Instance on Room 212	Inspected
Lighting	
Instance on Room 212	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 212	Inspected
Pendant Mounted	
Instance on Room 212	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 212	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 212	Does not exist
Lighting Fixture - HID	
Instance on Room 212	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 212	Does not exist
Lighting Fixture - LED	
Instance on Room 212	Does not exist
Raceway With Receptacles	
Instance on Room 212	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Room 212	Does not exist
LOCKER ROOM	Does not exist
MULTIPURPOSE ROOM	Does not exist
SCIENCE DEMO ROOM	Inspected
Instance on Rooms: 109, 113	Inspected
Power Panel?	No

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R051

Question	Response
SCIENCE DEMO ROOM	
Alternative Use	Yes
Instance on Rooms: 115, 209, 213, 219	Inspected
Power Panel?	No
Alternative Use	Yes
Lighting	
Instance on Rooms: 109, 113	Inspected
Instance on Rooms: 115, 209, 213, 219	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms: 109, 113	Inspected
Instance on Rooms: 115, 209, 213, 219	Inspected
Pendant Mounted	
Instance on Rooms: 109, 113	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms: 115, 209, 213, 219	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Rooms: 109, 113	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms: 115, 209, 213, 219	Does not exist
Recessed Mounted	
Instance on Rooms: 109, 113	Does not exist
Instance on Rooms: 115, 209, 213, 219	Does not exist
Lighting Fixture - HID	
Instance on Rooms: 109, 113	Does not exist
Instance on Rooms: 115, 209, 213, 219	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms: 109, 113	Does not exist
Instance on Rooms: 115, 209, 213, 219	Does not exist
Lighting Fixture - LED	
Instance on Rooms: 109, 113	Does not exist
Instance on Rooms: 115, 209, 213, 219	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Rooms: 109, 113	Does not exist
Instance on Rooms: 115, 209, 213, 219	Does not exist
Emergency Shut-Off Power	
Instance on Rooms: 109, 113	Does not exist
Instance on Rooms: 115, 209, 213, 219	Does not exist
Power Supply	
Instance on Rooms: 109, 113	Does not exist
Instance on Rooms: 115, 209, 213, 219	Does not exist
Projection System	
Instance on Rooms: 109, 113	Does not exist
Instance on Rooms: 115, 209, 213, 219	Does not exist
SCIENCE LAB	
Instance on Rooms: 205, 215	Inspected
Power Panel?	No
Alternative Use	Yes
Instance on Rooms: 105, 203	Inspected
Power Panel?	No

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R051

Question	Response
SCIENCE LAB	
Alternative Use	Yes
Lighting	
Instance on Rooms: 205, 215	Inspected
Instance on Rooms: 105, 203	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms: 205, 215	Inspected
Instance on Rooms: 105, 203	Inspected
Pendant Mounted	
Instance on Rooms: 205, 215	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms: 105, 203	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Rooms: 205, 215	Does not exist
Instance on Rooms: 105, 203	Does not exist
Recessed Mounted	
Instance on Rooms: 205, 215	Does not exist
Instance on Rooms: 105, 203	Does not exist
Lighting Fixture - HID	
Instance on Rooms: 205, 215	Does not exist
Instance on Rooms: 105, 203	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms: 205, 215	Does not exist
Instance on Rooms: 105, 203	Does not exist
Lighting Fixture - LED	
Instance on Rooms: 205, 215	Does not exist
Instance on Rooms: 105, 203	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Rooms: 205, 215	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms: 105, 203	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Rooms: 205, 215	Does not exist
Instance on Rooms: 105, 203	Does not exist
Power Supply	
Instance on Rooms: 205, 215	Does not exist
Instance on Rooms: 105, 203	Does not exist
Projection System	
Instance on Rooms: 205, 215	Does not exist
Instance on Rooms: 105, 203	Does not exist
SCIENCE PREP ROOM	
Instance on Rooms: 111, 211	Inspected
Power Panel?	No
Alternative Use	Yes
Lighting	
Instance on Rooms: 111, 211	Inspected
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R051

Question	Response
SCIENCE PREP ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Instance on Rooms: 111, 211	Inspected
Pendant Mounted	
Instance on Rooms: 111, 211	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Rooms: 111, 211	Does not exist
Recessed Mounted	
Instance on Rooms: 111, 211	Does not exist
Lighting Fixture - HID	
Instance on Rooms: 111, 211	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms: 111, 211	Does not exist
Lighting Fixture - LED	
Instance on Rooms: 111, 211	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Rooms: 111, 211	Does not exist
Emergency Shut-Off Power	
Instance on Rooms: 111, 211	Does not exist
Power Supply	
Instance on Rooms: 111, 211	Does not exist
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R051

Question	Response
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	LESS THAN 20% SPARE CIRCUIT BREAKERS
Deficiency Location/Instance	Electrical Room B33
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Gymnasium and Cafeteria
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 4
Violations	35672595H
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Corridor 1st and 2nd Floor
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 4
Violations	35672595H
Non Battery Pack	Does not exist
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
Bell/Horn	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R051

Question	Response
FIRE ALARM SYSTEM	
Area Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Heat Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Does not exist
Fused Cutout Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Main Panel	Inspected
Bell At Panel	Does not exist
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST3X
EquipmentId	Fire Alarm Control Panel
Installation Year	2014
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
Sub-Panel	Does not exist
Remote Annunciator	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	Does not exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	
Elevator	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R051

Question	Response
INTERCOM SYSTEM	
Elevator	
Deficiency	No deficiencies recorded
Holding Area	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	
	Does not exist
MOTOR CONTROLLER	
	Inspected
MOTOR CONTROL CENTER	
	Does not exist
MOTOR STARTER/CONTACTOR	
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Variable Frequency Drive	
	Does not exist
PANEL BOARD	
	Inspected
Fused Disconnect Switch Type	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	
	Does not exist
Fused Toggle Switch Type	
Condition	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B33
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Molded Case Circuit Breaker Type	
Condition	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	23
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	
	Inspected
Instance	Main Office - Room 131
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane 250
Installation Year	2014
Source of Installation Year	Documented
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R051

Question	Response
PUBLIC ADDRESS SYSTEM	
Deficiency Quantity	39
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SECURITY	
	Inspected
IPDVS/CCTV System	
	Inspected
Condition	1- Good
Installation Year	2020
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Intrusion Alarm System	
	Inspected
Central Control Panel	
	Inspected
Instance	Custodian's Office - Room 133
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 50P
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting - Security	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Location/Instance	Building Perimeter
Deficiency Quantity	19
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 3
Violations	No violations recorded
SERVICE SWITCH	
	Inspected
Instance	Electrical Room B33
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Pringle
EquipmentId	Sect A
Capacity/Size Quantity	800
Capacity/Size UOM	Amps
Source of Capacity/Size	Fuse Size

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R051

Question	Response
SERVICE SWITCH	
Installation Year	1960
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B33
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B33
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Pringle
EquipmentId	Sect B
Capacity/Size Quantity	800
Capacity/Size UOM	Amps
Source of Capacity/Size	Fuse Size
Installation Year	1960
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B33
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWITCHBOARD	Inspected
Number of Spares	1
Fused Disconnect Switch Type	Does not exist
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Instance	Electrical Room B33
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	Sect A
Capacity/Size Quantity	800
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1960
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B33
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B33

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R051

Question	Response
SWITCHBOARD	
Molded Case Circuit Breaker Type	
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	Sect B
Capacity/Size Quantity	800
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1960
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B33
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not exist