

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R061

Asset: I.S. 61 - STATEN ISLAND, 445 CASTLETON AVENUE, STATEN ISLAND, NY, 10301

Inspection Id	Inspection Type	Time In	Last Edited
4270	ELECTRICAL	2024-03-26 07:21AM	2024-05-22 02:17PM


Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Most Motor Starters, IPDVS/CCTV System Years: 2023 Systems: Surface LED Lighting (Room 314) Years: 2022 Systems: Most Exit Lights (Battery Pack), Retrofitted Surface LED Lighting (Corridors), LAN, Telephone System Years: 2021 Systems: Intrusion Alarm System (Panic Switch) Years: 2019 Systems: Partial Molded Case Circuit Breaker Panel Board Years: 2018, 2010, 2001, 1995 Systems: Auditorium (Projection System) Years: 2016 Systems: Public Address System, Local Sound System, Fire Alarm System, Gymnasium (Scoreboard, LED Lighting) Years: 2015 Systems: Auditorium (Theater Lighting System), Students Cafeteria (Fluorescent Lighting) Years: 2010 Systems: Intrusion Alarm System Years: 2005 Systems: Interior Fluorescent Lighting, Staff Cafeteria Lighting, Emergency Light/Exit Light Panel, Auditorium (Incandescent Lighting) Years: 2000
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	Yes

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	Yes
Are dedicated intercoms available in all of these spaces for use during a fire?	Yes
Are all dedicated intercoms operational?	Yes

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
Yes	Water Penetration in Electrical Room	Water penetrates through foundation wall	Electrical Equipment	Electrical Room	Gus Martinez	Fireman	

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance on 2nd Floor	Inspected
House Lighting	

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R061

Question	Response
AUDITORIUM	
House Lighting	
Instance on 2nd Floor	Inspected
Does a Chandelier Exist?	Yes
Lighting Fixture - Fluorescent	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 2nd Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Does not exist
Surface Mounted	
Instance on 2nd Floor	Does not exist
Recessed Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - LED	
Instance on 2nd Floor	Does not exist
Local Sound System	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Installation Year	2015
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Is the projector on a cart or installed on the ceiling?	Cart
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 2nd Floor	Inspected
Dimming System	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R061

Question	Response
CAFETERIA	
Instance on 1st Floor - Staff	Inspected
Instance on 1st Floor - Students	Inspected
Lighting	
Instance on 1st Floor - Staff	Inspected
Instance on 1st Floor - Students	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor - Staff	Inspected
Instance on 1st Floor - Students	Inspected
Pendant Mounted	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
Surface Mounted	
Instance on 1st Floor - Staff	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Students	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor - Staff	Inspected
Instance on 1st Floor - Students	Does not exist
Pendant Mounted	
Instance on 1st Floor - Staff	Does not exist
Surface Mounted	
Instance on 1st Floor - Staff	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor - Staff	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
Local Sound System	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Inspected
Instance Condition	2- Between Good and Fair
Installation Year	2015
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
Theater Lighting System	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R061

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
COMPUTER LAB	Does not exist
GYMNASIUM	Inspected
Instance on Cellar	Inspected
Lighting	
Instance on Cellar	Inspected
Lighting Fixture - Fluorescent	
Instance on Cellar	Does not exist
Lighting Fixture - HID	
Instance on Cellar	Does not exist
Lighting Fixture - Incandescent	
Instance on Cellar	Does not exist
Lighting Fixture - LED	
Instance on Cellar	Inspected
Pendant Mounted	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Cellar	Does not exist
Recessed Mounted	
Instance on Cellar	Does not exist
Local Sound System	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Installation Year	2015
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on Cellar	Does not exist
Scoreboard	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R061

Question	Response
GYMNASIUM	
Theater Lighting System	
Instance on Cellar	Does not exist
KITCHEN	
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist
LIBRARY	
Instance on Cellar	Inspected
Lighting	
Instance on Cellar	Inspected
Lighting Fixture - Fluorescent	
Instance on Cellar	Inspected
Pendant Mounted	
Instance on Cellar	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Cellar	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Cellar	Does not exist
Lighting Fixture - HID	
Instance on Cellar	Does not exist
Lighting Fixture - Incandescent	
Instance on Cellar	Does not exist
Lighting Fixture - LED	
Instance on Cellar	Does not exist
Raceway With Receptacles	
Instance on Cellar	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Cellar	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R061

Question	Response
LOCKER ROOM	Inspected
Instance on Cellar - Boys	Inspected
Alternative Use	Yes
Instance on Cellar - Girls	Inspected
Alternative Use	No
Lighting	
Instance on Cellar - Boys	Inspected
Instance on Cellar - Girls	Inspected
Lighting Fixture - Fluorescent	
Instance on Cellar - Boys	Inspected
Instance on Cellar - Girls	Inspected
Pendant Mounted	
Instance on Cellar - Boys	Does not exist
Instance on Cellar - Girls	Does not exist
Surface Mounted	
Instance on Cellar - Boys	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Cellar - Girls	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Cellar - Boys	Does not exist
Instance on Cellar - Girls	Does not exist
Lighting Fixture - HID	
Instance on Cellar - Boys	Does not exist
Instance on Cellar - Girls	Does not exist
Lighting Fixture - Incandescent	
Instance on Cellar - Boys	Does not exist
Instance on Cellar - Girls	Does not exist
Lighting Fixture - LED	
Instance on Cellar - Boys	Does not exist
Instance on Cellar - Girls	Does not exist
MULTIPURPOSE ROOM	Does not exist
SCIENCE DEMO ROOM	Inspected
Instance on Room: 107, 207	Inspected
Power Panel?	Yes
Alternative Use	Yes
Instance on Room 307	Inspected
Power Panel?	Yes
Alternative Use	No
Lighting	
Instance on Room: 107, 207	Inspected
Instance on Room 307	Inspected
Lighting Fixture - Fluorescent	
Instance on Room: 107, 207	Inspected
Instance on Room 307	Inspected
Pendant Mounted	
Instance on Room: 107, 207	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 307	Does not exist
Surface Mounted	

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R061

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Room: 107, 207	Does not exist
Instance on Room 307	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room: 107, 207	Does not exist
Instance on Room 307	Does not exist
Lighting Fixture - HID	
Instance on Room: 107, 207	Does not exist
Instance on Room 307	Does not exist
Lighting Fixture - Incandescent	
Instance on Room: 107, 207	Does not exist
Instance on Room 307	Does not exist
Lighting Fixture - LED	
Instance on Room: 107, 207	Does not exist
Instance on Room 307	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Room: 107, 207	Does not exist
Instance on Room 307	Does not exist
Emergency Shut-Off Power	
Instance on Room: 107, 207	Does not exist
Instance on Room 307	Does not exist
Power Supply	
Instance on Room: 107, 207	Does not exist
Instance on Room 307	Does not exist
Projection System	
Instance on Room: 107, 207	Does not exist
Instance on Room 307	Does not exist
SCIENCE LAB	
	Inspected
Instance on Rooms: 106, 110, 206, 210	Inspected
Power Panel?	No
Alternative Use	No
Instance on Rooms: 306, 310	Inspected
Power Panel?	No
Alternative Use	No
Lighting	
Instance on Rooms: 106, 110, 206, 210	Inspected
Instance on Rooms: 306, 310	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms: 106, 110, 206, 210	Inspected
Instance on Rooms: 306, 310	Inspected
Pendant Mounted	
Instance on Rooms: 106, 110, 206, 210	Does not exist
Instance on Rooms: 306, 310	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Rooms: 106, 110, 206, 210	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R061

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Rooms: 306, 310	Does not exist
Recessed Mounted	
Instance on Rooms: 106, 110, 206, 210	Does not exist
Instance on Rooms: 306, 310	Does not exist
Lighting Fixture - HID	
Instance on Rooms: 106, 110, 206, 210	Does not exist
Instance on Rooms: 306, 310	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms: 106, 110, 206, 210	Does not exist
Instance on Rooms: 306, 310	Does not exist
Lighting Fixture - LED	
Instance on Rooms: 106, 110, 206, 210	Does not exist
Instance on Rooms: 306, 310	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Rooms: 106, 110, 206, 210	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms: 306, 310	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Rooms: 106, 110, 206, 210	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms: 306, 310	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Power Supply	
Instance on Rooms: 106, 110, 206, 210	Does not exist
Instance on Rooms: 306, 310	Does not exist
Projection System	
Instance on Rooms: 106, 110, 206, 210	Does not exist
Instance on Rooms: 306, 310	Does not exist
SCIENCE PREP ROOM	
Instance on Room SC10	Inaccessible
Instance on Rooms: 108, 208, 308	Inspected
Power Panel?	Yes
Alternative Use	No
Lighting	
Instance on Rooms: 108, 208, 308	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms: 108, 208, 308	Inspected
Pendant Mounted	
Instance on Rooms: 108, 208, 308	Does not exist
Surface Mounted	
Instance on Rooms: 108, 208, 308	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms: 108, 208, 308	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R061

Question	Response
SCIENCE PREP ROOM	
Lighting	
Lighting Fixture - HID	
Instance on Rooms: 108, 208, 308	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms: 108, 208, 308	Does not exist
Lighting Fixture - LED	
Instance on Rooms: 108, 208, 308	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Rooms: 108, 208, 308	Does not exist
Emergency Shut-Off Power	
Instance on Rooms: 108, 208, 308	Does not exist
Power Supply	
Instance on Rooms: 108, 208, 308	Does not exist
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R061

Question	Response
EXIT LIGHT	
Battery Pack	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	
Bell/Horn	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Heat Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Does not exist
Fused Cutout Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Main Panel	Inspected
Bell At Panel	Does not exist
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST
EquipmentId	Fire Alarm Control Panel
Installation Year	2015
Source of Installation Year	Documented
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R061

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Fire Alarm Control Panel (Standard)	Does not exist
Sub-Panel	Does not exist
Remote Annunciator	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	Does not exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Inspected
Elevator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Holding Area	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not exist
MOTOR CONTROLLER	Inspected
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Variable Frequency Drive	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Sub Cellar Fan Room and Fan Room above Auditorium
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R061

Question	Response
PANEL BOARD	
Fused Toggle Switch Type	
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	29
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	Room 122A
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	QSC Model ISA 500Ti
Installation Year	2015
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SECURITY	Inspected
IPDVS/CCTV System	Inspected
Condition	1- Good
Installation Year	2023
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	Custodian's Office - Room C09
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128B
Installation Year	2005
Source of Installation Year	Documented
Deficiency	PANEL NOT CONNECTED TO DOE CENTRAL STATION
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL CONNECTION
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R061

Question	Response
SECURITY	
Intrusion Alarm System	
Panic Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting - Security	Under construction
SERVICE SWITCH	Inspected
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific Electric
EquipmentId	Main Switch 1600A "LCL" Fuses
Capacity/Size Quantity	1600
Capacity/Size UOM	Amps
Source of Capacity/Size	Fuse Size
Installation Year	1971
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific Electric
EquipmentId	Main Switch 2500A "LCL" Fuses
Capacity/Size Quantity	2500
Capacity/Size UOM	Amps
Source of Capacity/Size	Fuse Size
Installation Year	1971
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWITCHBOARD	Inspected
Number of Spares	1
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R061

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific Electric
EquipmentId	N/A
Capacity/Size Quantity	1600
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	3
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1971
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific Electric
EquipmentId	N/A
Capacity/Size Quantity	2500
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	5
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1971
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TRANSFORMER	Does not exist