

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R816

Asset: P.S. 38 TRANSPORTABLE - STATEN ISLAND, 421 LINCOLN AVENUE, STATEN ISLAND, NY, 10306

Inspection Id	Inspection Type	Time In	Last Edited
4167	ELECTRICAL	2024-03-22 10:02AM	2024-04-09 09:33AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Interior Retrofitted LED Lighting, Security Lighting Years: 2022 Systems: Partial Exit / Emergency Lights Years: 2019 Systems: Intrusion Alarm System (Infrared Sensors) Years: 2018 Systems: Public Address System Years: 2016 Systems: Telephone System Years: 2015 Systems: Service Switch, Switchboard, Grounding System, LAN Years: 2013 Systems: All Other Electrical Systems and Components Years: 2004
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No		No condition recorded					

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
CAFETERIA	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
COMPUTER LAB	Does not exist
GYMNASIUM	Does not exist
KITCHEN	Does not exist
LIBRARY	Does not exist
LOCKER ROOM	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R816

Question	Response
MULTIPURPOSE ROOM	Does not exist
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Does not exist
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Does not exist
EXIT LIGHT	Does not exist
EXIT/EMERGENCY LIGHT	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected
Bell/Horn	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Does not exist
Duct Smoke Detector	Does not exist
Area Smoke Detector	Does not exist
CO Detector	Does not exist
Heat Detector	Does not exist
Elevator Recall	Does not exist
Magnetic Door Holder/Contactor	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R816

Question	Response
FIRE ALARM SYSTEM	
Fused Cutout Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Room T1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST 2
EquipmentId	Fire Alarm Control Panel
Installation Year	2004
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
Sub-Panel	Does not exist
Remote Annunciator	Does not exist
Sprinkler Flow/Air Pressure Switch	Does not exist
Tamper Flow Switch/Chain	Does not exist
GROUNDING SYSTEM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Does not exist
LIGHTNING PROTECTION	Does not exist
MOTOR CONTROLLER	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Does not exist
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	Connected to Main Asset R038
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	2016
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SECURITY	Inspected
IPDVS/CCTV System	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R816

Question	Response
SECURITY	
Intrusion Alarm System	Inspected
Central Control Panel	Does not exist
Infrared Sensor	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	Does not exist
Remote Annunciator	Does not exist
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting - Security	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SERVICE SWITCH	Inspected
Instance	Outside Electrical Enclosure
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	Main
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2013
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	Inspected
Number of Spares	2
Fused Disconnect Switch Type	Inspected
Instance	Outside Electrical Enclosure
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	N/A
Capacity/Size Quantity	400
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2013
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not exist