

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R817

Asset: P.S. 19 TRANSPORTABLE - S.I., 780 POST AVENUE, STATEN ISLAND, NY, 10310

Inspection Id	Inspection Type	Time In	Last Edited
5016	ELECTRICAL	2024-04-29 11:47AM	2024-05-28 09:23AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: LAN Years: 2022 Systems: Partial Exit / Emergency Light Years: 2018 Systems: Public Address System Years: 2015 Systems: Telephone System Years: 2012 Systems: Fire Alarm System (Main Control Panel) Years: 2009 Systems: All Other Electrical Systems and Components Years: 2005
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	No
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image	
No		No condition recorded						

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
CAFETERIA	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
COMPUTER LAB	Does not exist
GYMNASIUM	Does not exist
KITCHEN	Does not exist
LIBRARY	Does not exist
LOCKER ROOM	Does not exist
MULTIPURPOSE ROOM	Does not exist
SCIENCE DEMO ROOM	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

R817

Question	Response
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Does not exist
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Does not exist
EXIT LIGHT	Does not exist
EXIT/EMERGENCY LIGHT	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected
Bell/Horn	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Does not exist
Duct Smoke Detector	Does not exist
Area Smoke Detector	Does not exist
CO Detector	Does not exist
Heat Detector	Does not exist
Elevator Recall	Does not exist
Magnetic Door Holder/Contactor	Does not exist
Fused Cutout Panel	Does not exist
Fire Alarm Digital Communicator	Does not exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Room T-1
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Fire Control Instruments

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R817

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Fire Alarm Control Panel (Electronic)	
Model	7100 Series
EquipmentId	N/A
Installation Year	2009
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	
	Does not exist
Sub-Panel	
	Does not exist
Remote Annunciator	
	Does not exist
Sprinkler Flow/Air Pressure Switch	
	Does not exist
Tamper Flow Switch/Chain	
	Does not exist
GROUNDING SYSTEM	
	Does not exist
INTERCOM SYSTEM	
	Does not exist
LAN	
	Inspected
Local Distribution Frame (I/LDF)	
Condition	1- Good
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	
	Does not exist
LIGHTNING PROTECTION	
	Does not exist
MOTOR CONTROLLER	
	Does not exist
PANEL BOARD	
	Inspected
Fused Disconnect Switch Type	
	Does not exist
Fused Knife Switch Type	
	Does not exist
Fused Toggle Switch Type	
	Does not exist
Molded Case Circuit Breaker Type	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	
	Inspected
Instance	Connected to Main Asset R019
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	2015
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SECURITY	
	Inspected
IPDVS/CCTV System	
	Does not exist
Intrusion Alarm System	
	Inspected
Central Control Panel	
Instance	Room T-2
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	2005
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	
	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R817

Question	Response
SECURITY	
Intrusion Alarm System	
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting - Security	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	Does not exist
SWITCHBOARD	Does not exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standard	Does not exist
TRANSFORMER	Does not exist