

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

R881

Asset: PETRIDES COMPLEX - (BLDG H) - S.I., 715 OCEAN TERRACE, STATEN ISLAND, NY, 10301

Inspection Id	Inspection Type	Time In	Last Edited
4460	MECHANICAL	2024-04-03 11:27AM	2024-05-13 03:47PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Electric Domestic Water Heater Years: 2023 Systems: DX Split Systems Years: 2021 Systems: Toilet Room Fixtures; Heating Years: 2017
Are there fuel tanks?	No
Total # of water main service entries to the asset	1
MERs/Fan Rooms Locations	None
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Are there any Emergency Stop Switches with Missing Hammers?	No components

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not exist
Cooling Coil in Ductwork	Does not exist
Cooling Tower	Does not exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Dry Cooler	Does not exist
Packaged / Rooftop Unit	Does not exist
Packaged Terminal A/C	Does not exist
Refrigerant Leak Detection System	Does not exist
Refrigerant Piping	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Return Fan	Does not exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not exist
CLIMATE CONTROL SYSTEM	Does not exist
COMPACTOR	Does not exist
CONVEYING	Does not exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not exist
Pressure Booster System	Does not exist
Water Service	Inspected
Instance	Room 101

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

R881

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN:MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Room 101
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not exist
Domestic Water Heat Exchanger	Does not exist
Electric Domestic Water Heater	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Gas Fired Domestic Water Heater	Does not exist
Oil Fired Domestic Water Heater	Does not exist
Heat Pump Domestic Water Heater	Does not exist
Domestic Water Distribution Piping	Inspected
Condition	3- Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Room H101
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Does not exist
Sewage/Waste/Vent Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not exist
Sump Pump	Does not exist
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Urinal	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

R881

Question	Response
FIXTURES	
Staff And Other	
Urinal	
Condition	1- Good
Deficiency	No deficiencies recorded
Student	Does not exist
GAS FIRED FURNACE	Does not exist
GAS SERVICE	Does not exist
HEATING	Inspected
Heating Coil In Ductwork	Does not exist
Hydronic Heating	Does not exist
Radiator/Convactor/Fin Tube	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Steam Heating	Does not exist
Steam supplied by External Sources	Does not exist
Unit Heater/Cabinet Heater	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
HEATING PLANT	Does not exist
Enclosed IDF Room	Does not exist
KITCHEN	Does not exist
MDF Room	Does not exist
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Does not exist
SWIMMING POOL	Does not exist
VENTILATION	Inspected
Is the building Mechanically ventilated?	Yes
Exhaust Fan	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-25
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not exist
Metal Ductwork	Inspected
Condition	3- Fair
Are there any uninsulated ductwork by design in Mechanical rooms?	No
Are there chain operated dampers?	No
Deficiency	No deficiencies recorded
Supply Fan	Does not exist
Unit Ventilator	Does not exist