

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X044**

**Asset:** P.S. 44 - BRONX, 1825 PROSPECT AVENUE, BRONX, NY, 10457

Inspection Id	Inspection Type	Time In	Last Edited
806	ELECTRICAL	2023-11-08 08:56AM	2024-02-27 03:11PM



**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: LAN Years: 2023 Systems: Partial Molded Case Circuit Breaker Type Panel Board Years: 2021, 2020, 2019, 2018, 2012, 2007, 1999, 1989 Systems: LED Lighting (4th Floor - Classrooms, Corridors, Staircases A/B, C/D, E/F), Toilet Rooms (Staff, Student), Gymnasium Years: 2021 Systems: Exit Light - Battery Pack, Security Lighting, Computer Lab - Room 107 (Raceway With Receptacles) Years: 2019 Systems: IPDVS/CCTV System Years: 2017 Systems: Telephone System Years: 2015 Systems: Service Switch, Switchboard, Grounding System Years: 2013 Systems: Public Address System, Local Sound System, Intrusion Alarm System, Fire Alarm System Years: 2008 Systems: Fused Disconnect Switch Type Panel Board Years: 2000, 1993 Systems: Interior Fluorescent Lighting Years: 2000 Systems: Emergency Light/Exit Light Panel Years: 1992 Type of Service Below Ground Does Interactive Whiteboard (IWB) Exist? Yes Water Penetration In Electrical Room? Yes

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
Yes	Emergency Lighting - Not Operational	N/A	Emergency Lighting	Throughout the Building	Jose Torres	Fireman	No Photo Taken
Yes	Water Penetration in Electrical Room	N/A	Electrical Equipment	Electrical Switchboard Room B5 (Inside Cafeteria)	Jose Torres	Fireman	
Yes	Water Leaks onto Electrical Equipment	N/A	Lighting Fixture	Cafeteria - Exit 10 Vestibule	Jose Torres	Fireman	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X044**

No	Public Address System - Speakers Not Operational	Not Operational	Public Address System	Multipurpose Room in Basement	Jose Torres	Fireman	No Photo Taken
----	--	-----------------	--------------------------	-------------------------------------	-------------	---------	----------------

**Inspection**

Question	Response
<b>Electrical</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Does not exist
<b>CAFETERIA</b>	Inspected
Instance on Basement	Inspected
<b>Lighting</b>	
Instance on Basement	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Basement	Does not exist
<b>Local Sound System</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on Basement	Does not exist
<b>Theater Lighting System</b>	
Instance on Basement	Does not exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>Lighting</b>	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Inspected
<b>Pendant Mounted</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X044**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
<b>Pendant Mounted</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>COMPUTER LAB</b>	Inspected
Instance on Room 107	Inspected
Power Panel?	No
<b>Lighting</b>	
Instance on Room 107	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 107	Inspected
<b>Pendant Mounted</b>	
Instance on Room 107	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 107	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 107	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 107	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 107	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 107	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 107	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Inspected
Instance on 4th Floor	Inspected
<b>Lighting</b>	
Instance on 4th Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 4th Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 4th Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 4th Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 4th Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 4th Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 4th Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X044**

Question	Response
<b>GYMNASIUM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
<b>Recessed Mounted</b>	
Instance on 4th Floor	Does not exist
<b>Local Sound System</b>	
Instance on 4th Floor	Inspected
Instance Condition	3- Fair
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 4th Floor	Does not exist
<b>Scoreboard</b>	
Instance on 4th Floor	Does not exist
<b>Theater Lighting System</b>	
Instance on 4th Floor	Does not exist
<b>KITCHEN</b>	
	Inspected
Instance on Basement	Inspected
<b>Lighting</b>	
Instance on Basement	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist
<b>Surface Mounted</b>	
Instance on Basement	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Basement	Does not exist
<b>LIBRARY</b>	
	Inspected
Instance on Room 205	Inspected
<b>Lighting</b>	
Instance on Room 205	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 205	Inspected
<b>Pendant Mounted</b>	
Instance on Room 205	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 205	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 205	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 205	Does not exist
<b>Lighting Fixture - Incandescent</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X044**

Question	Response
<b>LIBRARY</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 205	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 205	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 205	Does not exist
<b>Projection System</b>	
Instance on Room 205	Does not exist
<b>LOCKER ROOM</b>	Does not exist
<b>MULTIPURPOSE ROOM</b>	Inspected
Instance on 1st Floor	Inspected
Instance on Basement	Inspected
<b>Lighting</b>	
Instance on 1st Floor	Inspected
Instance on Basement	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
Instance on Basement	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
Instance on Basement	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
Instance on Basement	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not exist
Instance on Basement	Does not exist
<b>Local Sound System</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance on Basement	Inspected
Instance Condition	3- Fair
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X044**

Question	Response
<b>MULTIPURPOSE ROOM</b>	
<b>Projection System</b>	
Instance on 1st Floor	Does not exist
Instance on Basement	Does not exist
<b>Theater Lighting System</b>	
Instance on 1st Floor	Inspected
Instance on Basement	Does not exist
<b>Dimming System</b>	
Instance on 1st Floor	Does not exist
<b>Theater Lighting</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCIENCE DEMO ROOM</b>	Inspected
Instance on Room 313	Inspected
Power Panel?	No
Alternative Use	No
<b>Lighting</b>	
Instance on Room 313	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 313	Inspected
<b>Pendant Mounted</b>	
Instance on Room 313	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 313	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 313	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 313	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 313	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 313	Does not exist
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 313	Does not exist
<b>Emergency Shut-Off Power</b>	
Instance on Room 313	Does not exist
<b>Power Supply</b>	
Instance on Room 313	Does not exist
<b>Projection System</b>	
Instance on Room 313	Does not exist
<b>SCIENCE LAB</b>	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X044**

Question	Response
<b>TOILET ROOM - STAFF</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	4- Between Fair and Poor
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	19
Quantity Uom	EACH

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X044**

<b>Question</b>	<b>Response</b>
<b>EMERGENCY LIGHTING</b>	
<b>Battery Pack</b>	
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
<b>Non Battery Pack</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	
<b>Battery Pack</b>	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	
Condition	Inspected
Deficiency	5- Poor
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Gymnasium
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EXIT/EMERGENCY LIGHT</b>	
Does not exist	
<b>FIRE ALARM SYSTEM</b>	
Inspected	
<b>Bell/Horn</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Manual Pull Station</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	
Does not exist	
<b>Duct Smoke Detector</b>	
Does not exist	
<b>Area Smoke Detector</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>CO Detector</b>	
Does not exist	
<b>Heat Detector</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Elevator Recall</b>	
Does not exist	
<b>Magnetic Door Holder/Contactor</b>	
Does not exist	
<b>Fused Cutout Panel</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Digital Communicator</b>	
Does not exist	
<b>Main Panel</b>	
Inspected	
<b>Bell At Panel</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	
Condition	Inspected
Instance	Main Entrance Lobby



**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X044**

Question	Response
<b>FIRE ALARM SYSTEM</b>	
<b>Main Panel</b>	
<b>Fire Alarm Control Panel (Electronic)</b>	
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Faraday
Model	MPC - 7000
EquipmentId	Fire Alarm Control Panel
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>Sub-Panel</b>	Does not exist
<b>Remote Annunciator</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Printer</b>	Inspected
Condition	5- Poor
Deficiency	PRINTER NOT OPERATIONAL
Deficiency Location/Instance	Custodian's Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Punch Register</b>	Does not exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Does not exist
<b>Tamper Flow Switch/Chain</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>INTERCOM SYSTEM</b>	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (L/LDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>MOTOR CONTROLLER</b>	Inspected
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Variable Frequency Drive</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X044**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>Fused Disconnect Switch Type</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Fused Toggle Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	NO SPARE
Deficiency Location/Instance	By Rooms 104A, 206, 411 and by Custodian's Office Room 153.
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Inspected
Instance	General Office - Room 155
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Bogen HTA250A
Installation Year	2008
Source of Installation Year	Documented
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SPEAKER NOT OPERATIONAL
Deficiency Location/Instance	Multipurpose Room in Basement
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
<b>SECURITY</b>	Inspected
<b>IPDVS/CCTV System</b>	Inspected
Condition	2- Between Good and Fair
Installation Year	2017
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Intrusion Alarm System</b>	Inspected
<b>Central Control Panel</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X044**

Question	Response
<b>SECURITY</b>	
<b>Intrusion Alarm System</b>	
<b>Central Control Panel</b>	
Instance	Custodian's Office - Room 153
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128B
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting - Security</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	Inspected
Instance	Electrical Switchboard Room B5 (Inside Cafeteria)
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	East Coast
EquipmentId	Main Service Switch
Capacity/Size Quantity	2000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2013
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>SWITCHBOARD</b>	Inspected
Number of Spares	13
<b>Fused Disconnect Switch Type</b>	Inspected
Instance	Electrical Switchboard Room (Inside Boiler Room)
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	East Coast
EquipmentId	MDB
Capacity/Size Quantity	1600
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	3
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2013
Source of Installation Year	Documented

NYC Department of Education  
Building Condition Assessment Survey 2023-2024

*Electrical Inspection*

X044

Question	Response
<b>SWITCHBOARD</b>	
<b>Fused Disconnect Switch Type</b>	
Deficiency	No deficiencies recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Does not exist
<b>TELEPHONE SYSTEM</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>TRANSFORMER</b>	Does not exist