

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X059

Asset: P.S. 59 - BRONX, 2185 BATHGATE AVENUE, BRONX, NY, 10457

Inspection Id	Inspection Type	Time In	Last Edited
2699	MECHANICAL	2024-01-25 07:55AM	2024-04-02 06:37PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Steam Condensate Return Pumping System Years: 2023 Systems: F&T/Steam Drip Trap; Terminal Unit Thermostatic Trap Years: 2022 Systems: Boiler #2 - re-tubed Years: 2021 Systems: Kitchen - Gas System: Shut-Off Switch Years: 2020 Systems: MDF Room - Dedicated A/C Equipment (DX Split System) Years: 2013
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	8,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	1
MERs/Fan Rooms Locations	Basement - Steam Condensate Return Pump Room; MERs 108, 154, PH Fan Room
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Are there any Emergency Stop Switches with Missing Hammers?	No components

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Does not exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Rooms 240B, 302A, 504, 506B
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE TEMPERATURE CONTROL ZONE VALVE
Deficiency Location/Instance	MER 154@House Blower

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X059

Question	Response
CLIMATE CONTROL SYSTEM	
Pneumatic System	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE TERMINAL UNIT CONTROLLER
Deficiency Location/Instance	MER 154@House Blower
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Hybrid System	Does not exist
Electric System	Does not exist
COMPACTOR	Does not exist
CONVEYING	Inspected
Dumbwaiter	Does not exist
Elevator	Does not exist
Escalator	Does not exist
Non-auditorium Handicap Lift - Vertical	Does not exist
Non-auditorium Handicap Lift - Stair	Does not exist
Ash Hoist	Inspected
Condition	4- Between Fair and Poor
Are all the existing ash hoists operable?	No
Deficiency	No deficiencies recorded
Sidewalk Elevator	Does not exist
DOMESTIC WATER SYSTEM	
	Inspected
Domestic Cold Water System	
	Inspected
Gravity System	
	Does not exist
Pressure Booster System	
	Inspected
Electric Pressure Booster System	
Instance	MER 108
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Systecon
EquipmentId	N/A
Capacity/Size Quantity	2
Capacity/Size UOM	Total # Pumps
Capacity/Size 2 Quantity	10
Capacity/Size 2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	2008
Source of Installation Year	Inspector Estimate
Deficiency	No deficiencies recorded
Hydraulic/Pneumatic Booster System	
	Does not exist
Water Service	
	Inaccessible
Domestic Hot Water System	
	Inspected
Domestic Hot Water Remote Storage Tank	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Domestic Water Heat Exchanger	
	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

X059

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Electric Domestic Water Heater	Does not exist
Gas Fired Domestic Water Heater	Inspected
Instance	Basement - Steam Condensate Return Pump Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Rheem / Ruud
EquipmentId	N/A
Capacity/Size Quantity	264
Capacity/Size UOM	MBH Input
Capacity/Size 2 Quantity	0
Capacity/Size 2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2009
Source of Installation Year	Inspector Estimate
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not exist
Heat Pump Domestic Water Heater	Does not exist
Domestic Water Distribution Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not exist
Sump Pump	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Room 302A
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Toilet	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Urinal	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X059

Question	Response
FIXTURES	
Student	Inspected
Drinking Fountain	Inspected
Condition	3- Fair
Deficiency	CLOGGED/LEAKING
Deficiency Location/Instance	Corridor near Room 508, 303,
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lavatory/Sink	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Toilet Room 111, 452,
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Locker Room Shower	Does not exist
Sink And Fountain Combo Unit	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3- Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Toilet Room 111, 356,
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
GAS FIRED FURNACE	Does not exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Inspected
Instance	Basement - Gas Meter Room
Instance Condition	3- Fair
Instance Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

X059

Question	Response
GAS SERVICE	
Gas Pressure Booster	
Instance Quantity Uom	EACH
Manufacturer	Eclipse
EquipmentId	N/A
Capacity/Size Quantity	15000
Capacity/Size UOM	SCFH
Source of Capacity/Size	Documented
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
CO/Gas Leak Detection	Inspected
Instance	Basement - Boiler Room, Steam Condensate Return Pump Room, Gas Meter Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	1999
Source of Installation Year	Inspector Estimate
Deficiency	No deficiencies recorded
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	MER 108@Blower #3
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Hydronic Heating	Does not exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3- Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	MER 108
Deficiency Quantity	50
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Condensate Return Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X059

Question	Response
HEATING	
Steam Heating	
Steam Piping	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE VALVE
Deficiency Location/Instance	Boiler Room MER 108
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Basement outside Gas Meter Room
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Terminal Unit Thermostatic Trap	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not exist
Unit Heater/Cabinet Heater	Inspected
Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
HEATING PLANT	Inspected
Instance on Basement	Inspected
Is there a water meter on the boiler make-up water piping?	Yes
Observed Operational?	Yes
Burner Manufacturer	Gordon - Piatt Energy Group
Burner Model	FL12.1-GO-50
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2
Boiler Auxiliaries	
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X059

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Feedwater System	
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	DEFECTIVE HEADER VALVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not exist
Hot Water Boiler	
Instance on Basement	Does not exist
Modular Boiler	
Instance on Basement	Does not exist
Steam Boiler	
Instance on Basement	Inspected
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	4,299
Instance Quantity Uom	MBH NET

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X059

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Cast Iron Boiler?	No
Manufacturer	A. L. Eastmond & Sons Inc.
EquipmentId	6436-01
Capacity/Size Quantity	4299
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1998
Source of Installation Year	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	RUSTED CASING
Deficiency Quantity	20
Quantity Uom	S.F.
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	4,299
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	A. L. Eastmond & Sons Inc.
EquipmentId	6436-02
Capacity/Size Quantity	4299
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1998
Source of Installation Year	Documented
Deficiency	RUSTED CASING
Deficiency Quantity	20
Quantity Uom	S.F.
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fuel System	
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Instance on Basement	Inspected
Instance Condition	3- Fair
Type	Automatic
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X059

Question	Response
HEATING PLANT	
Fuel System	
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Enclosed IDF Room	
Instance on Room 358	Inspected
Dedicated A/C Equipment	
Instance on Room 358	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room 358
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
KITCHEN	
Instance on 1st Floor	Inspected
CO Detector	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Gas System	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Grease Trap	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Hood	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hot Water Temperature Booster	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X059

Question	Response
KITCHEN	
Hot Water Temperature Booster	
Instance on 1st Floor	Does not exist
Kitchen Sink	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room inside Room 110	Inspected
Dedicated A/C Equipment	
Instance on Room inside Room 110	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Does not exist
SWIMMING POOL	Does not exist
VENTILATION	Inspected
Is the building Mechanically ventilated?	Partial
Exhaust Fan	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-25
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not exist
Metal Ductwork	Inspected
Condition	3- Fair
Are there any uninsulated ductwork by design in Mechanical rooms?	Yes
Are there chain operated dampers?	Yes
Deficiency	DEFECTIVE REGISTER/DIFFUSER
Deficiency Location/Instance	Auditorium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Supply Fan	Inspected
Condition	4- Between Fair and Poor
Approximate Total # of Fans	1-5
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	MER 154 - House Blower (1 of 3)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Unit Ventilator	Does not exist