

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

**Asset:** I.S. 201 - BRONX, 730 BRYANT AVENUE, BRONX, NY, 10474

Inspection Id	Inspection Type	Time In	Last Edited
1077	ELECTRICAL	2023-11-17 08:35AM	2024-06-13 04:40PM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Auditorium - Theater Lighting, Dimming System Years: 2022 Systems: Partial Molded Case Circuit Breaker Panel Boards Years: 2021, 2012, 2009, 2007, 1986 Systems: Partial Motor Starters Years: 2021, 2009 Systems: Recessed LED Lighting CCA and Library Years: 2020 Systems: Security Lights, Gymnasium (LED Lighting) Years: 2019 Systems: Emergency Lighting (Battery Pack), Exit Lights (Battery Pack), Exit/Emergency Lights Years: 2018 Systems: Intercom System (Elevator) Years: 2014 Systems: Intrusion Alarm System (Central Control Panel) Years: 2012 Systems: IPDVS/CCTV System Years: 2010 Systems: Public Address System, Local Sound System Years: 2009 Systems: Interior Recessed Fluorescent Lighting, Auditorium (House Lighting), Fire Alarm System (Partial Elevator Recall System) Years: 2008 Systems: Interior Fluorescent Lighting (Except Recessed Mounted Type) Years: 2004 Systems: Fire Alarm System Years: 2001 Systems: Intrusion Alarm System, Emergency Light/Exit Light Panel Years: 1997
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	Yes
Are dedicated intercoms available in all of these spaces for use during a fire?	No
Which spaces do not have dedicated intercoms?	Rooms 243, 343, 443

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	Emergency Lighting - Not Operational	Not Operational	Emergency Lighting	Throughout the Building	Winston Anglin	Fireman	No Photo Taken
No	Fire Alarm System - Components Not Operational	Not Operational	Fire Alarm System - Elevator Recall	Elevators	Winston Anglin	Fireman	No Photo Taken

**Inspection**

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

Question	Response
<b>Electrical</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance on 2nd Floor	Inspected
<b>House Lighting</b>	
Instance on 2nd Floor	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Instance on 2nd Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 2nd Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 2nd Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 2nd Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 2nd Floor	Does not exist
<b>Local Sound System</b>	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Installation Year	2009
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
<b>Theater Lighting System</b>	
Instance on 2nd Floor	Inspected
<b>Dimming System</b>	
Instance on 2nd Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Theater Lighting</b>	
Instance on 2nd Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	Inspected
Instance on 1st Floor Small	Inspected
Instance on 1st Floor Large	Inspected
<b>Lighting</b>	
Instance on 1st Floor Small	Inspected
Instance on 1st Floor Large	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor Small	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

Question	Response
<b>CAFETERIA</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor Large	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor Small	Does not exist
Instance on 1st Floor Large	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor Small	Does not exist
Instance on 1st Floor Large	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor Small	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor Large	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor Small	Does not exist
Instance on 1st Floor Large	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor Small	Does not exist
Instance on 1st Floor Large	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor Small	Does not exist
Instance on 1st Floor Large	Does not exist
<b>Local Sound System</b>	
Instance on 1st Floor Small	Does not exist
Instance on 1st Floor Large	Inspected
Instance Condition	5- Poor
Installation Year	2009
Source of Installation Year	Documented
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE SYSTEM
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Projection System</b>	
Instance on 1st Floor Small	Does not exist
Instance on 1st Floor Large	Does not exist
<b>Theater Lighting System</b>	
Instance on 1st Floor Small	Does not exist
Instance on 1st Floor Large	Does not exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Condition	3- Fair

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Condition	Inspected
Deficiency	3- Fair
<b>Lighting Fixture - HID</b>	
Does not exist	
<b>Lighting Fixture - Incandescent</b>	
Does not exist	
<b>Lighting Fixture - LED</b>	
<b>Pendant Mounted</b>	
Does not exist	
<b>Surface Mounted</b>	
Does not exist	
<b>Recessed Mounted</b>	
Condition	Inspected
Deficiency	1- Good
<b>COMPUTER LAB</b>	
Inspected	
Instance on Room 241	Inspected
Power Panel?	Yes
<b>Lighting</b>	
Instance on Room 241	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 241	Inspected
<b>Pendant Mounted</b>	
Instance on Room 241	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 241	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 241	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 241	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 241	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 241	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 241	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	
Inspected	
Instance on 1st Floor	Inaccessible
<b>KITCHEN</b>	
Inspected	
Instance on 1st Floor	Inspected
<b>Lighting</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

Question	Response
<b>KITCHEN</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not exist
<b>LIBRARY</b>	
Instance on Room 392	Inspected
<b>Lighting</b>	
Instance on Room 392	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 392	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 392	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 392	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 392	Inspected
<b>Pendant Mounted</b>	
Instance on Room 392	Does not exist
<b>Surface Mounted</b>	
Instance on Room 392	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 392	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Raceway With Receptacles</b>	
Instance on Room 392	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on Room 392	Does not exist
<b>LOCKER ROOM</b>	
Instance on 1st Floor Boys	Inaccessible
Instance on 2nd Floor Girls	Inaccessible
<b>MULTIPURPOSE ROOM</b>	
	Does not exist
<b>SCIENCE DEMO ROOM</b>	
	Does not exist
<b>SCIENCE LAB</b>	
Instance on Rooms 337, 339	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Rooms 437, 439	Inspected
Power Panel?	Yes
Alternative Use	No
<b>Lighting</b>	
Instance on Rooms 337, 339	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

Question	Response
<b>SCIENCE LAB</b>	
<b>Lighting</b>	
Instance on Rooms 437, 439	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Rooms 337, 339	Inspected
Instance on Rooms 437, 439	Inspected
<b>Pendant Mounted</b>	
Instance on Rooms 337, 339	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 437, 439	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Rooms 337, 339	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 437, 439	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Rooms 337, 339	Does not exist
Instance on Rooms 437, 439	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Rooms 337, 339	Does not exist
Instance on Rooms 437, 439	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Rooms 337, 339	Does not exist
Instance on Rooms 437, 439	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Rooms 337, 339	Does not exist
Instance on Rooms 437, 439	Does not exist
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Rooms 337, 339	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 437, 439	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Emergency Shut-Off Power</b>	
Instance on Rooms 337, 339	Does not exist
Instance on Rooms 437, 439	Does not exist
<b>Power Supply</b>	
Instance on Rooms 337, 339	Does not exist
Instance on Rooms 437, 439	Does not exist
<b>Projection System</b>	
Instance on Rooms 337, 339	Does not exist
Instance on Rooms 437, 439	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>SCIENCE PREP ROOM</b>	
Instance on Room 237	Inspected
Power Panel?	Yes

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

Question	Response
<b>SCIENCE PREP ROOM</b>	
Alternative Use	Yes
<b>Lighting</b>	
Instance on Room 237	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 237	Inspected
<b>Pendant Mounted</b>	
Instance on Room 237	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 237	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 237	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 237	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 237	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 237	Does not exist
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 237	Does not exist
<b>Emergency Shut-Off Power</b>	
Instance on Room 237	Does not exist
<b>Power Supply</b>	
Instance on Room 237	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Does not exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

<b>Question</b>	<b>Response</b>
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	4- Between Fair and Poor
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	1- Good
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Non Battery Pack</b>	Does not exist
<b>EXIT/EMERGENCY LIGHT</b>	Inspected
Condition	3- Fair
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Corridor near Room 335
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>Bell/Horn</b>	Inspected
Condition	3- Fair



**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

Question	Response
<b>FIRE ALARM SYSTEM</b>	
<b>Bell/Horn</b>	
Deficiency	No deficiencies recorded
<b>Strobe</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Manual Pull Station</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Area Smoke Detector</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CO Detector</b>	Does not exist
<b>Heat Detector</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Elevator Recall</b>	Inspected
Condition	5- Poor
Deficiency	SYSTEM NOT OPERATIONAL
Deficiency Location/Instance	Elevators
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
<b>Magnetic Door Holder/Contactor</b>	Does not exist
<b>Fused Cutout Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Digital Communicator</b>	Does not exist
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Main Entrance Lobby
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Simplex
Model	4020
EquipmentId	Fire Alarm Control Panel
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>Sub-Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

Question	Response
<b>FIRE ALARM SYSTEM</b>	
<b>Sub-Panel</b>	
<b>Bell At Panel</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Room B1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Simplex
Model	4020
EquipmentId	Fire Alarm Control Panel
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>Remote Annunciator</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Printer</b>	Does not exist
<b>Punch Register</b>	Does not exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Tamper Flow Switch/Chain</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>INTERCOM SYSTEM</b>	Inspected
<b>Elevator</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Holding Area</b>	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>MOTOR CONTROLLER</b>	Inspected
<b>MOTOR CONTROL CENTER</b>	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	Roof Fan Control Center #1

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

Question	Response
<b>MOTOR CONTROLLER</b>	
<b>MOTOR CONTROL CENTER</b>	
Capacity/Size Quantity	200
Capacity/Size UOM	Amps
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Inspector Estimate
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	Roof Fan Control Center #2
Capacity/Size Quantity	200
Capacity/Size UOM	Amps
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Inspector Estimate
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Mechanical Equipment Room 240
Instance Condition	3- Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Manufacturer	I.T.E. Imperial Corp
EquipmentId	N/A
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Mechanical Equipment Room 240
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

Question	Response
<b>MOTOR CONTROLLER</b>	
<b>MOTOR CONTROL CENTER</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Mechanical Equipment Room 472
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	I.T.E. Imperial Corp
EquipmentId	SP4P
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Mechanical Equipment Room 472
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Variable Frequency Drive</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room, Mechanical Rooms
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Fused Toggle Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	20

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>Molded Case Circuit Breaker Type</b>	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
	Inspected
Instance	Room 325A
Instance Condition	4- Between Fair and Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland TC2105
Installation Year	2009
Source of Installation Year	Documented
Deficiency	SYSTEM DEFECTIVE
Deficiency Location/Instance	Room 325A
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR SYSTEM
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SECURITY</b>	
	Inspected
<b>IPDVS/CCTV System</b>	
	Inspected
Condition	3- Fair
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Intrusion Alarm System</b>	
	Inspected
<b>Central Control Panel</b>	
	Inspected
Instance	Electrical Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128BP
Installation Year	2012
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
	Inspected
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

Question	Response
<b>SECURITY</b>	
<b>Intrusion Alarm System</b>	
<b>Remote Annunciator</b>	
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting - Security</b>	
Deficiency	Inaccessible
<b>SERVICE SWITCH</b>	
Instance	Electrical Room B9
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	N/A
Capacity/Size Quantity	1000
Capacity/Size UOM	Amps
Source of Capacity/Size	Inspector Estimate
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B9
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B9
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	N/A
Capacity/Size Quantity	1000
Capacity/Size UOM	Amps
Source of Capacity/Size	Inspector Estimate
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B9
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SWITCHBOARD</b>	
Number of Spares	0
<b>Fused Disconnect Switch Type</b>	
Instance	Electrical Room B9
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X074**

Question	Response
<b>SWITCHBOARD</b>	
<b>Fused Disconnect Switch Type</b>	
EquipmentId	N/A
Capacity/Size Quantity	1000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	4
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Inspector Estimate
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B9
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B9
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	N/A
Capacity/Size Quantity	1000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	4
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Inspector Estimate
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B9
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Does not exist
<b>TELEPHONE SYSTEM</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>TRANSFORMER</b>	Does not exist