

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X076

Asset: P.S. 76 - BRONX, 900 ADEE AVENUE, BRONX, NY, 10469

Inspection Id	Inspection Type	Time In	Last Edited
1060	MECHANICAL	2023-11-16 07:58AM	2023-12-21 09:10AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Student Fixtures - Toilets; Gas Trains And Vent At The Boiler; Gas Trains Years: 2023 Systems: Steam Condensate Return Pumping System; Terminal Unit Thermostatic Traps; F&T/Steam Drip Traps (~95%) Years: 2022 Systems: Climate Control System - Electric System (Heat Timer System) Years: 2020 Systems: MDF Room - Dedicated A/C Equipment (1 of 2, DX Split System) Years: 2014
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	10,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	Basement Mechanical Area
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Room 152 (painted, 2)
Are there any Emergency Stop Switches with Missing Hammers?	No components

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
		No condition recorded					

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Does not exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
Hybrid System	Does not exist
Electric System	Inspected
Instance	Throughout (Heat Timer System)
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE LOCAL CONTROL PANEL
Deficiency Location/Instance	Boiler Room (1 of 2)

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X076

Question	Response
CLIMATE CONTROL SYSTEM	
Electric System	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
COMPACTOR	Does not exist
CONVEYING	Does not exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not exist
Pressure Booster System	Does not exist
Water Service	Inspected
Instance	Boiler Room, Basement Mechanical Area
Instance Condition	3- Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	WATER MAIN:MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Boiler Room, Basement Mechanical Area
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Domestic Water Heat Exchanger	Does not exist
Electric Domestic Water Heater	Does not exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lochinvar
EquipmentId	N/A
Capacity/Size Quantity	400
Capacity/Size UOM	MBH Input
Capacity/Size 2 Quantity	0
Capacity/Size 2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2002
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not exist
Heat Pump Domestic Water Heater	Does not exist
Domestic Water Distribution Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X076

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	
Interior Storm Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not exist
Sump Pump	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not exist
FIXTURES	
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Urinal	Does not exist
Student	Inspected
Drinking Fountain	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not exist
Sink And Fountain Combo Unit	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X076

Question	Response
GAS SERVICE	
Gas Pressure Booster	
Instance	Basement - Gas Meter Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Eclipse
EquipmentId	N/A
Capacity/Size Quantity	18000
Capacity/Size UOM	SCFH
Source of Capacity/Size	Documented
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
CO/Gas Leak Detection	Inspected
Instance	Basement - Boiler Room, Gas Meter Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Does not exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3- Fair
Deficiency	RADIATOR/CONVECTOR:DAMAGED GUARD/SHIELD
Deficiency Location/Instance	Room 359
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	AUXILIARY (VALVE,VENT):DEFECTIVE
Deficiency Location/Instance	Stairs "AB/2", "AB/3"
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

X076

Question	Response
HEATING	
Steam Heating	
Steam Condensate Return Pumping System	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Steam Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not exist
Unit Heater/Cabinet Heater	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
HEATING PLANT	Inspected
Instance on Basement	Inspected
Is there a water meter on the boiler make-up water piping? Observed Operational?	Yes Yes
Burner Manufacturer	N/A
Burner Model	N/A
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2
Boiler Auxiliaries	
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	FEEDWATER TANK:DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room Mechanical Area
Deficiency Quantity	5
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X076

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Make-up Water Backflow Preventer	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not exist
Hot Water Boiler	
Instance on Basement	Does not exist
Modular Boiler	
Instance on Basement	Does not exist
Steam Boiler	
Instance on Basement	Inspected
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	5,198
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	Cleaver Brooks
EquipmentId	6908-01
Capacity/Size Quantity	8369
Capacity/Size UOM	MBH Input
Source of Capacity/Size	Documented
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	5,198
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	Cleaver Brooks
EquipmentId	6908-02
Capacity/Size Quantity	8369
Capacity/Size UOM	MBH Input
Source of Capacity/Size	Documented
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fuel System	
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Instance on Basement	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X076

Question	Response
HEATING PLANT	
Fuel System	
Boiler Fresh Air Louver/Damper	
Type	Automatic
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Enclosed IDF Room	Does not exist
KITCHEN	
Instance on 1st Floor	Inspected
CO Detector	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Gas System	
Instance on 1st Floor	Does not exist
Grease Trap	
Instance on 1st Floor	Does not exist
Hood	
Instance on 1st Floor	Does not exist
Hood Exhaust Ductwork	
Instance on 1st Floor	Does not exist
Hood Exhaust Fan	
Instance on 1st Floor	Does not exist
Hood Fire Suppression System	
Instance on 1st Floor	Does not exist
Hot Water Temperature Booster	
Instance on 1st Floor	Does not exist
Kitchen Sink	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
MDF Room	
Instance on Room B13	Inspected
Dedicated A/C Equipment	
Instance on Room B13	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	
SCIENCE LAB	
SCIENCE PREP ROOM	
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Dry Sprinkler Alarm Valve Assembly	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X076

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Wet Sprinkler Alarm Valve Assembly	Does not exist
Fire Booster Pump Assembly	Does not exist
Roof Tank	Does not exist
Siamese Connection	Does not exist
Sprinkler Head	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Room 152 (painted, 2)
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Sprinkler Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not exist
Water Gong	Does not exist
SWIMMING POOL	Does not exist
VENTILATION	Inspected
Is the building Mechanically ventilated?	Yes
Exhaust Fan	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-25
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not exist
Metal Ductwork	Inspected
Condition	3- Fair
Are there any uninsulated ductwork by design in Mechanical rooms?	Yes
Are there chain operated dampers?	No
Deficiency	No deficiencies recorded
Supply Fan	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-5
Deficiency	DEFECTIVE MOTOR
Deficiency Location/Instance	Boiler Room Mechanical Area / 4th Floor Blower (1 of 4)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Unit Ventilator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded