

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Asset: I.S. 80/P.S. 280 - BRONX, 149 EAST MOSHOLU PARKWAY NORTH, BRONX, NY, 10467

Inspection Id	Inspection Type	Time In	Last Edited
4417	ELECTRICAL	2024-04-02 09:17AM	2024-05-03 01:49PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	<p>Systems: LAN, 5th Floor LED Lighting (Corridors - Surface Retrofit, Classrooms - Pendant), 4th Floor Library (LED Lighting)</p> <p>Years: 2022</p> <p>Systems: Partial Exit Lights (Battery Pack Type), Most Emergency Lights (Battery Pack)</p> <p>Years: 2021, 2018</p> <p>Systems: Locker Rooms, Toilet Rooms (LED Pendant Lighting), Dance Studio (LED Recessed Lighting), 2nd Floor Corridors LED Surface Lighting, Exit/Emergency Lights</p> <p>Years: 2021</p> <p>Systems: Security Lights, Auditorium (Projector System), 3rd Floor Corridor Retrofit LED Surface Lighting Fixtures, Public Address System (Master Clock)</p> <p>Years: 2020</p> <p>Systems: LED Lighting (Corridors), Computer Lab, 5th Floor Gymnasium (LED Lighting, Scoreboard)</p> <p>Years: 2018</p> <p>Systems: 3rd Floor Gymnasium (Scoreboard)</p> <p>Years: 2017</p> <p>Systems: Intrusion Alarm System (Central Control Panel, Most Remote Annunciator)</p> <p>Years: 2016</p> <p>Systems: 3rd Floor Gymnasium LED Lights</p> <p>Years: 2015</p> <p>Systems: Fire Alarm System (Elevator Recall, Remote Annunciator, Fused Cutout Panel), Fused Disconnect Switch Type Panelboards</p> <p>Years: 2014, 1999</p> <p>Systems: Auditorium (Pendant Fluorescent Lighting), Fire Alarm System (Sub-Panel), Partial Intercom System (Elevator)</p> <p>Years: 2014</p> <p>Systems: Partial Molded Case Circuit Breaker Type Panelboard</p> <p>Years: 2013, 2001, 1999, 1990</p> <p>Systems: IPDVS/CCTV System, Auditorium (Partial Theater Lighting)</p> <p>Years: 2010</p> <p>Systems: Interior Fluorescent Lighting (Pendant, Surface), Science Lab Room, Science Prep Room</p> <p>Years: 2006</p> <p>Systems: Fire Alarm System, Public Address System, Local Sound Systems, Interior Fluorescent Lighting (Recessed), Intrusion Alarm System, Emergency Light/Exit Light Panel</p> <p>Years: 1999</p> <p>Type of Service Does Interactive Whiteboard (IWB) Exist? Water Penetration In Electrical Room?</p> <p>Below Ground Yes Yes</p>

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	Yes
Are dedicated intercoms available in all of these spaces for use during a fire?	Yes
Are all dedicated intercoms operational?	Yes

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
Yes	Emergency Lighting - Not Operational	All Emergency Lights in 5th Floor Gymnasium are Not Operational.	Emergency Lighting	5th Floor Gymnasium	Carlos Intriago	Fireman	No Photo Taken
Yes	Fire Alarm System - Components Not Operational	N/A	Fire Alarm System - Magnetic Door Holder/Contactor	Corridor near Student Cafeteria.	Carlos Intriago	Fireman	No Photo Taken
No	Water Penetration in Electrical Room	N/A	Electrical Equipment	Electrical Room	Carlos Intriago	Fireman	No Photo Taken
Yes	Water Leaks onto Electrical Equipment	N/A	Lighting Fixture, Microphone Jack, Receptacle	Room 386, 389, Auditorium Stage, Corridor near Room 387	Carlos Intriago	Fireman	No Photo Taken
Yes	Intercom - Not Connected to Remote Monitoring Station	N/A	Intercom System - Elevator	Elevator Device ID: 2P10152, 2P11596	Carlos Intriago	Fireman	No Photo Taken

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance on 1st Floor	Inspected
House Lighting	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	Yes
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
AUDITORIUM	
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	1999
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Auditorium-1st Floor
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Projection System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Does not exist
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
CAFETERIA	
Instance on 1st Floor - Staff	Inspected
Instance on 1st Floor - Students	Inspected
Lighting	
Instance on 1st Floor - Staff	Inspected
Instance on 1st Floor - Students	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor - Staff	Inspected
Instance on 1st Floor - Students	Inspected
Pendant Mounted	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
Surface Mounted	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor - Staff	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Students	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - HID	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
Local Sound System	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Inspected
Instance Condition	3- Fair
Installation Year	1999
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Cafeteria-1st Floor - Students
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Projection System	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
Theater Lighting System	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Lighting Fixture - Incandescent	
Lighting Fixture - LED	
Pendant Mounted	
Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Inspected	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - LED	
Recessed Mounted	
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	
Instance on Room 407	Inspected
Power Panel?	Yes
Lighting	
Instance on Room 407	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 407	Does not exist
Lighting Fixture - HID	
Instance on Room 407	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 407	Does not exist
Lighting Fixture - LED	
Instance on Room 407	Inspected
Pendant Mounted	
Instance on Room 407	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 407	Does not exist
Recessed Mounted	
Instance on Room 407	Does not exist
Raceway With Receptacles	
Instance on Room 407	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance on 3rd Floor	Inspected
Instance on 5th Floor	Inspected
Lighting	
Instance on 3rd Floor	Inspected
Instance on 5th Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 3rd Floor	Does not exist
Instance on 5th Floor	Does not exist
Lighting Fixture - HID	
Instance on 3rd Floor	Does not exist
Instance on 5th Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 3rd Floor	Does not exist
Instance on 5th Floor	Does not exist
Lighting Fixture - LED	
Instance on 3rd Floor	Inspected
Instance on 5th Floor	Inspected
Pendant Mounted	
Instance on 3rd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
GYMNASIUM	
Lighting	
Lighting Fixture - LED	
Pendant Mounted	
Instance on 5th Floor	Does not exist
Surface Mounted	
Instance on 3rd Floor	Does not exist
Instance on 5th Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 3rd Floor	Does not exist
Instance on 5th Floor	Does not exist
Local Sound System	
Instance on 3rd Floor	Inspected
Instance Condition	5- Poor
Installation Year	1999
Source of Installation Year	Documented
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE SYSTEM
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 5th Floor	Inspected
Instance Condition	5- Poor
Installation Year	1999
Source of Installation Year	Documented
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE SYSTEM
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Projection System	
Instance on 3rd Floor	Does not exist
Instance on 5th Floor	Does not exist
Scoreboard	
Instance on 3rd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 5th Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 3rd Floor	Does not exist
Instance on 5th Floor	Does not exist
KITCHEN	
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
KITCHEN	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist
LIBRARY	
Instance on 4th Floor	Inspected
Instance on Room 280	Inspected
Lighting	
Instance on 4th Floor	Inspected
Instance on Room 280	Inspected
Lighting Fixture - Fluorescent	
Instance on 4th Floor	Does not exist
Instance on Room 280	Inspected
Pendant Mounted	
Instance on Room 280	Does not exist
Surface Mounted	
Instance on Room 280	Does not exist
Recessed Mounted	
Instance on Room 280	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 4th Floor	Does not exist
Instance on Room 280	Does not exist
Lighting Fixture - Incandescent	
Instance on 4th Floor	Does not exist
Instance on Room 280	Does not exist
Lighting Fixture - LED	
Instance on 4th Floor	Inspected
Instance on Room 280	Does not exist
Pendant Mounted	
Instance on 4th Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 4th Floor	Does not exist
Recessed Mounted	
Instance on 4th Floor	Does not exist
Raceway With Receptacles	
Instance on 4th Floor	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
LIBRARY	
Raceway With Receptacles	
Deficiency	No deficiencies recorded
Instance on Room 280	Does not exist
Projection System	
Instance on 4th Floor	Does not exist
Instance on Room 280	Does not exist
LOCKER ROOM	
	Inspected
Instance on 5th Floor - Boys	Inspected
Alternative Use	No
Instance on 5th Floor - Girls	Inspected
Alternative Use	No
Lighting	
Instance on 5th Floor - Boys	Inspected
Instance on 5th Floor - Girls	Inspected
Lighting Fixture - Fluorescent	
Instance on 5th Floor - Boys	Does not exist
Instance on 5th Floor - Girls	Does not exist
Lighting Fixture - HID	
Instance on 5th Floor - Boys	Does not exist
Instance on 5th Floor - Girls	Does not exist
Lighting Fixture - Incandescent	
Instance on 5th Floor - Boys	Does not exist
Instance on 5th Floor - Girls	Does not exist
Lighting Fixture - LED	
Instance on 5th Floor - Boys	Inspected
Instance on 5th Floor - Girls	Inspected
Pendant Mounted	
Instance on 5th Floor - Boys	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on 5th Floor - Girls	Does not exist
Surface Mounted	
Instance on 5th Floor - Boys	Does not exist
Instance on 5th Floor - Girls	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 5th Floor - Boys	Does not exist
Instance on 5th Floor - Girls	Does not exist
MULTIPURPOSE ROOM	
	Does not exist
SCIENCE DEMO ROOM	
	Does not exist
SCIENCE LAB	
	Inspected
Instance on Room 314A	Inspected
Power Panel?	Yes
Alternative Use	No
Lighting	
Instance on Room 314A	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 314A	Inspected
Pendant Mounted	
Instance on Room 314A	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 314A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 314A	Does not exist
Lighting Fixture - HID	
Instance on Room 314A	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 314A	Does not exist
Lighting Fixture - LED	
Instance on Room 314A	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Room 314A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 314A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Power Supply	
Instance on Room 314A	Inspected
Instructor Unit	
Instance on Room 314A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 314A	Does not exist
Student Unit	
Instance on Room 314A	Does not exist
Projection System	
Instance on Room 314A	Does not exist
SCIENCE PREP ROOM	
Instance on Room 314	Inspected
Power Panel?	No
Alternative Use	Yes
Lighting	
Instance on Room 314	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 314	Inspected
Pendant Mounted	
Instance on Room 314	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 314	Does not exist
Recessed Mounted	
Instance on Room 314	Does not exist
Lighting Fixture - HID	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
SCIENCE PREP ROOM	
Lighting	
Lighting Fixture - HID	
Instance on Room 314	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 314	Does not exist
Lighting Fixture - LED	
Instance on Room 314	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Room 314	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 314	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Power Supply	
Instance on Room 314	Does not exist
SWIMMING POOL	
	Does not exist
TOILET ROOM - STAFF	
	Inspected
Lighting	
	Inspected
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Recessed Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	
Pendant Mounted	
Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Recessed Mounted	Does not exist
TOILET ROOM - STUDENT	
	Inspected
Lighting	
	Inspected
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	
Pendant Mounted	
Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
TOILET ROOM - STUDENT	
Lighting	
Lighting Fixture - LED	
Pendant Mounted	
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Recessed Mounted	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	1- Good
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	5th Floor Gymnasium
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Outside Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EXIT/EMERGENCY LIGHT	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
FIRE ALARM SYSTEM	
Bell/Horn	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3- Fair
Deficiency	PULL STATION COVER IS MISSING
Deficiency Location/Instance	5th Floor Staircase - B, Gymnasium.
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL COVER
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fan Shutdown Control	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CO Detector	Does not exist
Heat Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Inspected
Condition	3- Fair
Deficiency	CONTACTOR NOT OPERATIONAL
Deficiency Location/Instance	Corridor near Student Cafeteria
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Fused Cutout Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	3- Fair
Instance Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Fire Alarm Control Panel (Electronic)	
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	AFP - 400
EquipmentId	Fire Alarm Panel
Installation Year	1999
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
Sub-Panel	Inspected
Bell At Panel	Does not exist
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST
EquipmentId	Elevator Recall Fire Alarm Panel
Installation Year	2014
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
Remote Annunciator	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	5- Poor
Deficiency	PRINTER NOT OPERATIONAL
Deficiency Location/Instance	Custodian's Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Punch Register	Does not exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Inspected
Elevator	Inspected
Condition	3- Fair
Deficiency	NOT CONNECTED TO REMOTE MONITORING STATION
Deficiency Location/Instance	Elevator Device ID: 2P10152, 2P11596

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
INTERCOM SYSTEM	
Elevator	
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL CONNECTION
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Holding Area	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	
Does not exist	
MOTOR CONTROLLER	
Inspected	
MOTOR CONTROL CENTER	
Does not exist	
MOTOR STARTER/CONTACTOR	
Condition	3- Fair
Deficiency	No deficiencies recorded
Variable Frequency Drive	Does not exist
PANEL BOARD	
Inspected	
Fused Disconnect Switch Type	
Condition	3- Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	
Does not exist	
Fused Toggle Switch Type	
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Near Room 110, Outside Electrical Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Molded Case Circuit Breaker Type	
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	
Inspected	
Instance	General Office - Room 211
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Telecor 250
Installation Year	1999

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
PUBLIC ADDRESS SYSTEM	
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SECURITY	Inspected
IPDVS/CCTV System	Inspected
Condition	3- Fair
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	Custodian's Office - Room 110
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 128BPT
Installation Year	2016
Source of Installation Year	Documented
Deficiency	PANEL NOT CONNECTED TO DOE CENTRAL STATION
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL CONNECTION
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inaccessible
Lighting - Security	Inaccessible
SERVICE SWITCH	Inspected
Instance	Electrical Meter Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	I.T.E.
EquipmentId	N/A
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1999
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Meter Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	N/A

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X080

Question	Response
SERVICE SWITCH	
Capacity/Size Quantity	2500
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1999
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	
	Inspected
Number of Spares	0
Fused Disconnect Switch Type	
	Inspected
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	N/A
Capacity/Size Quantity	2500
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	5
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1965
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	
	Does not exist
Molded Case Circuit Breaker Type	
	Does not exist
TELEPHONE SYSTEM	
	Inspected
PBX/Intercom	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standard	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
TRANSFORMER	
	Does not exist