

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X092**




**Asset:** P.S. 92 - BRONX, 700 EAST 179 STREET, BRONX, NY, 10457

Inspection Id	Inspection Type	Time In	Last Edited
1288	MECHANICAL	2023-11-28 08:36AM	2024-01-09 11:42AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Steam Condensate Return Pumping System; CO/Gas Leak Detection System; Student Fixtures - Toilets (~20%) Years: 2023 Systems: Staff Fixtures - Toilets; Student Fixtures - Toilets (~80%), Urinals (~60%) Years: 2022 Systems: Domestic Hot Water System; F&T/Steam Drip Traps; Terminal Unit Thermostatic Traps (~90%) Years: 2019 Systems: Water Service (1 of 2) Years: 2015 Systems: MDF Room - Dedicated A/C Equipment (1 of 2, DX Split System) Years: 2013
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	10,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	Basement MER, Basement Mechanical Area
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Basement - Workshop; 1st Floor - Kitchen Storage Room (painted, 4)
Are there any Emergency Stop Switches with Missing Hammers?	No components

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	Defective Sprinkler/Standpipe System	Sprinkler piping is excessively corroded	Sprinkler Piping	Boiler Room	Juan Acosta	Fireman	
No	Defective Boiler Safety Auxiliary	(4)	Boiler Safety Valve	Boiler Room @ Boilers #1, #2	Juan Acosta	Fireman	
No	Defective Boiler Safety Auxiliary	Water Column Assembly: Sight Glass is leaking	Steam Boiler	Boiler Room / Boiler #1	Juan Acosta	Fireman	

**Inspection**

Question	Response
<b>Mechanical</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

***Mechanical Inspection***

**X092**

<b>Question</b>	<b>Response</b>
<b>AIR CONDITIONING</b>	Does not exist
<b>CENTRAL ACID WASTE NEUTRALIZING TANK</b>	Does not exist
<b>CLIMATE CONTROL SYSTEM</b>	Inspected
<b>BMS</b>	Does not exist
<b>Pneumatic System</b>	Inspected
Instance	Throughout
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	41-60%
Deficiency	DEFECTIVE AIR COMPRESSOR
Deficiency Location/Instance	Boiler Room (1 of 2)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Rooms 420, 453, 461 and other locations
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Hybrid System</b>	Does not exist
<b>Electric System</b>	Does not exist
<b>COMPACTOR</b>	Does not exist
<b>CONVEYING</b>	Does not exist
<b>DOMESTIC WATER SYSTEM</b>	Inspected
<b>Domestic Cold Water System</b>	Inspected
<b>Gravity System</b>	Does not exist
<b>Pressure Booster System</b>	Does not exist
<b>Water Service</b>	Inspected
Instance	Basement Mechanical Area
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN:MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement Mechanical Area
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN:MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Boiler Room

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X092**

Question	Response
<b>DOMESTIC WATER SYSTEM</b>	
<b>Domestic Cold Water System</b>	
<b>Water Service</b>	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Domestic Hot Water System</b>	Inspected
<b>Domestic Hot Water Remote Storage Tank</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Domestic Water Heat Exchanger</b>	Does not exist
<b>Electric Domestic Water Heater</b>	Does not exist
<b>Gas Fired Domestic Water Heater</b>	Inspected
Instance	Boiler Room
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lochinvar
EquipmentId	N/A
Capacity/Size Quantity	500
Capacity/Size UOM	MBH Input
Capacity/Size 2 Quantity	0
Capacity/Size 2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2019
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Oil Fired Domestic Water Heater</b>	Does not exist
<b>Heat Pump Domestic Water Heater</b>	Does not exist
<b>Domestic Water Distribution Piping</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>DRAIN/WASTE/VENT AND STORM SYSTEM</b>	Inspected
<b>Interior Storm Piping</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Sewage/Waste/Vent Piping</b>	Inspected
Condition	3- Fair
Deficiency	SEWAGE/WASTE PIPING:DEFECTIVE/LEAKS
Deficiency Location/Instance	Toilet Room inside Nurse Office
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Sewage Ejector Pump</b>	Does not exist
<b>Sump Pump</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)</b>	Does not exist
<b>FIXTURES</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X092**

Question	Response
<b>FIXTURES</b>	
<b>Staff And Other</b>	Inspected
<b>Janitor Sink</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Toilet</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Urinal</b>	Does not exist
<b>Student</b>	Inspected
<b>Drinking Fountain</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Locker Room Shower</b>	Does not exist
<b>Sink And Fountain Combo Unit</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Toilet</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Urinal</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>GAS FIRED FURNACE</b>	Does not exist
<b>GAS SERVICE</b>	Inspected
<b>Gas Distribution Piping</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Gas Meter Room Exhaust Fan</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Gas Meter Room Vent</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Gas Pressure Booster</b>	Inspected
Instance	Basement - Gas Meter Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Eclipse
EquipmentId	N/A
Capacity/Size Quantity	27000
Capacity/Size UOM	SCFH
Source of Capacity/Size	Documented
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>CO/Gas Leak Detection</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X092**

<b>Question</b>	<b>Response</b>
<b>GAS SERVICE</b>	
<b>CO/Gas Leak Detection</b>	
Instance	Basement - Boiler Room, Gas Meter Room
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2023
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
<b>HEATING</b>	
<b>Heating Coil In Ductwork</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Hydronic Heating</b>	
<b>Radiator/Convactor/Fin Tube</b>	
Condition	Does not exist
Deficiency	Inspected
Deficiency	3- Fair
Deficiency	RADIATOR/CONVECTOR:DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Exit "10"
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Steam Heating</b>	
<b>F&amp;T/Steam Drip Trap</b>	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MER Steam and Condensate Piping</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Basement MER
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Steam Condensate Return Piping</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Steam Condensate Return Pumping System</b>	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
<b>Steam Piping</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Terminal Unit Thermostatic Trap</b>	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Steam supplied by External Sources</b>	
<b>Unit Heater/Cabinet Heater</b>	
Does not exist	
<b>HEATING PLANT</b>	
Instance on Basement	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X092**

Question	Response
<b>HEATING PLANT</b>	
Is there a water meter on the boiler make-up water piping?	Yes
Observed Operational?	Yes
Burner Manufacturer	GORDON-PIATT
Burner Model	F14-GO-50
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2
<b>Boiler Auxiliaries</b>	
Instance on Basement	Inspected
<b>Boiler Auxiliary Piping</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Boiler Emergency Stop Switch</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Boiler Feedwater System</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Boiler Feedwater Treatment(Automatic)</b>	
Instance on Basement	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Boiler Flue Exhaust</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Boiler Make-up Water Backflow Preventer</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Boiler Room Steam And Condensate Piping</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Boiler Safety Valve</b>	
Instance on Basement	Inspected
Instance Condition	5- Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room @ Boilers #1, #2
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X092**

Question	Response
<b>HEATING PLANT</b>	
<b>Boiler System</b>	
Instance on Basement	Inspected
<b>Coal-fired Boiler</b>	
Instance on Basement	Does not exist
<b>Hot Water Boiler</b>	
Instance on Basement	Does not exist
<b>Modular Boiler</b>	
Instance on Basement	Does not exist
<b>Steam Boiler</b>	
Instance on Basement	Inspected
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	6,498
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	A. L. Eastmond & Sons Inc.
EquipmentId	6047-01
Capacity/Size Quantity	6498
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2001
Source of Installation Year	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE SAFETY AUXILIARY: LOW-WATER CUT-OFF, WATER COLUMN ASSEMBLY
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	6,498
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	A. L. Eastmond & Sons Inc.
EquipmentId	6047-02
Capacity/Size Quantity	6498
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2001
Source of Installation Year	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

***Mechanical Inspection***

**X092**

<b>Question</b>	<b>Response</b>
<b>HEATING PLANT</b>	
<b>Boiler System</b>	
<b>Steam Boiler</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fuel System</b>	
Instance on Basement	Inspected
<b>Boiler Fresh Air Louver/Damper</b>	
Instance on Basement	Inspected
Instance Condition	4- Between Fair and Poor
Type	Automatic
Deficiency	DEFECTIVE ACTUATOR
Deficiency Location/Instance	Boiler Room @ Boilers #1, #2
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Burner/Burner Control Panel</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fuel Oil Storage/Supply System</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	FUEL OIL TRANSFER PUMP:DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Gas Trains And Vent At The Boiler</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Enclosed IDF Room</b>	
Instance on Room 263	Inspected
<b>Dedicated A/C Equipment</b>	
Instance on Room 263	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room 263
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>KITCHEN</b>	
Instance on 1st Floor	Inspected
<b>CO Detector</b>	
Instance on 1st Floor	Inspected



**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X092**

Question	Response
<b>KITCHEN</b>	
<b>CO Detector</b>	
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Gas System</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Grease Trap</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Hood</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Hood Exhaust Ductwork</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Outside the Kitchen Wall
Deficiency Quantity	30
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Hood Exhaust Fan</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Hood Fire Suppression System</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hot Water Temperature Booster</b>	
Instance on 1st Floor	Does not exist
<b>Kitchen Sink</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>MDF Room</b>	
Instance on Room 201B	Inspected
<b>Dedicated A/C Equipment</b>	
Instance on Room 201B	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	
	Does not exist
<b>SCIENCE LAB</b>	
	Does not exist
<b>SCIENCE PREP ROOM</b>	
	Does not exist
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	
	Inspected
<b>Dry Sprinkler Alarm Valve Assembly</b>	
	Does not exist
<b>Wet Sprinkler Alarm Valve Assembly</b>	
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X092**

Question	Response
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	
<b>Wet Sprinkler Alarm Valve Assembly</b>	
Deficiency	No deficiencies recorded
<b>Fire Booster Pump Assembly</b>	Does not exist
<b>Roof Tank</b>	Does not exist
<b>Siamese Connection</b>	Does not exist
<b>Sprinkler Head</b>	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Basement - Workshop; 1st Floor - Kitchen Storage Room (painted, 4)
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
<b>Sprinkler Piping</b>	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
<b>Standpipe System</b>	Does not exist
<b>Water Gong</b>	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>VENTILATION</b>	Inspected
Is the building Mechanically ventilated?	Partial
<b>Exhaust Fan</b>	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-25
Deficiency	DEFECTIVE
Deficiency Location/Instance	Basement Mechanical Area / House EF #3 (belt)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Heating And Ventilating Unit</b>	Does not exist
<b>Metal Ductwork</b>	Inspected
Condition	3- Fair
Are there any uninsulated ductwork by design in Mechanical rooms?	Yes
Are there chain operated dampers?	No
Deficiency	No deficiencies recorded
<b>Supply Fan</b>	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-5
Deficiency	DEFECTIVE MOTOR
Deficiency Location/Instance	Basement Mechanical Area / 4th Floor Blower #3
Deficiency Quantity	1
Quantity Uom	EACH

NYC Department of Education  
Building Condition Assessment Survey 2023-2024

*Mechanical Inspection*

**X092**

Question	Response
<b>VENTILATION</b>	
<b>Supply Fan</b>	
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Unit Ventilator</b>	Does not exist