

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X104**

**Asset:** P.S. 199 - BRONX, 1449 SHAKESPEARE AVENUE, BRONX, NY, 10452

Inspection Id	Inspection Type	Time In	Last Edited
3657	ELECTRICAL	2024-03-01 07:46AM	2024-05-06 03:09PM



**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: LAN Years: 2022 Systems: Partial Switchboard Years: 2021 Systems: Emergency Lights (Battery Pack), Most Emergency Lights (Non Battery Pack), LED (Health Clinic - Room 426), Toilet Room (Recessed Fluorescent Lighting), LAN for Health Clinic - Room 426M (MDF) Years: 2018 Systems: IPDVS/CCTV System, Interior Fluorescent Lighting (Except Library), Gymnasium (LED Lighting), Exit Lights Years: 2015 Systems: Intrusion Alarm System (Siren/Strobe) Years: 2014 Systems: Fire Alarm System, Public Address System, Auxiliary Signal/Bell System, Local Sound System, Partial Motor Starters, Telephone System Years: 2013 Systems: Service Switch Years: 2012, 2008 Systems: Partial Molded Case Circuit Breaker Panel Board Years: 2010, 2003, 1997 Systems: Library (Lighting) Years: 2009 Systems: Intrusion Alarm System, Security Lights Years: 2007 Systems: Emergency Light/Exit Light Panel Years: 1992
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	Yes

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	Water Penetration in Electrical Room	N/A	Electrical Equipment	Electrical Meter Room	Roman Roque	Fireman	
No	Water Leaks onto Electrical Equipment	N/A	Lighting Fixture	Boiler Room Entrance	Roman Roque	Fireman	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X104**

**Inspection**

Question	Response
<b>Electrical</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance on 1st Floor	Inspected
<b>House Lighting</b>	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	Yes
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not exist
<b>Local Sound System</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2013
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
<b>Theater Lighting System</b>	
Instance on 1st Floor	Inspected
<b>Dimming System</b>	
Instance on 1st Floor	Does not exist
<b>Theater Lighting</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	22

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X104**

Question	Response
<b>AUDITORIUM</b>	
<b>Theater Lighting System</b>	
<b>Theater Lighting</b>	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>CAFETERIA</b>	
	Inspected
Instance on 1st Floor	Inspected
<b>Lighting</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not exist
<b>Local Sound System</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2013
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 1st Floor	Does not exist
<b>Theater Lighting System</b>	
Instance on 1st Floor	Does not exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
	Inspected
<b>Lighting</b>	
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
	Inspected
<b>Pendant Mounted</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
	Does not exist
<b>Lighting Fixture - HID</b>	
	Does not exist
<b>Lighting Fixture - Incandescent</b>	
	Does not exist
<b>Lighting Fixture - LED</b>	
	Inspected
<b>Pendant Mounted</b>	
	Does not exist
<b>Surface Mounted</b>	
	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X104**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
<b>Recessed Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	
	Inspected
Instance on Room 405	Inspected
Power Panel?	No
<b>Lighting</b>	
Instance on Room 405	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 405	Inspected
<b>Pendant Mounted</b>	
Instance on Room 405	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 405	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 405	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 405	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 405	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 405	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 405	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	
Instance on 3rd Floor	Inspected
<b>Lighting</b>	
Instance on 3rd Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 3rd Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 3rd Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 3rd Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 3rd Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 3rd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	13
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X104**

Question	Response
<b>GYMNASIUM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
<b>Surface Mounted</b>	
Instance on 3rd Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 3rd Floor	Does not exist
<b>Local Sound System</b>	
Instance on 3rd Floor	Inspected
Instance Condition	3- Fair
Installation Year	2013
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 3rd Floor	Does not exist
<b>Scoreboard</b>	
Instance on 3rd Floor	Does not exist
<b>Theater Lighting System</b>	
Instance on 3rd Floor	Does not exist
<b>KITCHEN</b>	
Instance on 1st Floor	Inspected
Instance on 1st Floor	Inspected
<b>Lighting</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not exist
<b>LIBRARY</b>	
Instance on Room 307/309	Inspected
Instance on Room 307/309	Inspected
<b>Lighting</b>	
Instance on Room 307/309	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 307/309	Inspected
<b>Pendant Mounted</b>	
Instance on Room 307/309	Does not exist
<b>Surface Mounted</b>	
Instance on Room 307/309	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 307/309	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X104**

Question	Response
<b>LIBRARY</b>	
<b>Lighting</b>	
<b>Lighting Fixture - HID</b>	
Instance on Room 307/309	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 307/309	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 307/309	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 307/309	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on Room 307/309	Does not exist
<b>LOCKER ROOM</b>	Does not exist
<b>MULTIPURPOSE ROOM</b>	Inspected
Instance on 1st Floor	Inspected
<b>Lighting</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not exist
<b>Local Sound System</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2013
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 1st Floor	Does not exist
<b>Theater Lighting System</b>	
Instance on 1st Floor	Does not exist
<b>SCIENCE DEMO ROOM</b>	Does not exist
<b>SCIENCE LAB</b>	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X104**

Question	Response
<b>TOILET ROOM - STAFF</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Does not exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	1- Good
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Auditorium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Gymnasium
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Non Battery Pack</b>	Inspected
Condition	1- Good

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X104**

Question	Response
<b>EMERGENCY LIGHTING</b>	
<b>Non Battery Pack</b>	
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Auditorium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Does not exist
<b>EXIT/EMERGENCY LIGHT</b>	Does not exist
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>Bell/Horn</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Manual Pull Station</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Area Smoke Detector</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>CO Detector</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Heat Detector</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Elevator Recall</b>	Does not exist
<b>Magnetic Door Holder/Contactor</b>	Does not exist
<b>Fused Cutout Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Digital Communicator</b>	Does not exist
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	1st Floor By Exit 2
Instance Condition	2- Between Good and Fair



**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X104**

Question	Response
<b>FIRE ALARM SYSTEM</b>	
<b>Main Panel</b>	
<b>Fire Alarm Control Panel (Electronic)</b>	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	General Electric
Model	EST 3
EquipmentId	Fire Alarm Control Panel
Installation Year	2013
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>Sub-Panel</b>	Does not exist
<b>Remote Annunciator</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Printer</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Punch Register</b>	Does not exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Does not exist
<b>Tamper Flow Switch/Chain</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>INTERCOM SYSTEM</b>	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>MOTOR CONTROLLER</b>	Inspected
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Variable Frequency Drive</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room, Electrical Equipment Room, Mechanical Room Basement.
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X104**

Question	Response
<b>PANEL BOARD</b>	
<b>Fused Disconnect Switch Type</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD DOOR LOCK IS MISSING
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Fused Toggle Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Meter Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Inspected
Instance	General Office - Room 254
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane 250
Installation Year	2013
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
<b>SECURITY</b>	Inspected
<b>IPDVS/CCTV System</b>	Inspected
Condition	2- Between Good and Fair
Installation Year	2015
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
<b>Intrusion Alarm System</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	Custodian's Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128B

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X104**

Question	Response
<b>SECURITY</b>	
<b>Intrusion Alarm System</b>	
<b>Central Control Panel</b>	
Installation Year	2007
Source of Installation Year	Custodial Staff
Deficiency	PANEL NOT CONNECTED TO DOE CENTRAL STATION
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REWIRE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>Infrared Sensor</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting - Security</b>	Inaccessible
<b>SERVICE SWITCH</b>	
Instance	Electrical Meter Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Boltswitch
EquipmentId	N/A
Capacity/Size Quantity	2000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2008
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
Instance	Electrical Meter Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	General Electric
EquipmentId	Service Switch
Capacity/Size Quantity	200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2012
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
<b>SWITCHBOARD</b>	
Number of Spares	0
<b>Fused Disconnect Switch Type</b>	
Instance	Electrical Equipment Room
Instance Condition	1- Good

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X104**

Question	Response
<b>SWITCHBOARD</b>	
<b>Fused Disconnect Switch Type</b>	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	ACDP
Capacity/Size Quantity	400
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2021
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
Instance	Electrical Equipment Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington
EquipmentId	N/A
Capacity/Size Quantity	2000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	3
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1964
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Equipment Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Does not exist
<b>TELEPHONE SYSTEM</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>TRANSFORMER</b>	Does not exist