

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

**Asset:** I.S. 142 - BRONX, 3750 BAYCHESTER AVENUE, BRONX, NY, 10466

Inspection Id	Inspection Type	Time In	Last Edited
1182	ELECTRICAL	2023-11-22 08:40AM	2024-04-24 12:44PM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Computer Lab Room B21 (Raceways with Receptacles), Auditorium (Theater Lighting System, Local Sound System, Projection System) Years: 2023 Systems: LAN Years: 2022 Systems: Exit/Emergency Light Years: 2021 Systems: Exit Lights (Battery Pack) Years: 2020 Systems: Security Lights Years: 2019, 2017 Systems: IPDVS/CCTV System, Most Emergency Lights Years: 2019 Systems: Interior Lighting Years: 2017 Systems: Computer Room 223 (Raceways with Receptacles) Years: 2015 Systems: Gymnasium (Scoreboard) Years: 2014 Systems: Partial Molded Case Circuit Breaker Panel Board Years: 2011, 1995 Systems: Intrusion Alarm System - Central Control Panel, Science Rooms (105A, 105) Years: 2011 Systems: Emergency Light/Exit Light Panel, Fused Disconnect Panel Boards Years: 2010 Systems: Public Address System, Local Sound System, Fire Alarm System Years: 2008
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image	
		No condition recorded						

**Inspection**

Question	Response
<b>Electrical</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance on 1st Floor	Inspected
<b>House Lighting</b>	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

Question	Response
<b>AUDITORIUM</b>	
<b>House Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Local Sound System</b>	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Installation Year	2022
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
<b>Theater Lighting System</b>	
Instance on 1st Floor	Inspected
<b>Dimming System</b>	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Theater Lighting</b>	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance on Basement - Staff	Inspected
Instance on Basement - Students	Inspected
<b>Lighting</b>	
Instance on Basement - Staff	Inspected
Instance on Basement - Students	Inspected
<b>Lighting Fixture - Fluorescent</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

Question	Response
<b>CAFETERIA</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement - Staff	Inspected
Instance on Basement - Students	Inspected
<b>Pendant Mounted</b>	
Instance on Basement - Staff	Does not exist
Instance on Basement - Students	Does not exist
<b>Surface Mounted</b>	
Instance on Basement - Staff	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Basement - Students	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Basement - Staff	Does not exist
Instance on Basement - Students	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Basement - Staff	Does not exist
Instance on Basement - Students	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement - Staff	Does not exist
Instance on Basement - Students	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Basement - Staff	Does not exist
Instance on Basement - Students	Does not exist
<b>Local Sound System</b>	
Instance on Basement - Staff	Does not exist
Instance on Basement - Students	Inspected
Instance Condition	3- Fair
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on Basement - Staff	Does not exist
Instance on Basement - Students	Does not exist
<b>Theater Lighting System</b>	
Instance on Basement - Staff	Does not exist
Instance on Basement - Students	Does not exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
	Does not exist
<b>Lighting Fixture - HID</b>	
	Does not exist
<b>Lighting Fixture - Incandescent</b>	
	Does not exist
<b>Lighting Fixture - LED</b>	
	Does not exist
<b>COMPUTER LAB</b>	
	Inspected
Instance on Room 124	Inspected
Power Panel?	No
Instance on Room 223	Inspected
Power Panel?	Yes
Instance on Room B53	Inspected
Power Panel?	No
Instance on Room B21	Inspected
Power Panel?	Yes
Instance on Room 202	Inspected
Power Panel?	No
<b>Lighting</b>	
Instance on Room 124	Inspected
Instance on Room 223	Inspected
Instance on Room B53	Inspected
Instance on Room B21	Inspected
Instance on Room 202	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 124	Inspected
Instance on Room 223	Inspected
Instance on Room B53	Inspected
Instance on Room B21	Inspected
Instance on Room 202	Inspected
<b>Pendant Mounted</b>	
Instance on Room 124	Does not exist
Instance on Room 223	Does not exist
Instance on Room B53	Does not exist
Instance on Room B21	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 202	Does not exist
<b>Surface Mounted</b>	
Instance on Room 124	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 223	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room B53	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room B21	Does not exist
Instance on Room 202	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

Question	Response
<b>COMPUTER LAB</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 124	Does not exist
Instance on Room 223	Does not exist
Instance on Room B53	Does not exist
Instance on Room B21	Does not exist
Instance on Room 202	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 124	Does not exist
Instance on Room 223	Does not exist
Instance on Room B53	Does not exist
Instance on Room B21	Does not exist
Instance on Room 202	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 124	Does not exist
Instance on Room 223	Does not exist
Instance on Room B53	Does not exist
Instance on Room B21	Does not exist
Instance on Room 202	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 124	Does not exist
Instance on Room 223	Does not exist
Instance on Room B53	Does not exist
Instance on Room B21	Does not exist
Instance on Room 202	Inspected
<b>Pendant Mounted</b>	
Instance on Room 202	Does not exist
<b>Surface Mounted</b>	
Instance on Room 202	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Raceway With Receptacles</b>	
Instance on Room 124	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 223	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room B53	Does not exist
Instance on Room B21	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 202	Does not exist
<b>GYMNASIUM</b>	
Instance on 1st Floor	Inspected
<b>Lighting</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

Question	Response
<b>GYMNASIUM</b>	
<b>Lighting</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Local Sound System</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 1st Floor	Does not exist
<b>Scoreboard</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Theater Lighting System</b>	
Instance on 1st Floor	Does not exist
<b>KITCHEN</b>	
Instance on Basement	Inspected
<b>Lighting</b>	
Instance on Basement	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist
<b>Surface Mounted</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

Question	Response
<b>KITCHEN</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Basement	Does not exist
<b>LIBRARY</b>	
	Does not exist
<b>LOCKER ROOM</b>	
	Inspected
Instance on Basement - Boys	Inspected
Alternative Use	Yes
<b>Lighting</b>	
Instance on Basement - Boys	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement - Boys	Inspected
<b>Pendant Mounted</b>	
Instance on Basement - Boys	Does not exist
<b>Surface Mounted</b>	
Instance on Basement - Boys	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Basement - Boys	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Basement - Boys	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement - Boys	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Basement - Boys	Does not exist
<b>MULTIPURPOSE ROOM</b>	
	Does not exist
<b>SCIENCE DEMO ROOM</b>	
	Inspected
Instance on Room 218	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 222	Inspected
Power Panel?	No
Alternative Use	Yes
<b>Lighting</b>	
Instance on Room 218	Inspected
Instance on Room 222	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 218	Inspected
Instance on Room 222	Inspected
<b>Pendant Mounted</b>	
Instance on Room 218	Does not exist
Instance on Room 222	Does not exist
<b>Surface Mounted</b>	
Instance on Room 218	Inspected
Instance Condition	2- Between Good and Fair

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

Question	Response
<b>SCIENCE DEMO ROOM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Deficiency	No deficiencies recorded
Instance on Room 222	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 218	Does not exist
Instance on Room 222	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 218	Does not exist
Instance on Room 222	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 218	Does not exist
Instance on Room 222	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 218	Does not exist
Instance on Room 222	Does not exist
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 218	Does not exist
Instance on Room 222	Does not exist
<b>Emergency Shut-Off Power</b>	
Instance on Room 218	Does not exist
Instance on Room 222	Does not exist
<b>Power Supply</b>	
Instance on Room 218	Does not exist
Instance on Room 222	Does not exist
<b>Projection System</b>	
Instance on Room 218	Does not exist
Instance on Room 222	Does not exist
<b>SCIENCE LAB</b>	
	Inspected
Instance on Room 105	Inspected
Power Panel?	Yes
Alternative Use	No
<b>Lighting</b>	
Instance on Room 105	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 105	Inspected
<b>Pendant Mounted</b>	
Instance on Room 105	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 105	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 105	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 105	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 105	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 105	Does not exist



**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

Question	Response
<b>SCIENCE LAB</b>	
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 105	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Emergency Shut-Off Power</b>	
Instance on Room 105	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Power Supply</b>	
Instance on Room 105	Does not exist
<b>Projection System</b>	
Instance on Room 105	Does not exist
<b>SCIENCE PREP ROOM</b>	
Instance on Room 105A	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Rooms 120, 220	Inspected
Power Panel?	No
Alternative Use	Yes
<b>Lighting</b>	
Instance on Room 105A	Inspected
Instance on Rooms 120, 220	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 105A	Inspected
Instance on Rooms 120, 220	Inspected
<b>Pendant Mounted</b>	
Instance on Room 105A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 120, 220	Does not exist
<b>Surface Mounted</b>	
Instance on Room 105A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 120, 220	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 105A	Does not exist
Instance on Rooms 120, 220	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 105A	Does not exist
Instance on Rooms 120, 220	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 105A	Does not exist
Instance on Rooms 120, 220	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 105A	Does not exist
Instance on Rooms 120, 220	Does not exist
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 105A	Inspected
Instance Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

Question	Response
<b>SCIENCE PREP ROOM</b>	
<b>Emergency Gas Shut-Off Valve</b>	
Deficiency	No deficiencies recorded
Instance on Rooms 120, 220	Does not exist
<b>Emergency Shut-Off Power</b>	
Instance on Room 105A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 120, 220	Does not exist
<b>Power Supply</b>	
Instance on Room 105A	Does not exist
Instance on Rooms 120, 220	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Does not exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	1- Good

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

<b>Question</b>	<b>Response</b>
<b>EXIT LIGHT</b>	
<b>Battery Pack</b>	
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT/EMERGENCY LIGHT</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>Bell/Horn</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Manual Pull Station</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Area Smoke Detector</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>CO Detector</b>	Under construction
<b>Heat Detector</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Elevator Recall</b>	Does not exist
<b>Magnetic Door Holder/Contactor</b>	Does not exist
<b>Fused Cutout Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Digital Communicator</b>	Does not exist
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Main Entrance
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST 2
EquipmentId	Fire Alarm Control Panel
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>Sub-Panel</b>	Under construction
<b>Remote Annunciator</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Printer</b>	Inspected
Condition	5- Poor
Deficiency	PRINTER NOT OPERATIONAL
Deficiency Location/Instance	Custodian's Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Punch Register</b>	Does not exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Tamper Flow Switch/Chain</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>INTERCOM SYSTEM</b>	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (L/DF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>MOTOR CONTROLLER</b>	Inspected
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Variable Frequency Drive</b>	Under construction
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Fused Toggle Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room near Room B38
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

Question	Response
<b>PANEL BOARD</b>	
<b>Fused Toggle Switch Type</b>	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Molded Case Circuit Breaker Type</b>	
Inspected	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD DOOR LOCK IS MISSING
Deficiency Location/Instance	Kitchen
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
Inspected	Inspected
Instance	General Office - Room 140
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane 250
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>SECURITY</b>	
Inspected	Inspected
<b>IPDVS/CCTV System</b>	
Inspected	Inspected
Condition	2- Between Good and Fair
Installation Year	2019
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Intrusion Alarm System</b>	
Inspected	Inspected
<b>Central Control Panel</b>	
Inspected	Inspected
Instance	Custodian's Office - Room 142
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 50P
Installation Year	2011
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	
Inspected	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	
Inspected	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
Inspected	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

Question	Response
<b>SECURITY</b>	
<b>Intrusion Alarm System</b>	
<b>Remote Annunciator</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting - Security</b>	
	Inaccessible
<b>SERVICE SWITCH</b>	
	Inspected
Instance	Electrical Room Near Room B38
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
EquipmentId	Main SW SER A
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1958
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room Near Room B38
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room Near Room B38
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
EquipmentId	Main SW SER B
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1958
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room Near Room B38
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SWITCHBOARD</b>	
	Inspected
Number of Spares	0
<b>Fused Disconnect Switch Type</b>	
	Does not exist
<b>Fused Knife Switch Type</b>	
	Does not exist
<b>Molded Case Circuit Breaker Type</b>	
	Inspected
Instance	Electrical Room Near Room B38
Instance Condition	3- Fair
Instance Quantity	1

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

Question	Response
<b>SWITCHBOARD</b>	
<b>Molded Case Circuit Breaker Type</b>	
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
EquipmentId	SER A
Capacity/Size Quantity	750
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1958
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room Near Room B38
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room Near Room B38
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
EquipmentId	SER B
Capacity/Size Quantity	750
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1958
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room Near Room B38
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B10
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	SER A/SER B
Capacity/Size Quantity	400
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Inspector Estimate
Installation Year	1958
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B10
Deficiency Quantity	1

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X142**

Question	Response
<b>SWITCHBOARD</b>	
<b>Molded Case Circuit Breaker Type</b>	
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TELEPHONE SYSTEM</b>	
	Inspected
<b>PBX/Intercom</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>TRANSFORMER</b>	
	Does not exist