

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X198

Asset: P.S. 198 - BRONX, 1180 TINTON AVENUE, BRONX, NY, 10456

Inspection Id	Inspection Type	Time In	Last Edited
896	ELECTRICAL	2023-11-10 07:47AM	2023-12-05 10:31AM


Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Security Lights Years: 2023 Systems: Partial Molded Case Circuit Breaker Panel Board Years: 2020, 2017, 2011, 2007, 1999, 1991 Systems: Partial Fused Disconnect Switch Panel Years: 2020 Systems: Most Emergency Lighting (Battery Packs), Health Clinic 305 (Recessed LED Lighting), Variable Frequency Drive Years: 2018 Systems: Exit Lights (Battery Packs), LAN (Local Distribution Frame) Years: 2017 Systems: Interior Lighting Except (Library, Recessed LED Lighting), Gymnasium (Local Sound System, Scoreboard), Exit/Emergency Lights Years: 2015 Systems: Telephone System Years: 2014 Systems: Library Years: 2012 Systems: Intercom System (Elevator, Holding Areas) Years: 2009 Systems: Auditorium (Local Sound System) Years: 2008 Systems: Fire Alarm System, Public Address System (Amplifier, Tuner) Years: 2007 Systems: Intrusion Alarm System Years: 2006 Systems: Emergency Light/Exit Light Panel Years: 1998
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	Fire Alarm System - Components Not Operational	Smoke detector is out of order	Fire Alarm System - Area Smoke Detector	1st Floor	Maurine Ascencio	Custodian	

Inspection

Question	Response
Electrical	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X198

Question	Response
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance on 1st Floor	Inspected
House Lighting	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Is the projector on a cart or installed on the ceiling?	Cart
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Does not exist
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	33
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
CAFETERIA	Inspected
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X198

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Cafeteria-1st Floor
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Projection System	
Instance on 1st Floor	Does not exist
Theater Lighting System	
Instance on 1st Floor	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Does not exist
Recessed Mounted	Inspected
Condition	2- Between Good and Fair

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X198

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - LED	
Recessed Mounted	
Deficiency	No deficiencies recorded
COMPUTER LAB	
	Does not exist
GYMNASIUM	
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Installation Year	2015
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not exist
Scoreboard	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 1st Floor	Does not exist
KITCHEN	
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X198

Question	Response
KITCHEN	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist
LIBRARY	
Instance on Room 200	Inspected
Lighting	
Instance on Room 200	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 200	Inspected
Pendant Mounted	
Instance on Room 200	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 200	Does not exist
Recessed Mounted	
Instance on Room 200	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 200	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 200	Does not exist
Lighting Fixture - LED	
Instance on Room 200	Does not exist
Raceway With Receptacles	
Instance on Room 200	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Room 200	Does not exist
LOCKER ROOM	
	Does not exist
MULTIPURPOSE ROOM	
	Does not exist
SCIENCE DEMO ROOM	
	Does not exist
SCIENCE LAB	
	Does not exist
SCIENCE PREP ROOM	
	Does not exist
SWIMMING POOL	
	Does not exist
TOILET ROOM - STAFF	
	Inspected
Lighting	
	Inspected
Lighting Fixture - Fluorescent	
Pendant Mounted	
	Does not exist
Surface Mounted	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X198

Question	Response
TOILET ROOM - STAFF	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	5- Poor
Deficiency	BELL TRANSFORMER PANEL NOT OPERATIONAL
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE PANEL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected
Bell/Horn	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X198

Question	Response
FIRE ALARM SYSTEM	
Bell/Horn	
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	DETECTOR NOT OPERATIONAL
Deficiency Location/Instance	1st Floor
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
CO Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Heat Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Does not exist
Fused Cutout Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Inspected
Instance	Telephone Room G2
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Ademco
EquipmentId	Fire Alarm Digital Communicator
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Main Panel	Inspected
Bell At Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X198

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Fire Alarm Control Panel (Electronic)	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST 2
EquipmentId	Fire Alarm Control Panel
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
Sub-Panel	Does not exist
Remote Annunciator	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	Does not exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Inspected
Elevator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Holding Area	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LAN	Inspected
Local Distribution Frame (L/DF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MOTOR CONTROLLER	Inspected
MOTOR CONTROL CENTER	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X198

Question	Response
MOTOR CONTROLLER	
MOTOR CONTROL CENTER	
Instance Quantity Uom	EACH
Manufacturer	Allen Bradley
EquipmentId	N/A
Capacity/Size Quantity	200
Capacity/Size UOM	Amps
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Inspector Estimate
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Variable Frequency Drive	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Penthouse, Mechanical Room 209, Boiler Room
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	23
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X198

Question	Response
PANEL BOARD	
Molded Case Circuit Breaker Type	
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	
	Inspected
Instance	Main Office - Room 197
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Main Office - Room 197
Deficiency Quantity	102,000
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SECURITY	
	Inspected
IPDVS/CCTV System	
	Does not exist
Intrusion Alarm System	
	Inspected
Central Control Panel	
Instance	Room 111
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128BP
Installation Year	2006
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting - Security	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SERVICE SWITCH	
	Inspected
Instance	Electrical Room G1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan
EquipmentId	N/A

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X198

Question	Response
SERVICE SWITCH	
Capacity/Size Quantity	3000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room G1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room G1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan
EquipmentId	Serving AC Equipment
Capacity/Size Quantity	1000
Capacity/Size UOM	Amps
Source of Capacity/Size	Fuse Size
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room G1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room G1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan
EquipmentId	Serving HTG Equipment
Capacity/Size Quantity	225
Capacity/Size UOM	Amps
Source of Capacity/Size	Fuse Size
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room G1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWITCHBOARD	Inspected
Number of Spares	1
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room G1

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X198

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
EquipmentId	N/A
Capacity/Size Quantity	3000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	3
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room G1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Mechanical Room 209
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
EquipmentId	N/A
Capacity/Size Quantity	1000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1974
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Mechanical Room 209
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not exist