

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X373**

Asset: **PRE-K CENTER @ 3560 WEBSTER AVENUE - BRONX, 3560 WEBSTER AVENUE, BRONX, NY, 10467**

Inspection Id	Inspection Type	Time In	Last Edited
1621	MECHANICAL	2023-12-13 07:46AM	2024-01-08 11:10AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	No System Upgraded
Are there fuel tanks?	No
Total # of water main service entries to the asset	0
MERs/Fan Rooms Locations	MER 107
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Are there any Emergency Stop Switches with Missing Hammers?	No components

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

**Inspection**

Question	Response
<b>Mechanical</b>	
<b>AIR CONDITIONING</b>	Inspected
<b>Chilled Water System</b>	Does not exist
<b>Condenser Water Distribution: Piping, Pumps and Auxiliaries</b>	Does not exist
<b>Cooling Coil in Ductwork</b>	Does not exist
<b>Cooling Tower</b>	Does not exist
<b>DX Split System</b>	Inspected
<b>Indoor Unit</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Outdoor Unit</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Dry Cooler</b>	Does not exist
<b>Packaged / Rooftop Unit</b>	Inspected
Instance	MER 107
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	United CoolAir
EquipmentId	AHU-1
Capacity/Size Quantity	25
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2016
Source of Installation Year	Documented
Source of Heating	Hydronic
Refrigerant Type	R-410A
Deficiency	No deficiencies recorded
<b>Packaged Terminal A/C</b>	Does not exist
<b>Refrigerant Leak Detection System</b>	Does not exist
<b>Refrigerant Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Return Fan</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

***Mechanical Inspection***

**X373**

<b>Question</b>	<b>Response</b>
<b>CENTRAL ACID WASTE NEUTRALIZING TANK</b>	Does not exist
<b>CLIMATE CONTROL SYSTEM</b>	Inspected
<b>BMS</b>	Inspected
Instance	Throughout
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Installation Year	2016
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Pneumatic System</b>	Does not exist
<b>Hybrid System</b>	Does not exist
<b>Electric System</b>	Does not exist
<b>COMPACTOR</b>	Does not exist
<b>CONVEYING</b>	Does not exist
<b>DOMESTIC WATER SYSTEM</b>	Inspected
<b>Domestic Cold Water System</b>	Does not exist
<b>Domestic Hot Water System</b>	Inspected
<b>Domestic Hot Water Remote Storage Tank</b>	Does not exist
<b>Domestic Water Heat Exchanger</b>	Does not exist
<b>Electric Domestic Water Heater</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Gas Fired Domestic Water Heater</b>	Does not exist
<b>Oil Fired Domestic Water Heater</b>	Does not exist
<b>Heat Pump Domestic Water Heater</b>	Does not exist
<b>Domestic Water Distribution Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>DRAIN/WASTE/VENT AND STORM SYSTEM</b>	Inspected
<b>Interior Storm Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Sewage/Waste/Vent Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Sewage Ejector Pump</b>	Does not exist
<b>Sump Pump</b>	Does not exist
<b>DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)</b>	Does not exist
<b>FIXTURES</b>	Inspected
<b>Staff And Other</b>	Inspected
<b>Janitor Sink</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Toilet</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Urinal</b>	Does not exist
<b>Student</b>	Inspected
<b>Drinking Fountain</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X373**

Question	Response
<b>FIXTURES</b>	
<b>Student</b>	
<b>Drinking Fountain</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Rooms 102, 115
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Locker Room Shower</b>	Does not exist
<b>Sink And Fountain Combo Unit</b>	Does not exist
<b>Toilet</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Urinal</b>	Does not exist
<b>GAS FIRED FURNACE</b>	Does not exist
<b>GAS SERVICE</b>	Does not exist
<b>HEATING</b>	Inspected
<b>Heating Coil In Ductwork</b>	Does not exist
<b>Hydronic Heating</b>	Inspected
<b>Hydronic Hot Water Distribution: Piping, Pumps and Auxiliaries</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Backflow Preventer</b>	Does not exist
<b>Hot Water Heat Exchanger</b>	Does not exist
<b>Radiator/Convactor/Fin Tube</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Steam Heating</b>	Does not exist
<b>Steam supplied by External Sources</b>	Does not exist
<b>Unit Heater/Cabinet Heater</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	MER 107 (1 of 1)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>HEATING PLANT</b>	Does not exist
<b>Enclosed IDF Room</b>	Does not exist
<b>KITCHEN</b>	Inspected
Instance on 1st Floor	Inspected
<b>CO Detector</b>	
Instance on 1st Floor	Not required
<b>Gas System</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X373**

Question	Response
<b>KITCHEN</b>	
<b>Gas System</b>	
Instance on 1st Floor	Does not exist
<b>Grease Trap</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hood</b>	
Instance on 1st Floor	Does not exist
<b>Hood Exhaust Ductwork</b>	
Instance on 1st Floor	Does not exist
<b>Hood Exhaust Fan</b>	
Instance on 1st Floor	Does not exist
<b>Hood Fire Suppression System</b>	
Instance on 1st Floor	Does not exist
<b>Hot Water Temperature Booster</b>	
Instance on 1st Floor	Does not exist
<b>Kitchen Sink</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MDF Room</b>	Inspected
Instance on Room 114	Inspected
<b>Dedicated A/C Equipment</b>	
Instance on Room 114	Inspected
Instance Condition	3- Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Room 114
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCIENCE DEMO ROOM</b>	Does not exist
<b>SCIENCE LAB</b>	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	Inspected
<b>Dry Sprinkler Alarm Valve Assembly</b>	Does not exist
<b>Wet Sprinkler Alarm Valve Assembly</b>	Does not exist
<b>Fire Booster Pump Assembly</b>	Does not exist
<b>Roof Tank</b>	Does not exist
<b>Siamese Connection</b>	Does not exist
<b>Sprinkler Head</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Sprinkler Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Standpipe System</b>	Does not exist
<b>Water Gong</b>	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>VENTILATION</b>	Inspected
Is the building Mechanically ventilated?	Yes
<b>Exhaust Fan</b>	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

***Mechanical Inspection***

**X373**

Question	Response
<b>VENTILATION</b>	
<b>Exhaust Fan</b>	
Condition	2- Between Good and Fair
Approximate Total # of Fans	1-25
Deficiency	No deficiencies recorded
<b>Heating And Ventilating Unit</b>	
Does not exist	
<b>Metal Ductwork</b>	
Inspected	
Condition	1- Good
Are there any uninsulated ductwork by design in Mechanical rooms?	Yes
Are there chain operated dampers?	No
Deficiency	No deficiencies recorded
<b>Supply Fan</b>	
Does not exist	
<b>Unit Ventilator</b>	
Does not exist	