

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

**Asset:** WILLIAM H. TAFT HS - BRONX, 240 EAST 172 STREET, BRONX, NY, 10457

Inspection Id	Inspection Type	Time In	Last Edited
4921	ELECTRICAL	2024-04-23 09:12AM	2024-06-17 10:52AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Security Lights, Partial LAN Years: 2023 Systems: Intercom System (Fire Rescue Areas), Interior Retrofitted LED Lighting (Except Penthouse - Mechanical Room and Gymnasium 1st Floor) Years: 2021 Systems: Partial Emergency Lighting (Battery Pack) Years: 2019, 2012 Systems: Exit Lights (Battery Pack), Fire Alarm System (Electronic Sub Panel), IPDVS/CCTV System, 1st Floor Gymnasium (LED Lighting, Scoreboard), Emergency Lights (Non Battery Pack) Years: 2019 Systems: Telephone System Years: 2018 Systems: Grounding System, Library (Projection System), Auditorium (Dimming System) Years: 2015 Systems: Fused Disconnect Switch Type Panel Boards Years: 2011, 2001 Systems: Variable Frequency Drive Years: 2011 Systems: Public Address System, Local Sound System, Auditorium (Theater Lighting) Years: 2010 Systems: Fire Alarm System Except (Electronic Sub-Panel), Interior Fluorescent Pendant Lighting (Penthouse - MER, Boiler Room Crawl Space). Years: 2008 Systems: Molded Case Circuit Breaker Panel Boards Years: 2007, 2001, 1990 Systems: Service Switch, Switchboard Years: 2001, 1990 Systems: Intrusion Alarm System Years: 2001 Type of Service Does Interactive Whiteboard (IWB) Exist? Water Penetration In Electrical Room?

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	Yes
Are dedicated intercoms available in all of these spaces for use during a fire?	Yes
Are all dedicated intercoms operational?	Yes

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	Exposed Electrical Wires	Raceway is broken and wires are exposed.	Raceway With Receptacles	Computer Lab Room 227	Ricardo Guzman	Fireman	No Photo Taken
No	Emergency Lighting - Not Operational	N/A	Emergency Lighting	Throughout the Building	Ricardo Guzman	Fireman	No Photo Taken

**Inspection**

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

<b>Question</b>	<b>Response</b>
<b>Electrical</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance on 1st Floor	Inspected
<b>House Lighting</b>	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Local Sound System</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 1st Floor	Inspected
Instance Condition	5- Poor
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	VIDEO PROJECTOR IS NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Theater Lighting System</b>	
Instance on 1st Floor	Inspected
<b>Dimming System</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Theater Lighting</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>CAFETERIA</b>	Inspected
Instance on Basement	Inspected
<b>Lighting</b>	
Instance on Basement	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist
<b>Surface Mounted</b>	
Instance on Basement	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Local Sound System</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on Basement	Does not exist
<b>Theater Lighting System</b>	
Instance on Basement	Does not exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>Lighting</b>	Inspected
Does a Chandelier Exist?	Yes
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Inspected
Instance on Room 227	Inspected
Power Panel?	Yes

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>COMPUTER LAB</b>	
Instance on Room 277	Inaccessible
<b>Lighting</b>	
Instance on Room 227	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 227	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 227	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 227	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 227	Inspected
<b>Pendant Mounted</b>	
Instance on Room 227	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 227	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 227	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 227	Inspected
Instance Condition	3- Fair
Deficiency	RECEPTACLES NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>GYMNASIUM</b>	
Instance on 1st Floor	Inspected
Instance on 4th Floor - South, 4th Floor - North	Inspected
<b>Lighting</b>	
Instance on 1st Floor	Inspected
Instance on 4th Floor - South, 4th Floor - North	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Does not exist
Instance on 4th Floor - South, 4th Floor - North	Inspected
<b>Pendant Mounted</b>	
Instance on 4th Floor - South, 4th Floor - North	Does not exist
<b>Surface Mounted</b>	
Instance on 4th Floor - South, 4th Floor - North	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 4th Floor - South, 4th Floor - North	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
Instance on 4th Floor - South, 4th Floor - North	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
Instance on 4th Floor - South, 4th Floor - North	Does not exist
<b>Lighting Fixture - LED</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>GYMNASIUM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Inspected
Instance on 4th Floor - South, 4th Floor - North	Does not exist
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Local Sound System</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance on 4th Floor - South, 4th Floor - North	Inspected
Instance Condition	3- Fair
Installation Year	2010
Source of Installation Year	Documented
Deficiency	MICROPHONE / JACK NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Projection System</b>	
Instance on 1st Floor	Does not exist
Instance on 4th Floor - South, 4th Floor - North	Does not exist
<b>Scoreboard</b>	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on 4th Floor - South, 4th Floor - North	Does not exist
<b>Theater Lighting System</b>	
Instance on 1st Floor	Does not exist
Instance on 4th Floor - South, 4th Floor - North	Does not exist
<b>KITCHEN</b>	
Instance on Basement	Inspected
<b>Lighting</b>	
Instance on Basement	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>KITCHEN</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
<b>Surface Mounted</b>	
Instance on Basement	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	
Instance on Room 455	Inspected
<b>Lighting</b>	
Instance on Room 455	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 455	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 455	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 455	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 455	Inspected
<b>Pendant Mounted</b>	
Instance on Room 455	Does not exist
<b>Surface Mounted</b>	
Instance on Room 455	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 455	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 455	Does not exist
<b>Projection System</b>	
Instance on Room 455	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LOCKER ROOM</b>	
Instance on 2nd Floor - Boys, 2nd Floor - Girls	Inspected
Alternative Use	No
Instance on 3rd Floor - Girls	Inspected
Alternative Use	No
<b>Lighting</b>	
Instance on 2nd Floor - Boys, 2nd Floor - Girls	Inspected
Instance on 3rd Floor - Girls	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 2nd Floor - Boys, 2nd Floor - Girls	Does not exist
Instance on 3rd Floor - Girls	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 2nd Floor - Boys, 2nd Floor - Girls	Does not exist
Instance on 3rd Floor - Girls	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 2nd Floor - Boys, 2nd Floor - Girls	Does not exist
Instance on 3rd Floor - Girls	Does not exist
<b>Lighting Fixture - LED</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>LOCKER ROOM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
Instance on 2nd Floor - Boys, 2nd Floor - Girls	Inspected
Instance on 3rd Floor - Girls	Inspected
<b>Pendant Mounted</b>	
Instance on 2nd Floor - Boys, 2nd Floor - Girls	Does not exist
Instance on 3rd Floor - Girls	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on 2nd Floor - Boys, 2nd Floor - Girls	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 3rd Floor - Girls	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 2nd Floor - Boys, 2nd Floor - Girls	Does not exist
Instance on 3rd Floor - Girls	Does not exist
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>SCIENCE DEMO ROOM</b>	Inspected
Instance on Room 105	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 202	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 263	Inspected
Power Panel?	Yes
Alternative Use	Yes
Instance on Room 161	Inspected
Power Panel?	No
Alternative Use	No
<b>Lighting</b>	
Instance on Room 105	Inspected
Instance on Room 202	Inspected
Instance on Room 263	Inspected
Instance on Room 161	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 202	Does not exist
Instance on Room 263	Does not exist
Instance on Room 105	Does not exist
Instance on Room 161	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 202	Does not exist
Instance on Room 263	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>SCIENCE DEMO ROOM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - HID</b>	
Instance on Room 105	Does not exist
Instance on Room 161	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 202	Inspected
Instance on Room 263	Inspected
Instance on Room 105	Does not exist
Instance on Room 161	Does not exist
<b>Pendant Mounted</b>	
Instance on Room 202	Does not exist
Instance on Room 263	Does not exist
<b>Surface Mounted</b>	
Instance on Room 202	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 263	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 202	Does not exist
Instance on Room 263	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 202	Inspected
Instance on Room 263	Inspected
Instance on Room 105	Inspected
Instance on Room 161	Inspected
<b>Pendant Mounted</b>	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 263	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 105	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 161	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	



**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>SCIENCE DEMO ROOM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
<b>Surface Mounted</b>	
Instance on Room 202	Does not exist
Instance on Room 263	Does not exist
Instance on Room 105	Does not exist
Instance on Room 161	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 202	Does not exist
Instance on Room 263	Does not exist
Instance on Room 105	Does not exist
Instance on Room 161	Does not exist
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 105	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 202	Does not exist
Instance on Room 263	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 161	Does not exist
<b>Emergency Shut-Off Power</b>	
Instance on Room 105	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 202	Does not exist
Instance on Room 263	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 161	Does not exist
<b>Power Supply</b>	
Instance on Room 105	Inspected
Instance on Room 202	Does not exist
Instance on Room 263	Inspected
Instance on Room 161	Inspected
<b>Instructor Unit</b>	
Instance on Room 263	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 105	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 161	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 263	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 105	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>SCIENCE DEMO ROOM</b>	
<b>Power Supply</b>	
<b>Meter Demonstration Unit</b>	
Instance on Room 161	Does not exist
<b>Projection System</b>	
Instance on Room 105	Does not exist
Instance on Room 202	Does not exist
Instance on Room 263	Does not exist
Instance on Room 161	Does not exist
<b>SCIENCE LAB</b>	
Instance on Room 233	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 402	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 433	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 109/111	Inaccessible
Instance on Room 257	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 305, 311	Inspected
Power Panel?	Yes
Alternative Use	No
<b>Lighting</b>	
Instance on Room 233	Inspected
Instance on Room 402	Inspected
Instance on Room 433	Inspected
Instance on Room 257	Inspected
Instance on Room 305, 311	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 233	Does not exist
Instance on Room 402	Does not exist
Instance on Room 433	Does not exist
Instance on Room 257	Does not exist
Instance on Room 305, 311	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 233	Does not exist
Instance on Room 402	Does not exist
Instance on Room 433	Does not exist
Instance on Room 257	Does not exist
Instance on Room 305, 311	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 233	Does not exist
Instance on Room 402	Does not exist
Instance on Room 433	Does not exist
Instance on Room 257	Does not exist
Instance on Room 305, 311	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 233	Inspected
Instance on Room 402	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>SCIENCE LAB</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
Instance on Room 433	Inspected
Instance on Room 257	Inspected
Instance on Room 305, 311	Inspected
<b>Pendant Mounted</b>	
Instance on Room 233	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 402	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 433	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 257	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 305, 311	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 233	Does not exist
Instance on Room 402	Does not exist
Instance on Room 433	Does not exist
Instance on Room 257	Does not exist
Instance on Room 305, 311	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 233	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 402	Does not exist
Instance on Room 433	Does not exist
Instance on Room 257	Does not exist
Instance on Room 305, 311	Does not exist
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 233	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 402	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 433	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 257	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 305, 311	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Emergency Shut-Off Power</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>SCIENCE LAB</b>	
<b>Emergency Shut-Off Power</b>	
Instance on Room 233	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 402	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 433	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 257	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 305, 311	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Power Supply</b>	
Instance on Room 233	Inspected
Instance on Room 402	Inspected
Instance on Room 433	Inspected
Instance on Room 257	Inspected
Instance on Room 305, 311	Inspected
<b>Instructor Unit</b>	
Instance on Room 233	Does not exist
Instance on Room 402	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 433	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 257	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 305, 311	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 233	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 402	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 433	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 257	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 305, 311	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>SCIENCE LAB</b>	
<b>Power Supply</b>	
<b>Student Unit</b>	
Instance on Room 233	Does not exist
Instance on Room 402	Does not exist
Instance on Room 433	Does not exist
Instance on Room 257	Does not exist
Instance on Room 305, 311	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on Room 233	Does not exist
Instance on Room 402	Does not exist
Instance on Room 433	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 257	Does not exist
Instance on Room 305, 311	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>SCIENCE PREP ROOM</b>	Inspected
Instance on Room 231	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 402A	Inspected
Power Panel?	No
Alternative Use	Yes
Instance on Room 113	Inaccessible
Instance on Room 257A, 309	Inspected
Power Panel?	No
Alternative Use	No
<b>Lighting</b>	
Instance on Room 231	Inspected
Instance on Room 402A	Inspected
Instance on Room 257A, 309	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 231	Does not exist
Instance on Room 402A	Does not exist
Instance on Room 257A, 309	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 231	Does not exist
Instance on Room 402A	Does not exist
Instance on Room 257A, 309	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 231	Does not exist
Instance on Room 402A	Does not exist
Instance on Room 257A, 309	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 231	Inspected
Instance on Room 402A	Inspected
Instance on Room 257A, 309	Inspected
<b>Pendant Mounted</b>	
Instance on Room 231	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>SCIENCE PREP ROOM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
<b>Pendant Mounted</b>	
Instance on Room 402A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 257A, 309	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 231	Does not exist
Instance on Room 402A	Does not exist
Instance on Room 257A, 309	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 231	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 402A	Does not exist
Instance on Room 257A, 309	Does not exist
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 231	Does not exist
Instance on Room 402A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 257A, 309	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Emergency Shut-Off Power</b>	
Instance on Room 231	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 402A	Does not exist
Instance on Room 257A, 309	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Power Supply</b>	
Instance on Room 231	Does not exist
Instance on Room 402A	Does not exist
Instance on Room 257A, 309	Does not exist
<b>SWIMMING POOL</b>	
	Does not exist
<b>TOILET ROOM - STAFF</b>	
	Inspected
<b>Lighting</b>	
	Inspected
<b>Lighting Fixture - Fluorescent</b>	
	Does not exist
<b>Lighting Fixture - HID</b>	
	Does not exist
<b>Lighting Fixture - Incandescent</b>	
	Does not exist
<b>Lighting Fixture - LED</b>	
	Inspected
<b>Pendant Mounted</b>	
	Does not exist
<b>Surface Mounted</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Condition	2- Between Good and Fair

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>TOILET ROOM - STAFF</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
<b>Recessed Mounted</b>	
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	4- Between Fair and Poor
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	32
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	35672671K
<b>Non Battery Pack</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Auditorium, Room B2, Boiler Room Crawl Space
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EXIT/EMERGENCY LIGHT</b>	Inspected
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

<b>Question</b>	<b>Response</b>
<b>EXIT/EMERGENCY LIGHT</b>	
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>Bell/Horn</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Manual Pull Station</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Area Smoke Detector</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>CO Detector</b>	Does not exist
<b>Heat Detector</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Elevator Recall</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Magnetic Door Holder/Contactor</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fused Cutout Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Digital Communicator</b>	Does not exist
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Main Entrance Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST 3
EquipmentId	Fire Alarm Control Panel
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>Sub-Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	1- Good



**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>Sub-Panel</b>	
<b>Bell At Panel</b>	
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Auditorium - Stage
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST 3
EquipmentId	Emergency Control Board
Installation Year	2019
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>Remote Annunciator</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Printer</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Punch Register</b>	Does not exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Tamper Flow Switch/Chain</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>INTERCOM SYSTEM</b>	Inspected
<b>Elevator</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Holding Area</b>	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>MOTOR CONTROLLER</b>	Inspected
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

<b>Question</b>	<b>Response</b>
<b>MOTOR CONTROLLER</b>	
<b>Variable Frequency Drive</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>PANEL BOARD</b>	
	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Fused Toggle Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B45A
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
	Inspected
Instance	Room 133
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	QSC Model ISA 500Ti
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>SECURITY</b>	
	Inspected
<b>IPDVS/CCTV System</b>	Inspected
Condition	2- Between Good and Fair
Installation Year	2019
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Intrusion Alarm System</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	Room 183
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128B
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>SECURITY</b>	
<b>Intrusion Alarm System</b>	
<b>Remote Annunciator</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting - Security</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	
Instance	Inspected
Instance	Electrical Room B45A
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Electrotech
EquipmentId	Service Disconnect
Capacity/Size Quantity	2000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room B45B
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	Main Service Switch Disconnect
Capacity/Size Quantity	2500
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1990
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>SWITCHBOARD</b>	
Number of Spares	Inspected
Number of Spares	2
<b>Fused Disconnect Switch Type</b>	
Instance	Inspected
Instance	Room B45A
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Electrotech
EquipmentId	N/A
Capacity/Size Quantity	2000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Room B45B
Instance Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X410**

Question	Response
<b>SWITCHBOARD</b>	
<b>Fused Disconnect Switch Type</b>	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	N/A
Capacity/Size Quantity	2500
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	5
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1990
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Does not exist
<b>TELEPHONE SYSTEM</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>TRANSFORMER</b>	Inspected
Instance	Electrical Room B45B
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	EATON
EquipmentId	N/A
Capacity/Size Quantity	75
Capacity/Size UOM	kVA
Source of Capacity/Size	Nameplate
Installation Year	1997
Source of Installation Year	Documented
Deficiency	No deficiencies recorded