

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X444

Asset:	PRE-K CENTER @ 2510 MARION AVENUE - BRONX, 2510 MARION AVENUE, BRONX, NY, 10458		
Inspection Id	Inspection Type	Time In	Last Edited
947	ELECTRICAL	2023-11-14 08:52AM	2023-11-14 12:50PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: All Electrical Systems and Components (Except Theatre Lighting) Years: 2017
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
Yes	Water Leaks onto Electrical Equipment	N/A	Fire Alarm System Strobe	Room 106E	Ralph Pina	Fireman	No Photo Taken

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
CAFETERIA	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
COMPUTER LAB	Does not exist
GYMNASIUM	Does not exist
KITCHEN	Inspected
Instance on 1st Floor	Inspected
Lighting	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X444

Question	Response
KITCHEN	
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Does not exist
LOCKER ROOM	Does not exist
MULTIPURPOSE ROOM	Inspected
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Installation Year	2017
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not exist
Theater Lighting System	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Does not exist
Theater Lighting	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X444

Question	Response
MULTIPURPOSE ROOM	
Theater Lighting System	
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	44
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not exist
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X444

Question	Response
EXIT LIGHT	
Non Battery Pack	Does not exist
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
Bell/Horn	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Heat Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Elevator Recall	Does not exist
Magnetic Door Holder/Contactor	Does not exist
Fused Cutout Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Main Panel	Does not exist
Sub-Panel	Does not exist
Remote Annunciator	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	Does not exist
Sprinkler Flow/Air Pressure Switch	Does not exist
Tamper Flow Switch/Chain	Does not exist
GROUNDING SYSTEM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X444

Question	Response
LAN	
Local Distribution Frame (I/LDF)	
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not exist
MOTOR CONTROLLER	Inspected
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Variable Frequency Drive	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Does not exist
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	General Office - Room 109
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland TC2100
Installation Year	2017
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SECURITY	Inspected
IPDVS/CCTV System	Inspected
Condition	2- Between Good and Fair
Installation Year	2017
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	Custodian's Office - Room 308
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 128BPT
Installation Year	2017
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X444

Question	Response
SECURITY	
Intrusion Alarm System	
Siren/Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting - Security	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	Inspected
Instance	Electrical Room 110
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Electric Switchboard
EquipmentId	Service Disconnect Switch
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2017
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	Inspected
Number of Spares	6
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room 110
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Electric Switchboard
EquipmentId	Main Distribution Switchboard
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2017
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not exist