

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Asset: BRONX HS OF SCIENCE - BRONX, 75 W 205 STREET, BRONX, NY, 10468

Inspection Id	Inspection Type	Time In	Last Edited
3748	ELECTRICAL	2024-03-06 09:42AM	2024-03-29 10:05AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	<p>Systems: Intrusion Alarm System (Infrared Sensors) Years: 2023, 2010</p> <p>Systems: Projector in Science Lab and Demo Except(Science Lab Room 231), Science Lab 333, LAN Years: 2023</p> <p>Systems: Security Lighting, IPDVS/CCTV System, Auditorium - House Retrofitted LED Lighting, Cafeteria - Lighting, Science Lab - Room 231(LED Lighting) Years: 2022</p> <p>Systems: Partial Molded Case Circuit Breaker Panel Boards Years: 2020, 2011, 2008, 1999</p> <p>Systems: Fire Alarm System (CO Detectors), Exit/Emergency Lights, Partial Motor Starters Years: 2020</p> <p>Systems: LED Lighting, Most Exit Lights (Battery Pack) Years: 2018</p> <p>Systems: Fire Alarm System, Science Lab Room 325 (Fluorescent Lighting) Years: 2015</p> <p>Systems: Student Bathrooms (Fluorescent Lighting) Years: 2014, 1999</p> <p>Systems: Public Address System, Local Sound System, Science Lab - Room 233 (Pendant Fluorescent Lighting, Emergency Power Shut-Off Valve), Science Lab - Room 331 (Pendant Fluorescent Lighting) Years: 2014</p> <p>Systems: Science Lab - Rooms: 225, 229, Auditorium (Theater Lighting System, Surface Fluorescent Lighting) Years: 2011</p> <p>Systems: Science Lab - Rooms: 123, 125 (Except Emergency Gas Shut-Off Valve), Auditorium (Projector System), Intercom System (Elevator) Years: 2009</p> <p>Systems: Fused Disconnect Switch Type Panel Boards Years: 2007</p> <p>Systems: Intrusion Alarm System Years: 2004</p> <p>Systems: Interior Fluorescent Lighting, Science Rooms (Incandescent Lighting), Science Prep Room: 337P (Retrofitted Recessed Fluorescent Lighting), Kitchen (Retrofitted Recessed Fluorescent Lighting), Auditorium (Pendant Fluorescent Lighting) Years: 1999</p> <p>Systems: Emergency Light/Exit Panel Years: 1994</p> <p>Type of Service Below Ground</p> <p>Does Interactive Whiteboard (IWB) Exist? Yes</p> <p>Water Penetration In Electrical Room? No</p>

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	Yes
Are dedicated intercoms available in all of these spaces for use during a fire?	Yes
Are all dedicated intercoms operational?	Yes

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	Intercom - Not Connected to Remote Monitoring Station	N/A	Intercom System - Elevator	Main Entrance Lobby , ID# 2P3244	Debbie Crespo	Fireman	No Photo Taken
Yes	Emergency Gas Shut-Off Valve - Not Operational	N/A	Emergency Gas Shut-Off Valve	Science Lab - Room 225	Debbie Crespo	Fireman	No Photo Taken
Yes	Water Leaks onto Electrical Equipment	Leak from Ceiling	Lighting Fixture	Boys Locker Room	Debbie Crespo	Fireman	No Photo Taken
Yes	Emergency Shut-Off Power - Not Operational	N/A	Emergency Shut-Off Power	Science Lab - Room 225	Debbie Crespo	Fireman	No Photo Taken

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance on 1st Floor	Inspected
House Lighting	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2014

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
AUDITORIUM	
Local Sound System	
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance on Basement	Inspected
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Lighting Fixture - LED	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Does not exist
Local Sound System	
Instance on Basement	Inspected
Instance Condition	4- Between Fair and Poor
Installation Year	2014
Source of Installation Year	Documented
Deficiency	SYSTEM DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR SYSTEM
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Projection System	
Instance on Basement	Does not exist
Theater Lighting System	
Instance on Basement	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
CAFETERIA	
Theater Lighting System	
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - LED	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
COMPUTER LAB	
Instance on Room 011	Inspected
Power Panel?	Yes
Instance on Room 007, 109, 214, 319, 321	Inspected
Power Panel?	Yes
Lighting	
Instance on Room 011	Inspected
Instance on Room 007, 109, 214, 319, 321	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 011	Inspected
Instance on Room 007, 109, 214, 319, 321	Inspected
Pendant Mounted	
Instance on Room 011	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 007, 109, 214, 319, 321	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 011	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 007, 109, 214, 319, 321	Does not exist
Recessed Mounted	
Instance on Room 011	Does not exist
Instance on Room 007, 109, 214, 319, 321	Does not exist
Lighting Fixture - HID	
Instance on Room 011	Does not exist
Instance on Room 007, 109, 214, 319, 321	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 011	Does not exist
Instance on Room 007, 109, 214, 319, 321	Does not exist
Lighting Fixture - LED	
Instance on Room 011	Does not exist
Instance on Room 007, 109, 214, 319, 321	Does not exist
Raceway With Receptacles	
Instance on Room 011	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 007, 109, 214, 319, 321	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
COMPUTER LAB	
Raceway With Receptacles	
Deficiency	No deficiencies recorded
GYMNASIUM	
	Inspected
Instance on 1st Floor - East	Inspected
Instance on 1st Floor - West	Inspected
Lighting	
Instance on 1st Floor - East	Inspected
Instance on 1st Floor - West	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor - East	Does not exist
Instance on 1st Floor - West	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor - East	Does not exist
Instance on 1st Floor - West	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor - East	Does not exist
Instance on 1st Floor - West	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor - East	Inspected
Instance on 1st Floor - West	Inspected
Pendant Mounted	
Instance on 1st Floor - East	Does not exist
Instance on 1st Floor - West	Does not exist
Surface Mounted	
Instance on 1st Floor - East	Does not exist
Instance on 1st Floor - West	Does not exist
Recessed Mounted	
Instance on 1st Floor - East	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - West	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Local Sound System	
Instance on 1st Floor - East	Inspected
Instance Condition	3- Fair
Installation Year	2014
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance on 1st Floor - West	Inspected
Instance Condition	3- Fair
Installation Year	2014
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor - East	Does not exist
Instance on 1st Floor - West	Does not exist
Scoreboard	
Instance on 1st Floor - East	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - West	Does not exist
Theater Lighting System	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
GYMNASIUM	
Theater Lighting System	
Instance on 1st Floor - East	Does not exist
Instance on 1st Floor - West	Does not exist
KITCHEN	
Instance on Basement	Inspected
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Basement	Does not exist
Lighting Fixture - LED	
Instance on Basement	Does not exist
LIBRARY	
Instance on 1st Floor	Inspected
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
LIBRARY	
Lighting	
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist
Raceway With Receptacles	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not exist
LOCKER ROOM	
	Inspected
Instance on Basement - Boys	Inspected
Alternative Use	No
Instance on Basement - Girls	Inaccessible
Lighting	
Instance on Basement - Boys	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement - Boys	Inspected
Pendant Mounted	
Instance on Basement - Boys	Does not exist
Surface Mounted	
Instance on Basement - Boys	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Basement - Boys	Does not exist
Lighting Fixture - HID	
Instance on Basement - Boys	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement - Boys	Inspected
Pendant Mounted	
Instance on Basement - Boys	Does not exist
Surface Mounted	
Instance on Basement - Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Basement - Boys	Does not exist
Lighting Fixture - LED	
Instance on Basement - Boys	Does not exist
MULTIPURPOSE ROOM	
	Does not exist
SCIENCE DEMO ROOM	
	Inspected
Instance on Room 124, 227	Inspected
Power Panel?	Yes

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SCIENCE DEMO ROOM	
Alternative Use	No
Instance on Room 126, 128, 130, 230	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 224, 226, 228, 330, 324, 326, 328	Inspected
Power Panel?	No
Alternative Use	No
Lighting	
Instance on Room 124, 227	Inspected
Instance on Room 126, 128, 130, 230	Inspected
Instance on Room 224, 226, 228, 330, 324, 326, 328	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 124, 227	Inspected
Instance on Room 126, 128, 130, 230	Inspected
Instance on Room 224, 226, 228, 330, 324, 326, 328	Inspected
Pendant Mounted	
Instance on Room 124, 227	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 126, 128, 130, 230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 224, 226, 228, 330, 324, 326, 328	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 124, 227	Does not exist
Instance on Room 126, 128, 130, 230	Does not exist
Instance on Room 224, 226, 228, 330, 324, 326, 328	Does not exist
Recessed Mounted	
Instance on Room 124, 227	Does not exist
Instance on Room 126, 128, 130, 230	Does not exist
Instance on Room 224, 226, 228, 330, 324, 326, 328	Does not exist
Lighting Fixture - HID	
Instance on Room 124, 227	Does not exist
Instance on Room 126, 128, 130, 230	Does not exist
Instance on Room 224, 226, 228, 330, 324, 326, 328	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 124, 227	Does not exist
Instance on Room 126, 128, 130, 230	Inspected
Instance on Room 224, 226, 228, 330, 324, 326, 328	Inspected
Pendant Mounted	
Instance on Room 126, 128, 130, 230	Does not exist
Instance on Room 224, 226, 228, 330, 324, 326, 328	Does not exist
Surface Mounted	
Instance on Room 126, 128, 130, 230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 224, 226, 228, 330, 324, 326, 328	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Lighting Fixture - Incandescent	
Recessed Mounted	
Instance on Room 126, 128, 130, 230	Does not exist
Instance on Room 224, 226, 228, 330, 324, 326, 328	Does not exist
Lighting Fixture - LED	
Instance on Room 124, 227	Does not exist
Instance on Room 126, 128, 130, 230	Does not exist
Instance on Room 224, 226, 228, 330, 324, 326, 328	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Room 124, 227	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 126, 128, 130, 230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 224, 226, 228, 330, 324, 326, 328	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 124, 227	Does not exist
Instance on Room 126, 128, 130, 230	Does not exist
Instance on Room 224, 226, 228, 330, 324, 326, 328	Does not exist
Power Supply	
Instance on Room 124, 227	Inspected
Instance on Room 126, 128, 130, 230	Inspected
Instance on Room 224, 226, 228, 330, 324, 326, 328	Inspected
Instructor Unit	
Instance on Room 124, 227	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 126, 128, 130, 230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 224, 226, 228, 330, 324, 326, 328	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 124, 227	Does not exist
Instance on Room 126, 128, 130, 230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 224, 226, 228, 330, 324, 326, 328	Does not exist
Projection System	
Instance on Room 124, 227	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 126, 128, 130, 230	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 224, 226, 228, 330, 324, 326, 328	Inspected
Instance Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SCIENCE DEMO ROOM	
Projection System	
Deficiency	No deficiencies recorded
SCIENCE LAB	
Instance on Room 333	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 329	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 331	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 327	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 325	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 323	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 233	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 231	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 229	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 225	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 223	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 123, 125	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 127	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 129	Inspected
Power Panel?	No
Alternative Use	No
Lighting	
Instance on Room 333	Inspected
Instance on Room 329	Inspected
Instance on Room 331	Inspected
Instance on Room 327	Inspected
Instance on Room 325	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SCIENCE LAB	
Lighting	
Instance on Room 323	Inspected
Instance on Room 233	Inspected
Instance on Room 231	Inspected
Instance on Room 229	Inspected
Instance on Room 225	Inspected
Instance on Room 223	Inspected
Instance on Room 123, 125	Inspected
Instance on Room 127	Inspected
Instance on Room 129	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 333	Inspected
Instance on Room 331	Inspected
Instance on Room 329	Inspected
Instance on Room 327	Inspected
Instance on Room 325	Inspected
Instance on Room 323	Inspected
Instance on Room 233	Inspected
Instance on Room 231	Does not exist
Instance on Room 229	Inspected
Instance on Room 225	Inspected
Instance on Room 223	Inspected
Instance on Room 123, 125	Inspected
Instance on Room 127	Inspected
Instance on Room 129	Inspected
Pendant Mounted	
Instance on Room 333	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 331	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 329	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 327	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 325	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 323	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 233	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 229	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 225	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Deficiency	No deficiencies recorded
Instance on Room 223	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 123, 125	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 127	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 129	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 333	Does not exist
Instance on Room 331	Does not exist
Instance on Room 329	Does not exist
Instance on Room 327	Does not exist
Instance on Room 325	Does not exist
Instance on Room 323	Does not exist
Instance on Room 233	Does not exist
Instance on Room 229	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 225	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 223	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 123, 125	Does not exist
Instance on Room 127	Does not exist
Instance on Room 129	Does not exist
Recessed Mounted	
Instance on Room 333	Does not exist
Instance on Room 331	Does not exist
Instance on Room 329	Does not exist
Instance on Room 327	Does not exist
Instance on Room 325	Does not exist
Instance on Room 323	Does not exist
Instance on Room 233	Does not exist
Instance on Room 229	Does not exist
Instance on Room 225	Does not exist
Instance on Room 223	Does not exist
Instance on Room 123, 125	Does not exist
Instance on Room 127	Does not exist
Instance on Room 129	Does not exist
Lighting Fixture - HID	
Instance on Room 333	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - HID	
Instance on Room 331	Does not exist
Instance on Room 329	Does not exist
Instance on Room 327	Does not exist
Instance on Room 325	Does not exist
Instance on Room 323	Does not exist
Instance on Room 233	Does not exist
Instance on Room 231	Does not exist
Instance on Room 229	Does not exist
Instance on Room 225	Does not exist
Instance on Room 223	Does not exist
Instance on Room 123, 125	Does not exist
Instance on Room 127	Does not exist
Instance on Room 129	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 333	Does not exist
Instance on Room 331	Does not exist
Instance on Room 329	Does not exist
Instance on Room 327	Does not exist
Instance on Room 325	Does not exist
Instance on Room 323	Does not exist
Instance on Room 233	Does not exist
Instance on Room 231	Does not exist
Instance on Room 229	Does not exist
Instance on Room 225	Does not exist
Instance on Room 223	Does not exist
Instance on Room 123, 125	Does not exist
Instance on Room 127	Inspected
Instance on Room 129	Inspected
Pendant Mounted	
Instance on Room 127	Does not exist
Instance on Room 129	Does not exist
Surface Mounted	
Instance on Room 127	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 129	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 127	Does not exist
Instance on Room 129	Does not exist
Lighting Fixture - LED	
Instance on Room 333	Does not exist
Instance on Room 331	Does not exist
Instance on Room 329	Does not exist
Instance on Room 327	Does not exist
Instance on Room 325	Does not exist
Instance on Room 323	Does not exist
Instance on Room 233	Does not exist
Instance on Room 231	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X445

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - LED	
Instance on Room 229	Does not exist
Instance on Room 225	Does not exist
Instance on Room 223	Does not exist
Instance on Room 123, 125	Does not exist
Instance on Room 127	Does not exist
Instance on Room 129	Does not exist
Pendant Mounted	
Instance on Room 231	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 231	Does not exist
Recessed Mounted	
Instance on Room 231	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Room 333	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 329	Does not exist
Instance on Room 331	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 327	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 325	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 323	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 233	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 231	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 229	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 225	Inspected
Instance Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Instance on Room 223	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SCIENCE LAB	
Emergency Gas Shut-Off Valve	
Deficiency	No deficiencies recorded
Instance on Room 123, 125	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 127	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 129	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 333	Does not exist
Instance on Room 329	Does not exist
Instance on Room 331	Does not exist
Instance on Room 327	Does not exist
Instance on Room 325	Does not exist
Instance on Room 323	Does not exist
Instance on Room 233	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 231	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 229	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 225	Inspected
Instance Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Instance on Room 223	Does not exist
Instance on Room 123, 125	Does not exist
Instance on Room 127	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 129	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Power Supply	
Instance on Room 333	Does not exist
Instance on Room 329	Does not exist
Instance on Room 331	Does not exist
Instance on Room 327	Does not exist
Instance on Room 325	Does not exist
Instance on Room 323	Inspected
Instance on Room 233	Does not exist
Instance on Room 231	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SCIENCE LAB	
Power Supply	
Instance on Room 229	Inspected
Instance on Room 225	Inspected
Instance on Room 223	Inspected
Instance on Room 123, 125	Inspected
Instance on Room 127	Inspected
Instance on Room 129	Inspected
Instructor Unit	
Instance on Room 323	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 229	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 225	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 223	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 123, 125	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 127	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 129	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 323	Does not exist
Instance on Room 229	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 225	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 223	Does not exist
Instance on Room 123, 125	Does not exist
Instance on Room 127	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 129	Does not exist
Student Unit	
Instance on Room 323	Does not exist
Instance on Room 229	Does not exist
Instance on Room 225	Does not exist
Instance on Room 223	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 123, 125	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SCIENCE LAB	
Power Supply	
Student Unit	
Deficiency	No deficiencies recorded
Instance on Room 127	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 129	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Room 333	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 329	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 331	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 327	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 325	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 323	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 233	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 231	Does not exist
Instance on Room 229	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 225	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 223	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 123, 125	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 127	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 129	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCIENCE PREP ROOM	
Instance on Room 338	Inaccessible

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SCIENCE PREP ROOM	
Instance on Room 337P	Inspected
Power Panel?	No
Alternative Use	Yes
Instance on Room 327P	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 323P	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 233A	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 227P	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 223P	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 127P	Inspected
Power Panel?	Yes
Alternative Use	No
Lighting	
Instance on Room 337P	Inspected
Instance on Room 327P	Inspected
Instance on Room 323P	Inspected
Instance on Room 233A	Inspected
Instance on Room 227P	Inspected
Instance on Room 223P	Inspected
Instance on Room 127P	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 337P	Inspected
Instance on Room 327P	Inspected
Instance on Room 323P	Inspected
Instance on Room 233A	Inspected
Instance on Room 227P	Inspected
Instance on Room 223P	Inspected
Instance on Room 127P	Inspected
Pendant Mounted	
Instance on Room 337P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 327P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 323P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 233A	Does not exist
Instance on Room 227P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 223P	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SCIENCE PREP ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 127P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 337P	Does not exist
Instance on Room 327P	Does not exist
Instance on Room 323P	Does not exist
Instance on Room 233A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 227P	Does not exist
Instance on Room 223P	Does not exist
Instance on Room 127P	Does not exist
Recessed Mounted	
Instance on Room 337P	Does not exist
Instance on Room 327P	Does not exist
Instance on Room 323P	Does not exist
Instance on Room 233A	Does not exist
Instance on Room 227P	Does not exist
Instance on Room 223P	Does not exist
Instance on Room 127P	Does not exist
Lighting Fixture - HID	
Instance on Room 337P	Does not exist
Instance on Room 327P	Does not exist
Instance on Room 323P	Does not exist
Instance on Room 233A	Does not exist
Instance on Room 227P	Does not exist
Instance on Room 223P	Does not exist
Instance on Room 127P	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 337P	Does not exist
Instance on Room 327P	Does not exist
Instance on Room 323P	Inspected
Instance on Room 233A	Does not exist
Instance on Room 227P	Does not exist
Instance on Room 223P	Inspected
Instance on Room 127P	Inspected
Pendant Mounted	
Instance on Room 323P	Does not exist
Instance on Room 223P	Does not exist
Instance on Room 127P	Does not exist
Surface Mounted	
Instance on Room 323P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 223P	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SCIENCE PREP ROOM	
Lighting	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency	No deficiencies recorded
Instance on Room 127P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 323P	Does not exist
Instance on Room 223P	Does not exist
Instance on Room 127P	Does not exist
Lighting Fixture - LED	
Instance on Room 337P	Does not exist
Instance on Room 327P	Does not exist
Instance on Room 323P	Does not exist
Instance on Room 233A	Does not exist
Instance on Room 227P	Does not exist
Instance on Room 223P	Does not exist
Instance on Room 127P	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Room 337P	Does not exist
Instance on Room 327P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 323P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 233A	Does not exist
Instance on Room 227P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 223P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 127P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 337P	Does not exist
Instance on Room 327P	Does not exist
Instance on Room 323P	Does not exist
Instance on Room 233A	Does not exist
Instance on Room 227P	Does not exist
Instance on Room 223P	Does not exist
Instance on Room 127P	Does not exist
Power Supply	
Instance on Room 337P	Does not exist
Instance on Room 327P	Does not exist
Instance on Room 323P	Does not exist
Instance on Room 233A	Does not exist
Instance on Room 227P	Does not exist
Instance on Room 223P	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SCIENCE PREP ROOM	
Power Supply	
Instance on Room 127P	Inspected
Instructor Unit	
Instance on Room 223P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 127P	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
TOILET ROOM - STUDENT	
Lighting	
Lighting Fixture - LED	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	4- Between Fair and Poor
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	30
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Kitchen Exit
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EXIT/EMERGENCY LIGHT	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected
Bell/Horn	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
FIRE ALARM SYSTEM	
Fan Shutdown Control	
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Heat Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Does not exist
Fused Cutout Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Main Panel	Inspected
Bell At Panel	Does not exist
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST3X
EquipmentId	Fire Alarm Control Panel
Installation Year	2015
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
Sub-Panel	Inspected
Bell At Panel	Does not exist
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Auditorium
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	3X-SFS1
EquipmentId	N/A
Installation Year	2015
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
Remote Annunciator	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
FIRE ALARM SYSTEM	
Remote Annunciator	
Panel	
Deficiency	No deficiencies recorded
Printer	
Condition	Inspected
Deficiency	2- Between Good and Fair
Punch Register	
Deficiency	No deficiencies recorded
Sprinkler Flow/Air Pressure Switch	
Condition	Does not exist
Deficiency	Inspected
Tamper Flow Switch/Chain	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	Inspected
Deficiency	3- Fair
INTERCOM SYSTEM	
Elevator	
Condition	Inspected
Deficiency	3- Fair
Deficiency Location/Instance	NOT CONNECTED TO REMOTE MONITORING STATION
Deficiency Quantity	Main Entrance Lobby, ID# 2P3244
Quantity Uom	1
Potential Action	EACH
Urgency of Action	INSTALL CONNECTION
Purpose of Action	PRIORITY 5
Violations	LEVEL 6
Holding Area	
Condition	No violations recorded
LAN	
Local Distribution Frame (I/LDF)	
Condition	Does not exist
Deficiency	Inspected
Main Equipment Rack (MDF)	
Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	
MOTOR CONTROLLER	
MOTOR CONTROL CENTER	
MOTOR STARTER/CONTACTOR	
Condition	Inspected
Deficiency	3- Fair
Variable Frequency Drive	
Condition	No deficiencies recorded
Deficiency	Inspected
PANEL BOARD	
Fused Disconnect Switch Type	
Condition	Inspected
Deficiency	2- Between Good and Fair
Fused Knife Switch Type	
Condition	No deficiencies recorded
Fused Toggle Switch Type	
Condition	Does not exist
Deficiency	Inspected
Deficiency Location/Instance	3- Fair
	PANEL BOARD BEYOND USEFUL LIFE
	Boiler Room, Electrical Meter Room 099

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
PANEL BOARD	
Fused Toggle Switch Type	
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Molded Case Circuit Breaker Type	
Condition	Inspected
Deficiency	3- Fair
Deficiency Location/Instance	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Quantity	Throughout the Building
Quantity Uom	24
Potential Action	EACH
Urgency of Action	REPLACE-UPGRADE
Purpose of Action	PRIORITY 1
Violations	LEVEL 2
	No violations recorded
PUBLIC ADDRESS SYSTEM	
Instance	Inspected
Instance Condition	Sound Control Room 219
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Model	EACH
Installation Year	Bogen Quantum Multicom IP
Source of Installation Year	2014
Deficiency	Documented
	No deficiencies recorded
SECURITY	
IPDVS/CCTV System	
Condition	Inspected
Installation Year	1- Good
Source of Installation Year	2022
Deficiency	Documented
	No deficiencies recorded
Intrusion Alarm System	
Central Control Panel	
Instance	Inspected
Instance Condition	Inspected
Instance Quantity	Custodian's Office - Room 115
Instance Quantity Uom	3- Fair
Model	1
Installation Year	EACH
Source of Installation Year	Vista - 128B
Deficiency	2004
	Documented
	No deficiencies recorded
Infrared Sensor	
Condition	Inspected
Deficiency	3- Fair
	No deficiencies recorded
Panic Switch	
Condition	Inspected
Deficiency	3- Fair
	No deficiencies recorded
Remote Annunciator	
Condition	Inspected
Deficiency	3- Fair
	No deficiencies recorded
Siren/Strobe	
Condition	Inspected
	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SECURITY	
Intrusion Alarm System	
Siren/Strobe	
Deficiency	No deficiencies recorded
Lighting - Security	
Condition	Inspected
Deficiency	1- Good
SERVICE SWITCH	
Instance	Inspected
Instance Condition	Electrical Meter Room 099
Instance Quantity	3- Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	Federal Pacific Electric
Capacity/Size Quantity	A
Capacity/Size UOM	3000
Source of Capacity/Size	Amps
Installation Year	Nameplate
Source of Installation Year	1959
Deficiency	Documented
Deficiency Location/Instance	BEYOND USEFUL LIFE
Deficiency Quantity	Electrical Meter Room 099
Quantity Uom	1
Potential Action	EACH
Urgency of Action	REPLACE
Purpose of Action	PRIORITY 1
Violations	LEVEL 2
Instance	No violations recorded
Instance Condition	Electrical Meter Room 099
Instance Quantity	3- Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	Federal Pacific Electric
Capacity/Size Quantity	B
Capacity/Size UOM	3000
Source of Capacity/Size	Amps
Installation Year	Nameplate
Source of Installation Year	1959
Deficiency	Documented
Deficiency Location/Instance	BEYOND USEFUL LIFE
Deficiency Quantity	Electrical Meter Room 099
Quantity Uom	1
Potential Action	EACH
Urgency of Action	REPLACE
Purpose of Action	PRIORITY 1
Violations	LEVEL 2
Instance	No violations recorded
Instance Condition	Electrical Meter Room 099
Instance Quantity	3- Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	Federal Pacific Electric
Capacity/Size Quantity	Kit Panel
Capacity/Size UOM	400
Source of Capacity/Size	Amps
Installation Year	Nameplate
Source of Installation Year	1959

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X445

Question	Response
SERVICE SWITCH	
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Meter Room 099
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Meter Room 099
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific Electric
EquipmentId	Oil Burner Sec A
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Inspector Estimate
Installation Year	1959
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Meter Room 099
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Meter Room 099
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific Electric
EquipmentId	Oil Burner Sec B
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Inspector Estimate
Installation Year	1959
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Meter Room 099
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWITCHBOARD	Inspected
Number of Spares	0
Fused Disconnect Switch Type	Inspected
Instance	Electrical Meter Room 099
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific Electric

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X445

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
EquipmentId	Sect A
Capacity/Size Quantity	3000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1959
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Meter Room 099
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Meter Room 099
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific Electric
EquipmentId	Sect B
Capacity/Size Quantity	3000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1959
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Meter Room 099
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not exist