

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X460

Asset: HS OF LAW, GOV'T & JUSTICE - BRONX, 244 EAST 163 STREET, BRONX, NY, 10451

Inspection Id	Inspection Type	Time In	Last Edited
5068	ELECTRICAL	2024-04-30 09:14AM	2024-05-29 12:37PM






Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: IPDVS/CCTV System Years: 2022 Systems: Telephone System/LAN Years: 2015 Systems: Emergency Generator Battery Charger Years: 2010 Systems: All Other Electrical Systems/Components Years: 2003
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	Yes

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	Yes
Are dedicated intercoms available in all of these spaces for use during a fire?	Yes
Are all dedicated intercoms operational?	Yes



Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	Fire Alarm System - Defective	Trouble mode warning on the panel's screen.	Fire Alarm System	Main Entrance Lobby	Brian Thomas	Custodian	
Yes	Fire Alarm System - Components Not Operational	Four out of Eight Magnetic Door Holders are Not Operational.	Fire Alarm System - Magnetic Door Holder/Contactor	1st Floor Corridors near Rooms (128, 139)	Brian Thomas	Custodian	
Yes	Water Penetration in Electrical Room	N/A	Electrical Equipment	Electrical Room B47, Emergency Distribution Room B49A	Brian Thomas	Custodian	
Yes	Fire Alarm System - Components Missing	Two out of Eight Magnetic Door Holders are Missing.	Fire Alarm System - Magnetic Door Holder/Contactor	Basement Corridor near Room B10	Brian Thomas	Custodian	
Yes	Emergency Generator Components - Not Operational	N/A	Emergency Generator	Emergency Generator Room B45	Brian Thomas	Custodian	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X460

No	Emergency Shut-Off Power - Not Operational	One out of three Emergency Shut-Off Power is not operational.	Emergency Shut-Off Power	Science Prep Room 331	Brian Thomas	Custodian	
Yes	Water Leaks onto Electrical Equipment	Lighting fixtures are affected by Plaza Deck Leak (in Room 447), and Awning Leak in the Main Entrance Vestibule.	Lighting Fixture	Rom 447, Main Entrance Vestibule	Brian Thomas	Custodian	

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
CAFETERIA	Inspected
Instance on Basement - Staff	Inspected
Instance on Basement - Students	Inspected
Lighting	
Instance on Basement - Staff	Under construction
Instance on Basement - Students	Under construction
Local Sound System	
Instance on Basement - Staff	Does not exist
Instance on Basement - Students	Inspected
Instance Condition	5- Poor
Installation Year	2003
Source of Installation Year	Documented
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE SYSTEM
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Projection System	
Instance on Basement - Staff	Does not exist
Instance on Basement - Students	Does not exist
Theater Lighting System	
Instance on Basement - Staff	Does not exist
Instance on Basement - Students	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Under construction
COMPUTER LAB	Inspected
Instance on Rooms 221, 431	Inspected
Power Panel?	Yes
Lighting	
Instance on Rooms 221, 431	Under construction
Raceway With Receptacles	
Instance on Rooms 221, 431	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance on 5th Floor	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X460

Question	Response
GYMNASIUM	
Lighting	
Instance on 5th Floor	Under construction
Local Sound System	
Instance on 5th Floor	Inspected
Instance Condition	5- Poor
Installation Year	2003
Source of Installation Year	Documented
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE SYSTEM
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Projection System	
Instance on 5th Floor	Does not exist
Scoreboard	
Instance on 5th Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 5th Floor	Inspected
Dimming System	
Instance on 5th Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 5th Floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
KITCHEN	
Instance on Basement	Inspected
Lighting	
Instance on Basement	Under construction
LIBRARY	
Instance on Room 233	Inspected
Lighting	
Instance on Room 233	Under construction
Raceway With Receptacles	
Instance on Room 233	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Room 233	Does not exist
LOCKER ROOM	
Instance on Rooms 428 - Girls, 438 - Boys, 539 - Visiting Team, 543 - Visiting Team	Inspected
Alternative Use	No

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X460

Question	Response
LOCKER ROOM	
Lighting	
Instance on Rooms 428 - Girls, 438 - Boys, 539 - Visiting Team, 543 - Visiting Team	Under construction
MULTIPURPOSE ROOM	
	Does not exist
SCIENCE DEMO ROOM	
	Inspected
Instance on Rooms 328, 334, 338	Inspected
Power Panel?	No
Alternative Use	Yes
Lighting	
Instance on Rooms 328, 334, 338	Under construction
Emergency Gas Shut-Off Valve	
Instance on Rooms 328, 334, 338	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Rooms 328, 334, 338	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Power Supply	
Instance on Rooms 328, 334, 338	Inspected
Instructor Unit	
Instance on Rooms 328, 334, 338	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Rooms 328, 334, 338	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Rooms 328, 334, 338	Does not exist
SCIENCE LAB	
	Inspected
Instance on Rooms 325, 327, 333	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 425	Inspected
Power Panel?	Yes
Alternative Use	No
Lighting	
Instance on Rooms 325, 327, 333	Under construction
Instance on Room 425	Under construction
Emergency Gas Shut-Off Valve	
Instance on Rooms 325, 327, 333	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 425	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Rooms 325, 327, 333	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 425	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X460

Question	Response
SCIENCE LAB	
Emergency Shut-Off Power	
Deficiency	No deficiencies recorded
Power Supply	
Instance on Rooms 325, 327, 333	Inspected
Instance on Room 425	Inspected
Instructor Unit	
Instance on Rooms 325, 327, 333	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 425	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Rooms 325, 327, 333	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 425	Does not exist
Student Unit	
Instance on Rooms 325, 327, 333	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 425	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Rooms 325, 327, 333	Does not exist
Instance on Room 425	Does not exist
SCIENCE PREP ROOM	
Instance on Room 331	Inspected
Power Panel?	Yes
Alternative Use	No
Lighting	
Instance on Room 331	Under construction
Emergency Gas Shut-Off Valve	
Instance on Room 331	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 331	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Power Supply	
Instance on Room 331	Inspected
Instructor Unit	
Instance on Room 331	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X460

Question	Response
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Inspected
Lighting	Under construction
TOILET ROOM - STUDENT	Inspected
Lighting	Under construction
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Inspected
Automatic Transfer Switch (ATS)	Inspected
Instance	Water Meter Room B24B
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Firetrol
EquipmentId	Fire Pump Power Transfer Switch
Capacity/Size Quantity	40
Capacity/Size UOM	HP
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Emergency Distribution Room B49A
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Kohler Power Systems
EquipmentId	Fire Alarm Automatic Transfer Switch
Capacity/Size Quantity	30
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Emergency Distribution Room B49A
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Kohler Power Systems
EquipmentId	Transfer Switch
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Battery Charger	Inspected
Instance	Emergency Generator Room B45
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	Regulated Battery Charger
Capacity/Size Quantity	10

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X460

Question	Response
EMERGENCY GENERATOR SET	
Battery Charger	
Capacity/Size UOM	AmpsDC
Capacity/Size 2 Quantity	24
Capacity/Size 2 UOM	VDC
Source of Capacity/Size	Nameplate
Installation Year	2010
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
Emergency Distribution Board	Inspected
Number of Spares	3
Fused Disconnect Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Instance	Emergency Distribution Room B49A
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	EHDP - B
Capacity/Size Quantity	800
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Diesel	Inspected
Instance	Emergency Generator Room B45
Instance Condition	4- Between Fair and Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Kohler Power Systems
EquipmentId	Emergency Generator
Capacity/Size Quantity	375
Capacity/Size UOM	kVA
Capacity/Size 2 Quantity	300
Capacity/Size 2 UOM	kW
Capacity/Size 3 Quantity	451
Capacity/Size 3 UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	GENERATOR NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Natural Gas	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Does not exist
Non Battery Pack	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X460

Question	Response
EMERGENCY LIGHTING	
Non Battery Pack	
Deficiency	No deficiencies recorded
EXIT LIGHT	
	Inspected
Battery Pack	
Condition	3- Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 4
Violations	35672100R
Non Battery Pack	
Condition	Inspected
Deficiency	3- Fair
	No deficiencies recorded
EXIT/EMERGENCY LIGHT	
	Does not exist
FIRE ALARM SYSTEM	
	Inspected
Bell/Horn	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Strobe	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Manual Pull Station	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CO Detector	
	Does not exist
Heat Detector	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Elevator Recall	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	
	Inspected
Condition	4- Between Fair and Poor
Deficiency	CONTACTOR MISSING
Deficiency Location/Instance	Basement Corridor near Room B10
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL CONTACTOR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Deficiency	CONTACTOR NOT OPERATIONAL

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X460

Question	Response
FIRE ALARM SYSTEM	
Magnetic Door Holder/Contactor	
Deficiency Location/Instance	1st Floor Corridors near Rooms (128, 139)
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Fused Cutout Panel	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	
	Inspected
Instance	Water Meter Room B24B
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Ademco
EquipmentId	Fire Alarm Communicator
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Main Panel	
	Inspected
Bell At Panel	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	
	Inspected
Instance	Main Entrance Lobby
Instance Condition	4- Between Fair and Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
Model	MXL
EquipmentId	Fire Alarm Control Panel
Installation Year	2003
Source of Installation Year	Documented
Deficiency	SYSTEM DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR SYSTEM
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Fire Alarm Control Panel (Standard)	
	Does not exist
Sub-Panel	
	Does not exist
Remote Annunciator	
	Inspected
Display Monitor	
	Does not exist
Panel	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Printer	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Punch Register	
	Does not exist
Sprinkler Flow/Air Pressure Switch	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X460

Question	Response
FIRE ALARM SYSTEM	
Sprinkler Flow/Air Pressure Switch	
Condition	3- Fair
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	
Elevator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Holding Area	Does not exist
LAN	
Local Distribution Frame (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	
MOTOR CONTROLLER	
MOTOR CONTROL CENTER	
Instance	Penthouse West Mechanical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Square D
EquipmentId	MCC - 6A
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps
Capacity/Size 2 Quantity	7
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Penthouse East Mechanical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Square D
EquipmentId	MCC - 6B
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps
Capacity/Size 2 Quantity	5
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Air Handler Room B49
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X460

Question	Response
MOTOR CONTROLLER	
MOTOR CONTROL CENTER	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Square D
EquipmentId	MCC - B
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Capacity/Size 2 Quantity	3
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Variable Frequency Drive	Does not exist
PANEL BOARD	
Fused Disconnect Switch Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	
Instance	Sound Control Room 119
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland TC2100
Installation Year	2003
Source of Installation Year	Documented
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SECURITY	
IPDVS/CCTV System	Inspected
Condition	1- Good
Installation Year	2022
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	Custodian's Office - Room 105
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X460

Question	Response
SECURITY	
Intrusion Alarm System	
Central Control Panel	
Model	Vista - 128B
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting - Security	Under construction
SERVICE SWITCH	
Instance	Electrical Room B47
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	Service Switch #1
Capacity/Size Quantity	4000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room B47
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	Service Switch #2
Capacity/Size Quantity	3000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room B47
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	Service Switch #3 Fire Pump
Capacity/Size Quantity	800
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2003

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X460

Question	Response
SERVICE SWITCH	
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	
Number of Spares	Inspected 14
Fused Disconnect Switch Type	
Instance	Inspected Electrical Room B47
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	HDB Section #1, 2, 3
Capacity/Size Quantity	2500
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	3
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Switchboard Mains Size
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room B47
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	MSB - 1, 2, 3, 4
Capacity/Size Quantity	3000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	4
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE SYSTEM	
	Inspected
PBX/Intercom	
Condition	Inspected 2- Between Good and Fair
Deficiency	No deficiencies recorded
Standard	
Condition	Inspected 2- Between Good and Fair
Deficiency	No deficiencies recorded
TRANSFORMER	
Instance	Inspected Electrical Room B47
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Olsun Electric
EquipmentId	Fire Pump Transformer
Capacity/Size Quantity	75
Capacity/Size UOM	kVA
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X460

Question	Response
TRANSFORMER	
Instance	Electrical Room B47
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Olsun Electric
EquipmentId	N/A
Capacity/Size Quantity	1500
Capacity/Size UOM	kVA
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Emergency Distribution Room B49A
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Square D
EquipmentId	XFMR via ELDP-B
Capacity/Size Quantity	150
Capacity/Size UOM	kVA
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded