

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Architectural Inspection

X582

Asset: PRE-K CENTER @ 1434 OGDEN AVENUE - BRONX, 1434 OGDEN AVENUE, BRONX, NY, 10452

Inspection Id	Inspection Type	Time In	Last Edited
3222	ARCHITECTURAL - SENIOR	2024-02-14 08:27AM	2024-03-05 01:40PM
3400	ARCHITECTURAL - ASSOCIATE	2024-02-23 11:40AM	2024-02-23 02:28PM

Asset Data

Question	Answer
Was the Building Fully Accessible for Inspection?	Yes
Principal(s) Information	
Principal Name	Vincenzo Rosignano
Principal Organization	Garden of Learning and Discovery Pre-K Center
Meeting with Principal?	Yes
Principal Feedback	The Principal had no comments about the condition of the building at this time.
Custodian	Vinny Zadrma
Was the Custodian Present?	No
Fireman	Ivan Crispin (Handyman)
Was the Fireman Present?	Yes
Building Square Footage	11,000
Comments on the Area (for Athletic Field, Playing Surfaces, Leased Spaces)	None
Comments on the Stories (Floors) plus Basements	6+B
Comments on the Year Built	2015
Student Population	76
Staff Population	30
Comments on the Number of Classrooms	5
Weather	Fair
Facade Photo	



Ogden Avenue - Northeast View

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Architectural Inspection

X582

Main Entrance Photo



Facade A - Ogden Avenue

Roof Photo

Not taken

Do Stormwater Management/Green Infrastructure systems exist?
Type

No

No Storm Water Management Type Selected

Have any Systems/Major Building Components been upgraded?

Systems: Front and rear facade pointing and stone/ brick replacement

Years: 2024

Have there been any New Building Additions?

No New Construction

Tandem

No Tandem

Leased Space?

Yes

Year Leased

2015

Inspection Type

Partial Inspection

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

Structural Engineer Required

Structural Condition Type	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded						

Programmatic Accessibility

Programmatic Accessibility Status Question	Response
Is the Primary or secondary entrance on an accessible route?	Yes
Is the building a multi-story building?	No
Do any of the following spaces exist? Classroom, Art Room, Auditorium, Cafeteria, Computer, Gymnasiums, Library, Multipurpose Room, Science Labs	Yes
For the spaces that do exist, are they ALL accessible?	Yes
Is there at least one Boys and Girls or Unisex toilet accessible In the building?	Yes

Physical Breakdown Structure	Exists	Complies	Required	Deficiency	Assistive Listening System	Fire Alarm Strobe
------------------------------	--------	----------	----------	------------	----------------------------	-------------------

PROGRAMMATIC ACCESSIBILITY

Exterior Routes

Exterior Entrances & Exits		Yes		
Exterior H/C Lifts	No		No	
Exterior Ramps and Railings	No		No	

Interior Routes

Corridor and Lobby H/C Lifts	No		No	
Interior Corridor Doors And Hardware	Yes	Yes		

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**


Architectural Inspection

X582

Physical Breakdown Structure	Exists	Complies	Required	Deficiency	Assistive Listening System	Fire Alarm Strobe
Interior Corridors & Lobbies		Yes				
Interior Elevators	No					
Interior Lobby Doors And Hardware		Yes				
Interior Ramps	Yes	Yes				
Rooms & Spaces						
Art Rooms	No					
Auditorium	No					
Cafeteria	No					
Classrooms						
1st Floor	Yes	Yes				
Computer Rooms	No					
Gymnasium	No					
Library	No					
Main Office						
Room 115A	Yes	Yes				
Multi-purpose Room						
1st Floor	Yes	Yes			No	Yes
Nurse's Office						
Room 116	Yes	Yes				
Pool	No					
Science Lab	No					
Toilet Rooms (boys)						
1st Floor	Yes	Yes				
Toilet Rooms (girls)						
1st Floor	Yes	Yes				
Toilet Rooms (staff)						
1st Floor	Yes	Yes				

Building Template

X582



Inspection


Question	Response
----------	----------

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**


Architectural Inspection

X582

Question	Response
Architectural	
EXTERIOR	Inspected
AREAWAY	Does not exist
AWNINGS AND CANOPIES	Does not exist
CHIMNEY	Does not exist
COPING	Does not exist
CORNICE	Does not exist
DOORS	Inspected
DOORS AND FRAMES	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
DOOR HARDWARE	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LINTELS	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TRANSOM/SIDE LIGHT	Does not exist
EXTERIOR WALLS	Inspected
Material Type(s)	Masonry
Replacement Quantity	4,000
Replacement Uom	S.F.
Instance on Facades B, C, E	Inspected
Instance Condition	3- Fair
Instance Quantity	4,000
Instance Quantity Uom	S.F.
Deficiency	STUCCO CEMENT SURFACE:CRACKS, SPALLING
Roof Plan Reference	




Elevation



Elevation Reference
Deficiency Quantity
Quantity Uom
Potential Action
Urgency of Action
Purpose of Action
Deficiency Photo 1

Facade E
25
S.F.
REPLACE
PRIORITY 4
LEVEL 2



Facade E

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Architectural Inspection

X582

Question	Response
EXTERIOR	
EXTERIOR WALLS	
Deficiency Photo 2	No photo recorded
Violations	No violations recorded
EXTERIOR SOFFITS	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LOADING DOCK	Does not exist
LOUVER	Does not exist
PARAPETS	Not required
PLAZA DECK	Does not exist
ROOF	Not required
STAIRS/RAMPS: EXTERIOR	Does not exist
WINDOWS	Inspected
Replacement Quantity	600
Replacement Uom	S.F.
EXTERIOR GUARDS	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LINTELS	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
WINDOWS	Inspected
Material Type(s)	Aluminum
Instance on Aluminum - Other:Facade C	Inspected
Instance Condition	2- Between Good and Fair
Instance Quantity	600
Instance Quantity Uom	S.F.
Installation Year	2015
Source of Installation Year	Documented
Are these windows insulated?	Yes
Deficiency	No deficiencies recorded
INTERIOR	Inspected
POOLS	Does not exist
STRUCTURAL	Inspected
COLUMNS/BEAMS/BEARING WALLS	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FLOOR STRUCTURE	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FOUNDATION WALLS	Inspected
Material Type(s)	Concrete
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
ROOF STRUCTURE	Not required
VAULTS-BUNKERS	Does not exist
AUDITORIUM	Does not exist
CAFETERIA	Does not exist
CLASSROOMS/CORRIDORS/ADMIN SPACES	Inspected
Ceiling	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Door(s)	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Architectural Inspection

X582

Question	Response
INTERIOR	
CLASSROOMS/CORRIDORS/ADMIN SPACES	
Door(s)	
Deficiency	No deficiencies recorded
Floor Finish	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Walls	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Specialties	Does not exist
GYMNASIUM	Does not exist
INTERIOR DOOR HARDWARE	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
INTERIOR GUARDS	Does not exist
KITCHEN	Inspected
Instance on 1st Floor	Inspected
Ceiling	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Door(s)	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Floor Finish	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Walls	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Does not exist
LOCKER ROOM	Does not exist
MULTI-PURPOSE ROOM	Inspected
Instance on 1st Floor	Inspected
Ceiling	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Door(s)	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fixed Equipment	
Instance on 1st Floor	Does not exist
Floor Finish	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Sliding-folding Partition	
Instance on 1st Floor	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Architectural Inspection


X582

Question	Response
INTERIOR	
MULTI-PURPOSE ROOM	
Stage	
Instance on 1st Floor	Does not exist
Walls	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Window Curtains/Shades/Blinds	
Instance on 1st Floor	Does not exist
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SHOWER ROOM	Does not exist
STAIRS/RAMPS: INTERIOR	Does not exist
TOILET ROOMS - STAFF	Inspected
Ceiling	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Door(s)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Floor Finish	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Stalls	Does not exist
Walls	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOMS - STUDENTS	Inspected
Ceiling	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Door(s)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Floor Finish	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Stalls	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Walls	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIFE SAFETY	Inspected
F.D. HOLDING AREA	Does not exist
STEEL STAIRS	Does not exist
SITE	Inspected
CONTAINERIZATION	Does not exist
DRAINAGE SYSTEM FOR ASPHALT	Does not exist
DRAINAGE SYSTEM FOR CONCRETE	Does not exist
DRAINAGE SYSTEM FOR SOIL	Does not exist
DRINKING FOUNTAINS	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Architectural Inspection

X582

Question	Response
SITE	
FENCES	Does not exist
IRRIGATION SYSTEM	Does not exist
PAVING	Inspected
Student Non-Use	Does not exist
Student Use	Does not exist
Site Sidewalks & Walkways	Does not exist
DOT Sidewalk	Inspected
Asphalt	Does not exist
Concrete	Inspected
Condition	3- Fair
Deficiency	DAMAGED/DETERIORATED/MISSING SECTIONS
Deficiency Location/Instance	Along Ogden Avenue
Deficiency Quantity	50
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo 1	
Deficiency Photo 2	Along Ogden Avenue
Violations	No photo recorded No violations recorded
Pavers	Does not exist
PLAYGROUNDS	Does not exist
PLAYING SURFACE	Does not exist
RETAINING WALLS	Does not exist
SEATING	Does not exist
SITE WALLS (NOT RETAINING WALLS)	Does not exist
STAIRS/RAMPS: EXTERIOR	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Architectural Inspection

X582

Does the SCA expect asset to have artwork?

No