

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X601**

**Asset:** SMITH HS AF - BRONX, 333 EAST 151 STREET, BRONX, NY, 10451

Inspection Id	Inspection Type	Time In	Last Edited
4785	ELECTRICAL	2024-04-16 09:12AM	2024-04-17 11:45AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: All Electrical Systems and Components Years: 2003
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	No
Water Penetration In Electrical Room?	No

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

**Inspection**

Question	Response
<b>Electrical</b>	
<b>ATHLETIC FIELD</b>	Inspected
<b>Exterior Lighting</b>	Inspected
Condition	5- Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Local Sound System</b>	Does not exist
<b>Scoreboard</b>	Inspected
Instance	East Side of Athletic Field
Instance Condition	5- Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUDITORIUM</b>	Does not exist
<b>CAFETERIA</b>	Does not exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Does not exist
<b>COMPUTER LAB</b>	Does not exist
<b>GYMNASIUM</b>	Does not exist
<b>KITCHEN</b>	Does not exist
<b>LIBRARY</b>	Does not exist
<b>LOCKER ROOM</b>	Does not exist
<b>MULTIPURPOSE ROOM</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X601**

<b>Question</b>	<b>Response</b>
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Does not exist
TOILET ROOM - STUDENT	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Does not exist
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Does not exist
EXIT LIGHT	Does not exist
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Does not exist
GROUNDING SYSTEM	Does not exist
INTERCOM SYSTEM	Does not exist
LAN	Does not exist
LIGHTNING PROTECTION	Does not exist
MOTOR CONTROLLER	Does not exist
PANEL BOARD	Does not exist
PUBLIC ADDRESS SYSTEM	Does not exist
SECURITY	Inspected
IPDVS/CCTV System	Does not exist
Intrusion Alarm System	Does not exist
Lighting - Security	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	Does not exist
SWITCHBOARD	Does not exist
TELEPHONE SYSTEM	Does not exist
TRANSFORMER	Does not exist