

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X780

Asset: **P.S. @ 268 EAST 207 STREET - BRONX, 268 EAST 207 STREET, BRONX, NY, 10467**

Inspection Id	Inspection Type	Time In	Last Edited
2056	ELECTRICAL	2024-01-02 10:31AM	2024-01-30 08:52AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: All Electrical Systems and Components Except (Fire Alarm System, Electrical Panels on the Corridors, Staff Toilets Fluorescent and Incandescent Lighting, Service Switch and Partial Switchboard). Years: 2023
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
CAFETERIA	Inspected
Instance on Basement	Inspected
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Lighting Fixture - LED	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Does not exist
Local Sound System	
Instance on Basement	Does not exist
Projection System	
Instance on Basement	Does not exist
Theater Lighting System	
Instance on Basement	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X780

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Does not exist
GYMNASIUM	Inspected
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Local Sound System	
Instance on 1st Floor	Does not exist
Projection System	
Instance on 1st Floor	Does not exist
Scoreboard	
Instance on 1st Floor	Does not exist
Theater Lighting System	
Instance on 1st Floor	Does not exist
KITCHEN	Inspected
Instance on Basement	Inspected
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Does not exist
Lighting Fixture - HID	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X780

Question	Response
KITCHEN	
Lighting	
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Lighting Fixture - LED	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIBRARY	Does not exist
LOCKER ROOM	Does not exist
MULTIPURPOSE ROOM	Does not exist
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X780

Question	Response
TOILET ROOM - STUDENT	
Lighting	
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Does not exist
Recessed Mounted	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	1- Good
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	
Does not exist	
EMERGENCY GENERATOR SET	
Does not exist	
EMERGENCY LIGHT/EXIT LIGHT PANEL	
Does not exist	
EMERGENCY LIGHTING	
Inspected	
Battery Pack	
Inspected	
Condition	1- Good
Deficiency	No deficiencies recorded
Non Battery Pack	
Does not exist	
EXIT LIGHT	
Inspected	
Battery Pack	
Inspected	
Condition	1- Good
Deficiency	No deficiencies recorded
Non Battery Pack	
Does not exist	
EXIT/EMERGENCY LIGHT	
Inspected	
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	
Inspected	
Bell/Horn	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
Strobe	
Does not exist	
Manual Pull Station	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	
Does not exist	
Duct Smoke Detector	
Does not exist	
Area Smoke Detector	
Does not exist	
CO Detector	
Does not exist	
Heat Detector	
Does not exist	
Elevator Recall	
Does not exist	
Magnetic Door Holder/Contactor	
Does not exist	
Fused Cutout Panel	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	
Does not exist	
Main Panel	
Inspected	
Bell At Panel	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	
Does not exist	
Fire Alarm Control Panel (Standard)	
Inspected	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X780

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Fire Alarm Control Panel (Standard)	
Instance	Room Inside the Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	N/A
Installation Year	1960
Source of Installation Year	Inspector Estimate
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Room Inside the Cafeteria
Deficiency Quantity	37,000
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Sub-Panel	Does not exist
Remote Annunciator	Does not exist
Sprinkler Flow/Air Pressure Switch	Does not exist
Tamper Flow Switch/Chain	Does not exist
GROUNDING SYSTEM	Does not exist
INTERCOM SYSTEM	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Does not exist
Main Equipment Rack (MDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not exist
MOTOR CONTROLLER	Inspected
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Variable Frequency Drive	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Does not exist
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	2- Between Good and Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Corridors
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	1st Floor - Main Office
Instance Condition	1- Good
Instance Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X780

Question	Response
PUBLIC ADDRESS SYSTEM	
Instance Quantity Uom	EACH
Model	Bogen WMA 150
Installation Year	2023
Source of Installation Year	Documented
Deficiency	SPEAKER NOT OPERATIONAL
Deficiency Location/Instance	Rooms: 301, 302, 303
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
SECURITY	Inspected
IPDVS/CCTV System	Does not exist
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	Room B103
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 128BPT
Installation Year	2023
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Lighting - Security	Inaccessible
SERVICE SWITCH	Inspected
Instance	Basement - Boiler/Electric Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	School Air Conditioning. Panel
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1960
Source of Installation Year	Inspector Estimate
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Basement - Boiler/Electric Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X780

Question	Response
SERVICE SWITCH	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Basement - Boiler/Electric Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	School Distribution Panel
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1960
Source of Installation Year	Inspector Estimate
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Basement - Boiler/Electric Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWITCHBOARD	Inspected
Number of Spares	0
Fused Disconnect Switch Type	Inspected
Instance	Room inside the Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	Air Conditioning
Capacity/Size Quantity	400
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1960
Source of Installation Year	Inspector Estimate
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Room inside the Cafeteria
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Instance	Room inside the Cafeteria
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	General Electric
EquipmentId	600A
Capacity/Size Quantity	600

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X780

Question	Response
SWITCHBOARD	
Molded Case Circuit Breaker Type	
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2023
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TRANSFORMER	Does not exist