

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X864**

**Asset: P.S. 205B (ECF) - BRONX, 2375 SOUTHERN BOULEVARD, BRONX, NY, 10460**

Inspection Id	Inspection Type	Time In	Last Edited
2513	ELECTRICAL	2024-01-19 08:44AM	2024-02-13 08:34AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: LED Lighting Years: 2023 Systems: Public Address System (Amplifier) Years: 2021 Systems: LAN Years: 2019 Systems: Intrusion Alarm System (Partial Remote Annunciator) Years: 2015 Systems: Most Molded Case Circuit Breaker Panel Boards Years: 2014, 2009, 2002 Systems: Cafeteria (Projection System) Years: 2011 Systems: Interior Fluorescent Lighting, Security Lights Years: 2008 Systems: Fire Alarm System (Main Panel) Years: 2006 Systems: Service Switch, Emergency Light/Exit Light Panel, Intrusion Alarm System Years: 2002
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

**Inspection**

Question	Response
<b>Electrical</b>	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
CAFETERIA	Inspected
Instance on 1st Floor - Staff	Inspected
Instance on 1st Floor - Students	Inspected
<b>Lighting</b>	
Instance on 1st Floor - Staff	Inspected
Instance on 1st Floor - Students	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor - Staff	Inspected
Instance on 1st Floor - Students	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor - Staff	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X864**

Question	Response
<b>CAFETERIA</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Students	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor - Staff	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Students	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
<b>Local Sound System</b>	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
<b>Projection System</b>	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Inspected
Instance Condition	3- Fair
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
<b>Theater Lighting System</b>	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
Inspected	
<b>Lighting</b>	
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Inspected	
<b>Pendant Mounted</b>	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Does not exist	
<b>Lighting Fixture - Incandescent</b>	
Does not exist	
<b>Lighting Fixture - LED</b>	
Inspected	
<b>Pendant Mounted</b>	
Does not exist	
<b>Surface Mounted</b>	
Does not exist	
<b>Recessed Mounted</b>	
Inspected	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X864**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
<b>Recessed Mounted</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Does not exist
<b>GYMNASIUM</b>	Does not exist
<b>KITCHEN</b>	Inspected
Instance on 1st Floor	Inspected
<b>Lighting</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not exist
<b>LIBRARY</b>	Does not exist
<b>LOCKER ROOM</b>	Does not exist
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>SCIENCE DEMO ROOM</b>	Does not exist
<b>SCIENCE LAB</b>	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X864**

<b>Question</b>	<b>Response</b>
<b>TOILET ROOM - STUDENT</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Does not exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT/EMERGENCY LIGHT</b>	Does not exist
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>Bell/Horn</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	Does not exist
<b>Manual Pull Station</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Area Smoke Detector</b>	Does not exist
<b>CO Detector</b>	Does not exist
<b>Heat Detector</b>	Does not exist
<b>Elevator Recall</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X864**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>Magnetic Door Holder/Contactor</b>	Does not exist
<b>Fused Cutout Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Digital Communicator</b>	Does not exist
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Room 218
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mirtone
Model	Quick Start
EquipmentId	N/A
Installation Year	2006
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>Sub-Panel</b>	Does not exist
<b>Remote Annunciator</b>	Does not exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Does not exist
<b>Tamper Flow Switch/Chain</b>	Does not exist
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>INTERCOM SYSTEM</b>	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Does not exist
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>MOTOR CONTROLLER</b>	Inspected
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Variable Frequency Drive</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Kitchen, Electrical Room, Rooms 134, 218, 219
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Fused Toggle Switch Type</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X864**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room, Rooms 134, 219
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Inspected
Instance	Room 125
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	1976
Source of Installation Year	Documented
Deficiency	SPEAKER NOT OPERATIONAL
Deficiency Location/Instance	Assistant Principal's Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Room 125
Deficiency Quantity	21,000
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SECURITY</b>	Inspected
<b>IPDVS/CCTV System</b>	Does not exist
<b>Intrusion Alarm System</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	Room 125
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128B
Installation Year	2002
Source of Installation Year	Custodial Staff
Deficiency	PANEL NOT CONNECTED TO DOE CENTRAL STATION
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REWIRE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>Infrared Sensor</b>	Inspected
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X864**

Question	Response
<b>SECURITY</b>	
<b>Intrusion Alarm System</b>	
<b>Infrared Sensor</b>	
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting - Security</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	
Instance	Electrical Room 114
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	Main Service Switch
Capacity/Size Quantity	2000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2002
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>SWITCHBOARD</b>	
Number of Spares	0
<b>Fused Disconnect Switch Type</b>	
Instance	Electrical Room 114
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific Electric
EquipmentId	Main SWBD
Capacity/Size Quantity	2000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1976
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room 114
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	
	Does not exist
<b>Molded Case Circuit Breaker Type</b>	
	Does not exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

***Electrical Inspection***

**X864**

<b>Question</b>	<b>Response</b>
<b>TELEPHONE SYSTEM</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>TRANSFORMER</b>	Does not exist