

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X878

Asset: FANNIE LOU HAMER FREEDOM HS - BRONX, 1021 JENNINGS STREET, BRONX, NY, 10460

Inspection Id	Inspection Type	Time In	Last Edited
530	ELECTRICAL	2023-10-30 08:29AM	2023-11-27 03:19PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Public Address and Local Sound Systems Years: 2023 Systems: Security Lighting, Gymnasium LED Retrofitted Years: 2022 Systems: Molded Case Circuit Breaker Panel Boards Years: 2019, 1994 Systems: Grounding System Years: 2019 Systems: IPDVS/CCTV System Years: 2013 Systems: Telephone System, LAN Years: 2009 Systems: Intrusion Alarm System Years: 1999 Systems: All Other Electrical Systems and Components Years: 1994
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	Fire Alarm System - Components Not Operational	Not Operational	Fire Alarm System - Fan Shutdown Control	Main Entrance	Rondy Torrellas	Fireman	No Photo Taken
Yes	Emergency Generator Components - Not Operational	Not Operational	Emergency Generator	Roof Enclosure	Rondy Torrellas	Fireman	No Photo Taken
Yes	Emergency Gas Shut-Off Valve - Not Operational	Not Operational	Emergency Gas Shut-Off Valve	Room 123	Rondy Torrellas	Fireman	No Photo Taken

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
CAFETERIA	Inspected
Instance on Basement	Inspected
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Surface Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X878

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Lighting Fixture - LED	
Instance on Basement	Does not exist
Local Sound System	
Instance on Basement	Inspected
Instance Condition	1- Good
Installation Year	2023
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on Basement	Does not exist
Theater Lighting System	
Instance on Basement	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Pendant Mounted	
Does not exist	
Surface Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	30
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	680
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Does not exist	

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X878

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
COMPUTER LAB	Does not exist
GYMNASIUM	Inspected
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Installation Year	2023
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not exist
Scoreboard	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 1st Floor	Does not exist
KITCHEN	Inspected
Instance on Basement	Inspected
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	12

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X878

Question	Response
KITCHEN	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Lighting Fixture - LED	
Instance on Basement	Does not exist
LIBRARY	Inspected
Instance on Room 218	Inspected
Lighting	
Instance on Room 218	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 218	Inspected
Pendant Mounted	
Instance on Room 218	Does not exist
Surface Mounted	
Instance on Room 218	Does not exist
Recessed Mounted	
Instance on Room 218	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	47
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room 218	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 218	Does not exist
Lighting Fixture - LED	
Instance on Room 218	Does not exist
Raceway With Receptacles	
Instance on Room 218	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Room 218	Does not exist
LOCKER ROOM	Does not exist
MULTIPURPOSE ROOM	Does not exist
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Inspected
Instance on Room B3	Inspected
Power Panel?	Yes
Alternative Use	No

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X878

Question	Response
SCIENCE LAB	
Instance on Room 112	Inspected
Power Panel?	Yes
Alternative Use	Yes
Instance on Room 123	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 210	Inspected
Power Panel?	Yes
Alternative Use	No
Lighting	
Instance on Room B3	Inspected
Instance on Room 112	Inspected
Instance on Room 123	Inspected
Instance on Room 210	Inspected
Lighting Fixture - Fluorescent	
Instance on Room B3	Inspected
Instance on Room 112	Inspected
Instance on Room 123	Inspected
Instance on Room 210	Inspected
Pendant Mounted	
Instance on Room B3	Does not exist
Instance on Room 112	Does not exist
Instance on Room 123	Does not exist
Instance on Room 210	Does not exist
Surface Mounted	
Instance on Room B3	Does not exist
Instance on Room 112	Does not exist
Instance on Room 123	Does not exist
Instance on Room 210	Does not exist
Recessed Mounted	
Instance on Room B3	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 112	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 123	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	18
Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X878

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 210	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room B3	Does not exist
Instance on Room 112	Does not exist
Instance on Room 123	Does not exist
Instance on Room 210	Does not exist
Lighting Fixture - Incandescent	
Instance on Room B3	Does not exist
Instance on Room 112	Does not exist
Instance on Room 123	Does not exist
Instance on Room 210	Does not exist
Lighting Fixture - LED	
Instance on Room B3	Does not exist
Instance on Room 112	Does not exist
Instance on Room 123	Does not exist
Instance on Room 210	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Room B3	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 123	Inspected
Instance Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Instance on Room 210	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room B3	Does not exist
Instance on Room 112	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X878

Question	Response
SCIENCE LAB	
Emergency Shut-Off Power	
Instance on Room 123	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Power Supply	
Instance on Room B3	Inspected
Instance on Room 112	Inspected
Instance on Room 123	Inspected
Instance on Room 210	Inspected
Instructor Unit	
Instance on Room B3	Does not exist
Instance on Room 112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 123	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room B3	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 123	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room B3	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 123	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Room B3	Does not exist
Instance on Room 112	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X878

Question	Response
SCIENCE LAB	
Projection System	
Instance on Room 123	Does not exist
Instance on Room 210	Does not exist
SCIENCE PREP ROOM	Does not exist
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Inspected
Automatic Transfer Switch (ATS)	Inspected
Instance	Room B25
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Generac
EquipmentId	Fire Alarm System ATS
Capacity/Size Quantity	105
Capacity/Size UOM	Amps

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X878

Question	Response
EMERGENCY GENERATOR SET	
Automatic Transfer Switch (ATS)	
Source of Capacity/Size	Nameplate
Installation Year	1994
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Room B25
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Generac
EquipmentId	N/A
Capacity/Size Quantity	105
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1994
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Battery Charger	Inspected
Instance	Roof Generator Enclosure
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	Battery Charger
Capacity/Size Quantity	6
Capacity/Size UOM	AmpsDC
Capacity/Size 2 Quantity	12
Capacity/Size 2 UOM	VDC
Source of Capacity/Size	Nameplate
Installation Year	1994
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Emergency Distribution Board	Inspected
Number of Spares	1
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room B21
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	EMDP
Capacity/Size Quantity	400
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Inspector Estimate
Installation Year	1994
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Molded Case Circuit Breaker Type	Does not exist
Diesel	Inspected
Instance	Roof Generator Enclosure
Instance Condition	5- Poor
Instance Quantity	1
Instance Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X878

Question	Response
EMERGENCY GENERATOR SET	
Diesel	
Manufacturer	Generac
EquipmentId	Emergency Generator
Capacity/Size Quantity	44
Capacity/Size UOM	kVA
Capacity/Size 2 Quantity	35
Capacity/Size 2 UOM	kW
Capacity/Size 3 Quantity	121
Capacity/Size 3 UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1994
Source of Installation Year	Documented
Deficiency	GENERATOR NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Natural Gas	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Does not exist
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not exist
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
Bell/Horn	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	5- Poor
Deficiency	CONTROL NOT OPERATIONAL
Deficiency Location/Instance	Main Entrance
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Duct Smoke Detector	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X878

Question	Response
FIRE ALARM SYSTEM	
Duct Smoke Detector	
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CO Detector	Does not exist
Heat Detector	Does not exist
Elevator Recall	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Does not exist
Fused Cutout Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	IRC - 3
EquipmentId	Fire Alarm Control Panel
Installation Year	1994
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
Sub-Panel	Does not exist
Remote Annunciator	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Punch Register	Does not exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Inspected
Elevator	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X878

Question	Response
INTERCOM SYSTEM	
Elevator	
Deficiency	No deficiencies recorded
Holding Area	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Does not exist
Main Equipment Rack (MDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not exist
MOTOR CONTROLLER	Inspected
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Variable Frequency Drive	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	Main Office
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Telecor eSeries eMH
Installation Year	2023
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SECURITY	Inspected
IPDVS/CCTV System	Inspected
Condition	2- Between Good and Fair
Installation Year	2013
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	Custodian's Office Room B12
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128B
Installation Year	1999
Source of Installation Year	Inspector Estimate
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X878

Question	Response
SECURITY	
Intrusion Alarm System	
Panic Switch	
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting - Security	
Condition	1- Good
Deficiency	No deficiencies recorded
SERVICE SWITCH	
Instance	Electrical Room B21
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	Main
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1994
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	
Number of Spares	0
Fused Disconnect Switch Type	
Instance	Electrical Room B21
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	N/A
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1994
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	
Does not exist	
Molded Case Circuit Breaker Type	
Does not exist	
TELEPHONE SYSTEM	
PBX/Intercom	
Condition	3- Fair
Deficiency	No deficiencies recorded
Standard	
Condition	3- Fair
Deficiency	No deficiencies recorded
TRANSFORMER	
Does not exist	