

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

X891

Asset: P.S. 91 MINISCHOOL - BRONX, 2170 AQUEDUCT AVENUE, BRONX, NY, 10453

Inspection Id	Inspection Type	Time In	Last Edited
4407	MECHANICAL	2024-04-01 07:19AM	2024-04-01 03:08PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Drinking Fountain Years: 2023 Systems: Gas Fired Furnace Years: 2018 Systems: Refrigerant Piping Years: 2016
Are there fuel tanks?	No
Total # of water main service entries to the asset	1
MERs/Fan Rooms Locations	MER 6
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Are there any Emergency Stop Switches with Missing Hammers?	No components

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image	
		No condition recorded						

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not exist
Cooling Coil in Ductwork	Does not exist
Cooling Tower	Does not exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Dry Cooler	Does not exist
Packaged / Rooftop Unit	Does not exist
Packaged Terminal A/C	Does not exist
Refrigerant Leak Detection System	Does not exist
Refrigerant Piping	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Return Fan	Does not exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not exist
CLIMATE CONTROL SYSTEM	Does not exist
COMPACTOR	Does not exist
CONVEYING	Does not exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not exist
Pressure Booster System	Does not exist
Water Service	Inspected
Instance	MER 6

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

X891

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN:MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	MER 6
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not exist
Domestic Water Heat Exchanger	Does not exist
Electric Domestic Water Heater	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Fired Domestic Water Heater	Does not exist
Oil Fired Domestic Water Heater	Does not exist
Heat Pump Domestic Water Heater	Does not exist
Domestic Water Distribution Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	
Interior Storm Piping	Does not exist
Sewage/Waste/Vent Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not exist
Sump Pump	Does not exist
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not exist
FIXTURES	
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Urinal	Does not exist
Student	Inspected
Drinking Fountain	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3- Fair

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

X891

Question	Response
FIXTURES	
Student	
Lavatory/Sink	
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Girl's Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Locker Room Shower	
	Does not exist
Sink And Fountain Combo Unit	
	Does not exist
Toilet	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Urinal	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
GAS SERVICE	
	Inspected
Gas Distribution Piping	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	
	Does not exist
Gas Meter Room Vent	
	Does not exist
Gas Pressure Booster	
	Does not exist
CO/Gas Leak Detection	
	Does not exist
HEATING	
	Inspected
Heating Coil In Ductwork	
	Does not exist
Hydronic Heating	
	Does not exist
Radiator/Convactor/Fin Tube	
	Inspected
Condition	4- Between Fair and Poor
Deficiency	RADIATOR/CONVECTOR:DEFECTIVE
Deficiency Location/Instance	MER 6 (1 of 1)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Heating	
	Does not exist
Steam supplied by External Sources	
	Does not exist
Unit Heater/Cabinet Heater	
	Does not exist
HEATING PLANT	
	Does not exist
Enclosed IDF Room	
	Inspected
Instance on Room 1	Inspected
Dedicated A/C Equipment	
	Inspected
Instance on Room 1	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room 1

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

X891

Question	Response
Enclosed IDF Room	
Dedicated A/C Equipment	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
KITCHEN	Does not exist
MDF Room	Does not exist
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Does not exist
SWIMMING POOL	Does not exist
VENTILATION	Inspected
Is the building Mechanically ventilated?	Yes
Exhaust Fan	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-25
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not exist
Metal Ductwork	Inspected
Condition	3- Fair
Are there any uninsulated ductwork by design in Mechanical rooms?	No
Are there chain operated dampers?	No
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	MER 6
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Supply Fan	Does not exist
Unit Ventilator	Does not exist