

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X906

Asset: P.S. 175 TRANSPORTABLE- BRONX, 200 CITY ISLAND AVENUE, BRONX, NY, 10464

Inspection Id	Inspection Type	Time In	Last Edited
585	ELECTRICAL	2023-10-31 08:14AM	2023-11-28 09:02AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Telephone System Years: 2016 Systems: Exit/Emergency Lights, Public Address System Years: 2012 Systems: Security Lights Years: 2009 Systems: All Other Electrical Systems and Components Years: 2002
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
Yes	Exit/Emergency Light - Not Operational	Each room has only one Exit/Emergency Light fixture and none of them work.	Exit/Emergency Light	Rooms: T1, T2, T3, T4	Patrick Bridgewater	Fireman	No Photo Taken

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
CAFETERIA	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
COMPUTER LAB	Does not exist
GYMNASIUM	Does not exist
KITCHEN	Does not exist
LIBRARY	Does not exist
LOCKER ROOM	Does not exist
MULTIPURPOSE ROOM	Does not exist
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X906

Question	Response
SCIENCE PREP ROOM	Does not exist
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Does not exist
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Does not exist
EXIT LIGHT	Does not exist
EXIT/EMERGENCY LIGHT	Inspected
Condition	4- Between Fair and Poor
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	T1, T2, T3, T4
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
FIRE ALARM SYSTEM	Inspected
Bell/Horn	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Does not exist
Duct Smoke Detector	Does not exist
Area Smoke Detector	Does not exist
CO Detector	Does not exist
Heat Detector	Does not exist
Elevator Recall	Does not exist
Magnetic Door Holder/Contactor	Does not exist
Fused Cutout Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3- Fair

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X906

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Bell At Panel	
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	
Instance	Room T1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST 2
EquipmentId	Fire Alarm Control Panel
Installation Year	2002
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	
	Does not exist
Sub-Panel	
	Does not exist
Remote Annunciator	
	Does not exist
Sprinkler Flow/Air Pressure Switch	
	Does not exist
Tamper Flow Switch/Chain	
	Does not exist
GROUNDING SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	
	Does not exist
LAN	
	Inspected
Local Distribution Frame (I/LDF)	
Condition	3- Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	
	Does not exist
LIGHTNING PROTECTION	
	Does not exist
MOTOR CONTROLLER	
	Does not exist
PANEL BOARD	
	Inspected
Fused Disconnect Switch Type	
	Does not exist
Fused Knife Switch Type	
	Does not exist
Fused Toggle Switch Type	
	Does not exist
Molded Case Circuit Breaker Type	
Condition	3- Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	
	Inspected
Instance	Connected to Main Asset X175
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	2012
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
SECURITY	
	Inspected
IPDVS/CCTV System	
	Does not exist
Intrusion Alarm System	
	Does not exist
Lighting - Security	
Condition	3- Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X906

Question	Response
SERVICE SWITCH	
Instance	Outdoor Electric Enclosure
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	Main
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2002
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	
	Inspected
Number of Spares	13
Fused Disconnect Switch Type	Does not exist
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Instance	Outdoor Electrical Enclosure
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	Main Distribution Panel
Capacity/Size Quantity	400
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2002
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
TELEPHONE SYSTEM	
	Inspected
PBX/Intercom	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Standard	
	Does not exist
TRANSFORMER	
	Does not exist