

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X926**

**Asset: P.S. 76 TEMP. C.R. BLDG. - BRONX, 900 ADEE AVENUE, BRONX, NY, 10469**

Inspection Id	Inspection Type	Time In	Last Edited
1018	ELECTRICAL	2023-11-16 08:13AM	2023-12-11 01:34PM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Security Lights, LAN Years: 2023 Systems: Exit/Emergency Lighting Years: 2018 Systems: Telephone System (PBX/Intercom) Years: 2014 Systems: Intrusion Alarm System (Infrared Sensors, Remote Annunciator, Siren/Strobe) Years: 2009 Systems: Auxiliary Signal/Bell System Years: 2004 Systems: All Other Electrical Systems and Components Years: 1997
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	condition	recorded					

**Inspection**

Question	Response
<b>Electrical</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Does not exist
<b>CAFETERIA</b>	Does not exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>Lighting</b>	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Surface Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	131
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Does not exist
<b>COMPUTER LAB</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X926**

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	Does not exist
<b>KITCHEN</b>	Does not exist
<b>LIBRARY</b>	Does not exist
<b>LOCKER ROOM</b>	Does not exist
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>SCIENCE DEMO ROOM</b>	Does not exist
<b>SCIENCE LAB</b>	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>TOILET ROOM - STAFF</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Surface Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Does not exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Does not exist
<b>EMERGENCY LIGHTING</b>	Does not exist
<b>EXIT LIGHT</b>	Does not exist
<b>EXIT/EMERGENCY LIGHT</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>Bell/Horn</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Manual Pull Station</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Does not exist
<b>Duct Smoke Detector</b>	Does not exist
<b>Area Smoke Detector</b>	Does not exist
<b>CO Detector</b>	Does not exist
<b>Heat Detector</b>	Does not exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X926**

Question	Response
<b>FIRE ALARM SYSTEM</b>	
<b>Elevator Recall</b>	Does not exist
<b>Magnetic Door Holder/Contactor</b>	Does not exist
<b>Fused Cutout Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Digital Communicator</b>	Does not exist
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Corridor by Room T10
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST
EquipmentId	Fire Alarm Control Panel
Installation Year	1997
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>Sub-Panel</b>	Does not exist
<b>Remote Annunciator</b>	Does not exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Does not exist
<b>Tamper Flow Switch/Chain</b>	Does not exist
<b>GROUNDING SYSTEM</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>INTERCOM SYSTEM</b>	
Does not exist	
<b>LAN</b>	
Inspected	
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Does not exist
<b>LIGHTNING PROTECTION</b>	
Does not exist	
<b>MOTOR CONTROLLER</b>	
Does not exist	
<b>PANEL BOARD</b>	
Inspected	
<b>Fused Disconnect Switch Type</b>	Does not exist
<b>Fused Knife Switch Type</b>	Does not exist
<b>Fused Toggle Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
Inspected	
Instance	Connected to Main Asset X076
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	1997
Source of Installation Year	Documented
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**X926**

<b>Question</b>	<b>Response</b>
<b>SECURITY</b>	Inspected
<b>IPDVS/CCTV System</b>	Does not exist
<b>Intrusion Alarm System</b>	Inspected
<b>Central Control Panel</b>	Does not exist
<b>Infrared Sensor</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Does not exist
<b>Remote Annunciator</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting - Security</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	Inspected
Instance	Outdoor Electrical Enclosure
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Square D
EquipmentId	Service Disconnect
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1997
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>SWITCHBOARD</b>	Inspected
Number of Spares	10
<b>Fused Disconnect Switch Type</b>	Does not exist
<b>Fused Knife Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Inspected
Instance	Outdoor Electrical Enclosure
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Square D
EquipmentId	N/A
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1997
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>TELEPHONE SYSTEM</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist