

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X930

Asset: P.S. 9 TEMP. C.R. BLDG. - BRONX, 230 EAST 183 STREET, BRONX, NY, 10458

Inspection Id	Inspection Type	Time In	Last Edited
2604	ELECTRICAL	2024-01-23 08:37AM	2024-01-23 03:32PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Interior Lighting, LAN Years: 2022 Systems: Public Address System Years: 2013 Systems: All Other Electrical Systems and Components Years: 1998
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	Yes
Are dedicated intercoms available in all of these spaces for use during a fire?	Yes
Are all dedicated intercoms operational?	Yes

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
Yes	Emergency Lighting - Not Operational	Emergency Lights are out of order.	Emergency Lighting	Corridors and Multipurpose Room	John Pomilla	Custodian	No Photo Taken

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
CAFETERIA	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Does not exist
GYMNASIUM	Does not exist
KITCHEN	Does not exist
LIBRARY	Does not exist
LOCKER ROOM	Does not exist
MULTIPURPOSE ROOM	Inspected
Instance on 1st Floor	Inspected
Lighting	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X930

Question	Response
MULTIPURPOSE ROOM	
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Local Sound System	
Instance on 1st Floor	Does not exist
Projection System	
Instance on 1st Floor	Does not exist
Theater Lighting System	
Instance on 1st Floor	Does not exist
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Does not exist
EMERGENCY DC STANDBY BATTERY POWER	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X930

Question	Response
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	5- Poor
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Non Battery Pack	Does not exist
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not exist
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
Bell/Horn	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Does not exist
Duct Smoke Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CO Detector	Does not exist
Heat Detector	Does not exist
Elevator Recall	Does not exist
Magnetic Door Holder/Contactor	Does not exist
Fused Cutout Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Main Panel	Inspected
Bell At Panel	Does not exist
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST 2
EquipmentId	Fire Alarm Control Panel

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

X930

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Fire Alarm Control Panel (Electronic)	
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	
	Does not exist
Sub-Panel	
	Does not exist
Remote Annunciator	
	Does not exist
Sprinkler Flow/Air Pressure Switch	
	Does not exist
Tamper Flow Switch/Chain	
	Does not exist
GROUNDING SYSTEM	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	
	Does not exist
LAN	
	Inspected
Local Distribution Frame (I/LDF)	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	
	Does not exist
LIGHTNING PROTECTION	
	Does not exist
MOTOR CONTROLLER	
	Does not exist
PANEL BOARD	
	Inspected
Fused Disconnect Switch Type	
	Does not exist
Fused Knife Switch Type	
	Does not exist
Fused Toggle Switch Type	
	Does not exist
Molded Case Circuit Breaker Type	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	
	Inspected
Instance	Connected to Main Asset X009
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	2013
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SECURITY	
	Inspected
IPDVS/CCTV System	
	Does not exist
Intrusion Alarm System	
	Inspected
Central Control Panel	
	Inspected
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

X930

Question	Response
SECURITY	
Intrusion Alarm System	
Panic Switch	
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting - Security	Inaccessible
SERVICE SWITCH	Inspected
Instance	Outdoor Electrical Enclosure
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Electrotech
EquipmentId	N/A
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	Inspected
Number of Spares	8
Fused Disconnect Switch Type	Does not exist
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Square D
EquipmentId	N/A
Capacity/Size Quantity	1000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not exist