

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X982**

Asset: **P.S. 197 TEMP. C.R. BLDG S - BRONX, 1250 WARD AVENUE, BRONX, NY, 10472**

Inspection Id	Inspection Type	Time In	Last Edited
5021	MECHANICAL	2024-04-29 07:15AM	2024-05-29 10:12AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Electric Domestic Water Heater (1 of 2) Years: 2016 Systems: Fixtures - Toilets, Urinals Years: 2015
Are there fuel tanks?	No
Total # of water main service entries to the asset	0
MERs/Fan Rooms Locations	None
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Are there any Emergency Stop Switches with Missing Hammers?	No components

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

**Inspection**

Question	Response
<b>Mechanical</b>	
<b>AIR CONDITIONING</b>	Inspected
Chilled Water System	Does not exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not exist
Cooling Coil in Ductwork	Does not exist
Cooling Tower	Does not exist
DX Split System	Does not exist
Dry Cooler	Does not exist
Packaged / Rooftop Unit	Does not exist
Packaged Terminal A/C	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	S -1, S -4, S -9, s -10, S -11.
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Refrigerant Leak Detection System	Does not exist
Refrigerant Piping	Does not exist
Return Fan	Does not exist
<b>CENTRAL ACID WASTE NEUTRALIZING TANK</b>	Does not exist
<b>CLIMATE CONTROL SYSTEM</b>	Does not exist
<b>COMPACTOR</b>	Does not exist
<b>CONVEYING</b>	Does not exist
<b>DOMESTIC WATER SYSTEM</b>	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not exist
Pressure Booster System	Does not exist
Water Service	Inaccessible
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X982**

Question	Response
<b>DOMESTIC WATER SYSTEM</b>	
<b>Domestic Hot Water System</b>	
<b>Domestic Water Heat Exchanger</b>	Does not exist
<b>Electric Domestic Water Heater</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Gas Fired Domestic Water Heater</b>	Does not exist
<b>Oil Fired Domestic Water Heater</b>	Does not exist
<b>Heat Pump Domestic Water Heater</b>	Does not exist
<b>Domestic Water Distribution Piping</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>DRAIN/WASTE/VENT AND STORM SYSTEM</b>	Inspected
<b>Interior Storm Piping</b>	Does not exist
<b>Sewage/Waste/Vent Piping</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Sewage Ejector Pump</b>	Does not exist
<b>Sump Pump</b>	Does not exist
<b>DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)</b>	Does not exist
<b>FIXTURES</b>	Inspected
<b>Staff And Other</b>	Inspected
<b>Janitor Sink</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Toilet</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Urinal</b>	Does not exist
<b>Student</b>	Inspected
<b>Drinking Fountain</b>	Inspected
Condition	4- Between Fair and Poor
Deficiency	CLOGGED/LEAKING
Deficiency Location/Instance	Corridor near Rooms T-9, 117
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lavatory/Sink</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Locker Room Shower</b>	Does not exist
<b>Sink And Fountain Combo Unit</b>	Does not exist
<b>Toilet</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Urinal</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**X982**

<b>Question</b>	<b>Response</b>
<b>GAS FIRED FURNACE</b>	Does not exist
<b>GAS SERVICE</b>	Does not exist
<b>HEATING</b>	Inspected
<b>Heating Coil In Ductwork</b>	Does not exist
<b>Hydronic Heating</b>	Does not exist
<b>Radiator/Convactor/Fin Tube</b>	Inspected
Condition	4- Between Fair and Poor
Deficiency	FIN TUBE:DEFECTIVE
Deficiency Location/Instance	Main Entrance
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Steam Heating</b>	Does not exist
<b>Steam supplied by External Sources</b>	Does not exist
<b>Unit Heater/Cabinet Heater</b>	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE CONTROLS
Deficiency Location/Instance	Room S118
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>HEATING PLANT</b>	Does not exist
<b>Enclosed IDF Room</b>	Inspected
Instance on Room S118	Inspected
<b>Dedicated A/C Equipment</b>	
Instance on Room S118	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room S118
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>KITCHEN</b>	Does not exist
<b>MDF Room</b>	Does not exist
<b>SCIENCE DEMO ROOM</b>	Does not exist
<b>SCIENCE LAB</b>	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>VENTILATION</b>	Inspected
Is the building Mechanically ventilated?	Yes
<b>Exhaust Fan</b>	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-25
Deficiency	No deficiencies recorded

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

***Mechanical Inspection***

**X982**

<b>Question</b>	<b>Response</b>
<b>VENTILATION</b>	
<b>Heating And Ventilating Unit</b>	Does not exist
<b>Metal Ductwork</b>	Inspected
Condition	3- Fair
Are there any uninsulated ductwork by design in Mechanical rooms?	No
Are there chain operated dampers?	No
Deficiency	No deficiencies recorded
<b>Supply Fan</b>	Does not exist
<b>Unit Ventilator</b>	Does not exist