

Appendix B: COVID-19 Inspections

Date: **February 24, 2021**

Name of person conducting the inspection: **Rick Nakano, Javier Rodriguez, Jerry Hills, Rosa Gonzalez**

Work location evaluated: **Parkview Elementary**

Exposure Controls	Status	Person Assigned to Correct	Date Corrected
Engineering			
Barriers/partitions	Good	All face-to-face interaction areas covered. All student and teacher desks included.	
Ventilation (amount of fresh air and filtration maximized)	Good	MERV13 and MERV15 filters with maximum outdoor air.	
Additional room air filtration	Good	Additional portable HEPA air filters added to health office and CARE rooms.	
Administrative			
Physical distancing	Good	As much as possible including directional paths and markers for any lines.	
Surface cleaning and disinfection (frequently enough and adequate supplies)	Good	Additional custodial training and support provided.	
Hand washing facilities (adequate numbers and supplies)	Good	Placed in strategic areas to reduce gatherings in bathrooms and to provide additional to portable classrooms.	
Disinfecting and hand sanitizing solutions being used according to manufacturer instructions	Good		
PPE (not shared, available and being worn)	Good		
Face coverings (cleaned sufficiently often)	Good		
Gloves	Good.	In situations that	

		require their use and as requested.	
Face shields/goggles	Good.	In situations that require their use and as requested.	
Respiratory protection	Good.	In situations that require their use.	