

KIPP: NJ Newark School District
 KIPP Truth Justice School
 275 Sussex Avenue, Newark, NJ 07107
 Water Quality Testing Analytical Results

Station Name	NJDEP Drinking Water Standards	FB-20220830	TJ-FL1-H103-DF	TJ-FL1-H103-DFB	TJ-FL1-H119-DF1	TJ-FL1-H119-DF2	TJ-FL1-H119-DFB	TJ-FL1-H122-DF1	TJ-FL1-H122-DF2	TJ-FL1-H122-DFB	TJ-FL1-PEO*	TJ-FL1-R102-TS	TJ-FL1-R104-NS												
Date		8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022												
Lab Sample ID		460-264626-41	460-264626-8	460-264626-9	460-264626-11	460-264626-12	460-264626-13	460-264626-4	460-264626-5	460-264626-6	460-264626-1	460-264626-7	460-264626-10												
Matrix		Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water												
Units		ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l												
		Result	RL	Result	RL	Result	RL	Result	RL	Result	RL	Result	RL	Result	RL										
Metals																									
Lead	15	ND	2	ND	2	ND	2	ND	2	ND	2	ND	2	ND	2	ND	2	ND	2	31.8	2	1.2 J	2	0.66 J	2

Station Name	NJDEP Drinking Water Standards	TJ-FL1-R119-TS	TJ-FL1-R123-DF	TJ-FL1-R123-DFB	TJ-FL2-H210-DF	TJ-FL2-H210-DFB	TJ-FL2-H224-DF1	TJ-FL2-H224-DF2	TJ-FL2-H224-DFB	TJ-FL2-H233-DF1	TJ-FL2-H233-DF2	TJ-FL2-H233-DFB	TJ-FL2-R224-TS												
Date		8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022												
Lab Sample ID		460-264626-14	460-264626-2	460-264626-3	460-264626-15	460-264626-16	460-264626-23	460-264626-24	460-264626-25	460-264626-17	460-264626-18	460-264626-19	460-264626-22												
Matrix		Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water												
Units		ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l												
		Result	RL	Result	RL	Result	RL	Result	RL	Result	RL	Result	RL	Result	RL										
Metals																									
Lead	15	0.62 J	2	ND	2	ND	2	ND	2	ND	2	ND	2	ND	2	ND	2	ND	2	ND	2	ND	2	0.48 J	2

Station Name	NJDEP Drinking Water Standards	TJ-FL2-R227-TS	TJ-FL2-R229-TS	TJ-FL3-H309-DF	TJ-FL3-H309-DFB	TJ-FL3-H323-DF1	TJ-FL3-H323-DF2	TJ-FL3-H323-DFB	TJ-FL3-H332-DF1	TJ-FL3-H332-DF2	TJ-FL3-H332-DFB	TJ-FL3-R301-TS1	TJ-FL3-R301-TS2												
Date		8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022												
Lab Sample ID		460-264626-21	460-264626-20	460-264626-32	460-264626-33	460-264626-37	460-264626-38	460-264626-39	460-264626-34	460-264626-35	460-264626-36	460-264626-26	460-264626-27												
Matrix		Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water												
Units		ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l												
		Result	RL	Result	RL	Result	RL	Result	RL	Result	RL	Result	RL	Result	RL										
Metals																									
Lead	15	0.48 J	2	5.2	2	ND	2	ND	2	ND	2	ND	2	ND	2	ND	2	ND	2	ND	2	1 J	2	0.3 J	2

Station Name	NJDEP Drinking Water Standards	TJ-FL3-R301-TS3	TJ-FL3-R312-TS1	TJ-FL3-R312-TS2	TJ-FL3-R312TS3	TJ-FL3-R323-TS					
Date		8/30/2022	8/30/2022	8/30/2022	8/30/2022	8/30/2022					
Lab Sample ID		460-264626-28	460-264626-29	460-264626-30	460-264626-31	460-264626-40					
Matrix		Water	Water	Water	Water	Water					
Units		ug/l	ug/l	ug/l	ug/l	ug/l					
		Result	RL	Result	RL	Result	RL				
Metals											
Lead	15	0.67 J	2	ND	2	ND	2	0.31 J	2	0.36 J	2

Note: *PEO sample was collected from the water line point of entry and is not a drinking water outlet.